

OKHOTSKIY-PEREVOZ, Russian Federation

WMO: 248710

Lat: 61.877N

Lon: 135.529E

Elev: 141

StdP: 99.65

Time Zone: 9.00 (E09)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-53.1	-51.1	-54.8	0.0	-52.7	-52.8	0.0	-51.1	3.3	-26.6	2.9	-30.8	0.1	170	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	28.1	18.3	26.3	17.6	24.3	16.8	19.8	25.5	18.7	24.0	17.8	22.8	2.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.1	21.8	16.8	12.2	20.8	15.8	11.4	19.9	57.5	25.5	53.9	23.9	50.9	23.1	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.5	4.5	3.9	-52.9	31.7	2.8	1.2	-54.9	32.6	-56.6	33.3	-58.2	34.0	-60.2	34.9		
(5)			-53.0	21.7	2.6	1.3	-54.9	22.6	-56.5	23.4	-58.0	24.1	-59.9	25.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.9	-41.7	-36.6	-20.9	-5.4	6.9	15.0	18.0	14.9	5.7	-8.2	-28.6	-39.1
	DBStd	22.43	6.41	6.12	8.21	6.27	4.38	3.43	3.56	3.34	4.26	7.11	8.18	7.37
	HDD10.0	7837	1603	1304	959	462	115	3	1	4	139	565	1159	1522
	HDD18.3	10348	1861	1538	1218	712	356	107	50	114	378	823	1409	1781
	CDD10.0	585	0	0	0	0	17	154	248	155	11	0	0	0
	CDD18.3	54	0	0	0	0	0	8	39	7	0	0	0	0
	CDH23.3	594	0	0	0	0	6	121	386	83	0	0	0	0
	CDH26.7	126	0	0	0	0	1	18	98	9	0	0	0	0
Wind	WSAvg	1.5	0.6	0.8	1.4	2.0	2.3	2.0	1.8	1.7	1.8	1.6	1.0	0.7
Precipitation	PrecAvg	407	12	8	11	19	39	49	71	63	56	41	26	11
	PrecMax	550	34	21	57	66	66	93	130	128	112	104	93	37
	PrecMin	291	2	2	1	3	12	18	30	22	17	14	3	2
	PrecStd	65	8	5	11	12	14	16	27	23	25	19	19	7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-17.6	-15.3	2.3	11.7	23.3	29.2	31.6	27.8	21.0	7.3	-0.4	-13.4
		MCWB	-17.9	-15.7	-0.8	4.3	11.3	18.0	20.0	18.5	13.3	4.3	-1.0	-13.9
	2%	DB	-25.3	-20.7	-0.6	8.6	19.8	26.7	29.2	25.8	17.6	4.7	-8.1	-18.3
		MCWB	-25.6	-21.0	-3.1	2.5	9.5	16.4	19.1	17.9	11.5	2.6	-8.6	-18.6
	5%	DB	-29.2	-24.4	-2.9	6.4	17.4	24.8	27.4	23.5	15.0	2.7	-12.7	-24.4
		MCWB	-29.4	-24.7	-5.0	1.3	8.8	15.6	18.4	17.4	10.2	0.8	-13.1	-24.5
	10%	DB	-32.6	-27.3	-5.8	4.6	15.0	22.8	25.4	21.4	12.9	0.9	-17.3	-28.8
		MCWB	-32.7	-27.5	-7.5	0.3	7.7	14.7	17.9	15.9	9.2	-0.3	-17.6	-29.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-17.9	-15.7	-0.4	4.5	12.6	19.2	21.9	20.5	14.0	4.5	-0.8	-13.9
		MCDB	-17.7	-15.2	2.0	10.8	21.8	26.2	28.5	24.7	18.4	6.5	-0.4	-13.6
	2%	WB	-25.4	-21.0	-2.9	2.8	10.4	17.9	20.4	19.1	12.5	2.8	-8.5	-18.5
		MCDB	-25.2	-20.8	-1.0	7.5	17.4	24.8	26.6	23.6	16.2	4.3	-8.2	-18.1
	5%	WB	-29.3	-24.6	-5.0	1.6	9.3	16.7	19.4	17.8	11.1	1.2	-13.1	-24.6
		MCDB	-29.2	-24.4	-2.8	6.0	15.6	22.6	25.1	21.9	14.1	2.5	-12.7	-24.5
	10%	WB	-32.6	-27.5	-7.6	0.5	8.3	15.6	18.5	16.8	9.7	-0.5	-17.6	-28.9
		MCDB	-32.5	-27.3	-5.8	4.1	14.0	21.1	23.8	20.5	12.4	0.9	-17.3	-28.7
Mean Daily Temperature Range	5% DB	MDBR	6.4	11.1	17.3	14.8	11.2	11.8	11.0	11.2	10.2	7.6	7.9	6.0
		MCDBR	10.2	13.5	15.6	13.8	16.2	15.7	14.9	14.1	14.2	8.1	10.0	11.5
		MCWBR	10.1	13.1	13.2	8.7	7.8	6.9	6.3	7.1	8.7	5.8	9.8	11.2
	5% WB	MCDBR	10.2	13.3	14.8	12.1	13.1	13.5	12.2	12.2	11.5	7.2	10.1	11.7
		MCWBR	10.0	13.1	12.6	7.9	6.6	6.7	5.7	6.7	7.5	5.4	9.8	11.4
Clear-Sky Solar Irradiance	taub		0.204	0.253	0.302	0.371	0.426	0.414	0.508	0.437	0.346	0.284	0.215	0.173
	taud		1.995	2.097	2.059	1.983	2.109	2.273	1.983	2.169	2.397	2.278	1.993	1.896
	Ebn at Noon		498	712	794	799	787	810	706	733	758	671	456	339
	Edh at Noon		37	70	106	143	138	119	156	119	79	59	36	22
All-Sky Solar Radiation	RadAvg		0.38	1.39	3.12	4.97	5.21	5.84	5.35	4.17	2.48	1.19	0.52	0.18
	RadStd		0.02	0.05	0.11	0.20	0.38	0.39	0.29	0.33	0.28	0.09	0.04	0.01

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	+0.58	+0.99	N/A	N/A	N/A	N/A	-198	-207	N/A	N/A

Nomenclature: See separate page