

LENSK, Russian Federation

WMO: 249230

Lat: 60.7250N

Lon: 114.8360E

Elev: 792

StdP: 14.28

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-51.2	-46.3	-55.3	0.2	-51.3	-50.5	0.3	-46.3	21.0	-3.4	19.0	-3.8	1.2	270	0.701

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.1	84.6	65.9	80.8	64.6	77.0	62.6	68.4	79.8	66.5	77.2	64.5	74.2	5.5	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.4	93.3	73.2	62.4	86.9	71.5	60.5	81.2	69.2	33.2	79.4	31.7	77.6	30.1	73.9	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.5	15.1	13.6	-52.8	91.2	5.9	2.8	-57.0	93.2	-60.5	94.8	-63.8	96.4	-68.1	98.5	DB WB
			-52.8	72.4	5.9	1.8	-57.0	73.7	-60.5	74.8	-63.8	75.8	-68.1	77.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.9	-19.4	-11.5	6.6	26.5	43.2	59.7	63.9	57.5	43.0	23.8	-2.4	-18.6
	DBStd	32.14	16.48	14.06	14.13	9.92	7.88	8.12	6.53	6.50	7.21	10.99	17.04	17.31
	HDD50	10936	2151	1722	1345	705	239	15	1	15	232	812	1573	2126
	HDD65	15493	2616	2142	1810	1155	676	197	100	245	661	1277	2023	2591
	CDD50	1031	0	0	0	0	28	305	431	246	21	0	0	0
	CDD65	113	0	0	0	0	0	37	65	11	0	0	0	0
	CDH74	1473	0	0	0	0	12	557	746	157	1	0	0	0
	CDH80	402	0	0	0	0	1	158	215	28	0	0	0	0
Wind	WSAvg	5.9	6.4	6.1	5.8	6.1	6.4	5.3	4.8	4.8	5.7	6.3	6.4	6.1
Precipitation	PrecAvg	16.3	0.8	0.6	0.6	0.7	1.3	2.0	2.5	2.6	1.8	1.5	1.3	0.8
	PrecMax	21.9	1.6	1.1	1.1	1.7	3.6	4.4	6.8	5.3	3.9	3.0	2.2	1.8
	PrecMin	11.3	0.3	0.4	0.1	0.2	0.4	0.5	0.4	0.9	0.5	0.6	0.4	0.4
	PrecStd	2.9	0.4	0.2	0.2	0.4	0.7	1.0	1.5	1.2	1.0	0.7	0.5	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.0	26.1	44.5	56.7	76.3	88.7	90.9	83.6	69.2	49.0	35.3	25.3
		MCWB	18.5	24.4	35.0	42.0	55.5	65.6	68.9	67.2	56.1	41.8	32.5	23.8
	2%	DB	13.8	19.7	36.5	51.4	69.2	84.5	85.6	78.4	63.8	44.0	32.1	18.4
		MCWB	12.5	18.1	29.8	39.4	51.0	64.3	67.3	64.2	52.0	38.9	30.7	17.3
	5%	DB	9.7	14.6	31.3	46.8	64.4	80.6	81.7	74.1	58.9	40.7	29.0	12.9
		MCWB	8.6	13.2	27.0	36.7	48.2	63.0	65.7	61.6	50.1	36.7	27.7	11.8
	10%	DB	4.6	9.6	27.6	42.4	59.6	76.3	78.1	70.2	54.9	37.3	23.2	7.1
		MCWB	3.7	8.4	24.0	34.1	46.3	60.7	64.7	59.9	48.1	34.4	22.0	6.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.5	24.3	35.2	42.8	57.4	69.3	71.7	69.0	57.5	43.0	33.2	24.3
		MCDB	19.6	25.7	44.1	53.0	70.5	81.0	84.7	80.1	66.1	46.0	34.2	25.3
	2%	WB	12.8	18.0	30.5	40.1	53.2	66.8	69.4	65.9	54.0	39.6	30.8	17.3
		MCDB	13.8	19.5	35.2	50.1	66.5	80.1	81.7	75.8	60.8	43.4	32.0	18.3
	5%	WB	8.7	13.2	27.3	37.4	49.8	64.5	67.7	63.7	51.4	37.0	27.7	12.0
		MCDB	9.7	14.5	31.5	45.5	62.2	77.0	78.2	71.5	56.5	40.0	29.2	13.0
	10%	WB	3.7	8.5	24.0	34.9	46.7	62.2	65.8	61.5	49.1	34.5	22.0	6.2
		MCDB	4.5	9.6	27.4	41.3	58.6	73.6	75.4	68.3	54.6	37.1	23.3	7.1
Mean Daily Temperature Range	5% DB	MDBR	12.9	17.2	23.6	21.1	20.0	22.5	20.1	19.4	15.2	11.9	13.1	12.6
		MCDBR	15.7	16.3	21.5	24.9	30.1	30.0	28.0	28.3	23.4	13.9	13.7	14.2
		MCWBR	15.3	15.4	16.8	14.9	15.4	12.8	12.9	14.9	13.3	9.8	13.3	14.0
	5% WB	MCDBR	15.6	16.3	20.1	21.4	26.7	25.4	24.1	23.2	19.9	12.5	13.2	14.5
		MCWBR	15.2	15.4	15.9	13.3	14.8	11.8	12.5	13.2	12.3	9.5	13.0	14.3
Clear-Sky Solar Irradiance	taub	0.245	0.280	0.306	0.341	0.369	0.411	0.451	0.418	0.334	0.293	0.244	0.213	
	taud	1.955	2.029	2.068	2.118	2.309	2.294	2.294	2.182	2.244	2.460	2.333	2.001	1.892
	Ebn at Noon	147	216	254	268	271	259	243	242	250	219	145	105	
	Edh at Noon	15	25	35	40	36	37	41	36	24	19	13	10	
All-Sky Solar Radiation	RadAvg	137	436	951	1462	1632	1788	1612	1268	774	358	169	74	
	RadStd	8	30	62	105	106	162	140	85	77	42	19	4	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page