

OLYOKMINSK, Russian Federation

WMO: 249440

Lat: 60.400N

Lon: 120.417E

Elev: 230

StdP: 98.60

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-46.7	-44.7	-48.3	0.0	-46.5	-46.2	0.0	-44.7	8.6	-17.4	7.6	-19.0	1.3	40	0.698

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	29.3	19.1	27.3	18.3	25.3	17.4	20.5	26.8	19.4	25.2	18.4	23.8	2.7	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	13.6	22.9	17.3	12.7	21.9	16.2	11.9	21.0	60.3	27.0	56.4	25.1	53.1	24.1	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.5	5.6	DB	-48.3	32.3	3.0	1.5	-50.5	33.4	-52.3	34.3	-54.0	35.2	-56.2	36.3	(4)
(5)			WB	-48.3	22.3	3.0	1.0	-50.5	23.0	-52.3	23.7	-54.0	24.2	-56.2	25.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.6	-30.9	-25.7	-14.5	-2.6	7.2	15.6	18.3	14.7	6.1	-4.9	-20.5	-30.7	(6)	
	DBStd	18.77	8.78	7.54	7.50	5.27	4.30	4.40	3.72	3.85	4.08	5.99	9.22	9.26	(7)	
	HDD10.0	6298	1266	999	760	377	109	8	1	7	129	463	916	1263	(8)	
	HDD18.3	8797	1524	1233	1018	627	346	102	48	122	368	722	1166	1521	(9)	
	CDD10.0	619	0	0	0	0	22	176	257	154	11	0	0	0	(10)	
	CDD18.3	77	0	0	0	0	0	20	46	11	0	0	0	0	(11)	
	CDH23.3	889	0	0	0	0	8	281	479	121	1	0	0	0	(12)	
	CDH26.7	234	0	0	0	0	1	69	142	22	0	0	0	0	(13)	
(14) Wind	WSAvg	2.5	2.1	2.3	2.6	3.0	3.1	2.5	2.3	2.2	2.5	2.6	2.3	2.1	(14)	
(15) Precipitation	PrecAvg	306	16	11	9	10	24	47	53	45	37	20	20	19	(15)	
	PrecMax	467	27	22	30	29	51	104	182	94	90	44	33	37	(16)	
	PrecMin	201	5	1	1	2	3	15	10	4	1	5	8	7	(17)	
	PrecStd	63	6	5	6	6	14	20	35	25	22	9	6	6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-8.2	-5.0	5.4	14.1	24.3	31.2	32.2	29.1	21.3	9.3	1.5	-5.4	(19)	
		MCWB	-8.8	-5.9	0.9	6.7	13.0	18.6	20.3	19.4	13.5	5.5	-0.1	-5.9	(20)	
	2%	DB	-12.1	-8.3	1.4	10.4	21.0	28.7	30.1	26.5	17.9	6.4	-0.8	-10.0	(21)	
		MCWB	-12.5	-9.1	-1.6	4.4	11.4	17.6	19.8	18.2	11.6	3.4	-1.6	-10.4	(22)	
	5%	DB	-14.9	-11.3	-1.3	7.7	18.3	26.6	28.1	24.3	15.2	4.4	-3.1	-12.8	(23)	
		MCWB	-15.3	-11.9	-3.4	2.7	9.6	16.9	19.5	17.2	10.2	2.0	-3.7	-13.1	(24)	
	10%	DB	-17.8	-14.3	-3.5	5.6	15.8	24.5	26.0	22.1	12.9	2.6	-7.2	-16.5	(25)	
		MCWB	-18.1	-14.8	-5.2	1.3	8.5	16.1	18.6	16.1	9.2	0.7	-7.9	-16.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-8.7	-5.7	1.0	7.0	14.2	20.1	22.3	20.8	14.3	5.9	0.3	-5.9	(27)	
		MCDB	-8.1	-4.8	5.2	13.5	21.9	27.5	28.6	26.7	19.4	8.2	0.9	-5.4	(28)	
	2%	WB	-12.5	-9.1	-1.4	4.8	12.0	18.9	21.1	19.2	12.4	4.0	-1.6	-10.3	(29)	
		MCDB	-12.1	-8.4	1.1	9.7	19.3	26.3	27.7	24.5	16.3	5.8	-0.8	-10.0	(30)	
	5%	WB	-15.3	-11.9	-3.2	3.1	10.5	17.9	20.2	18.1	11.0	2.2	-4.0	-13.0	(31)	
		MCDB	-15.0	-11.2	-1.3	7.2	17.0	24.6	26.3	22.7	14.2	4.0	-3.1	-12.8	(32)	
	10%	WB	-18.1	-14.8	-5.2	1.6	8.9	16.9	19.2	16.9	9.6	0.7	-7.9	-16.7	(33)	
		MCDB	-17.8	-14.3	-3.6	5.1	14.8	23.1	24.5	20.8	12.4	2.4	-7.2	-16.4	(34)	
(35) Mean Daily Temperature Range	MDBR		6.8	8.9	12.1	11.2	11.0	12.2	11.0	10.9	8.9	6.9	7.0	6.5	(35)	
	5% DB	MCDBR	8.0	9.9	11.5	13.0	16.0	16.1	14.8	14.7	13.6	8.3	8.0	8.8	(36)	
		MCWBR	7.8	9.3	9.1	8.2	8.1	7.0	6.4	7.0	7.9	5.9	7.7	8.8	(37)	
	5% WB	MCDBR	8.0	9.8	10.9	11.9	14.5	13.8	13.0	12.5	11.9	7.7	7.9	9.0	(38)	
		MCWBR	7.8	9.3	8.7	7.8	7.9	6.5	6.2	6.4	7.4	5.9	7.6	8.9	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.240	0.271	0.299	0.347	0.400	0.416	0.480	0.421	0.334	0.291	0.241	0.211	(40)	
	taud		1.979	2.057	2.094	2.138	2.222	2.279	2.087	2.244	2.461	2.375	2.037	1.908	(41)	
	Ebn at Noon		491	706	816	842	822	814	741	762	791	705	486	359	(42)	
	Edh at Noon		46	79	106	124	124	120	142	113	76	58	42	31	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.48	1.49	3.22	5.01	5.00	5.76	5.16	4.01	2.50	1.21	0.59	0.26	(44)	
	RadStd		0.03	0.07	0.12	0.25	0.43	0.47	0.44	0.30	0.22	0.12	0.07	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page