

UEGA, Russian Federation

WMO: 249820

Lat: 60.717N

Lon: 142.783E

Elev: 1304

StdP: 14.02

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-39.2	-34.8	-43.5	0.5	-38.5	-39.4	0.6	-34.3	11.4	6.9	10.0	4.8	1.4	330	0.721

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.9	79.4	60.7	75.4	59.2	71.6	57.5	63.0	75.5	60.9	71.5	59.0	68.5	4.7	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.4	76.5	66.0	56.6	71.6	63.8	55.0	67.6	61.7	29.2	76.7	27.7	71.6	26.4	68.3	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	9.1	7.7	-42.7	84.9	4.7	2.8	-46.1	86.9	-48.8	88.6	-51.4	90.2	-54.8	92.2		
(5)			-42.2	66.1	4.7	3.1	-45.6	68.3	-48.3	70.1	-50.9	71.8	-54.3	74.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.8	-12.7	-4.2	6.0	23.2	39.2	52.3	57.8	55.6	42.6	22.4	-1.3	-9.5		
	DBStd	27.04	12.30	12.25	9.87	8.25	6.24	6.12	4.63	5.11	7.27	9.88	11.22	12.53		
	HDD50	10504	1944	1518	1363	805	338	42	2	13	238	857	1540	1844		
	HDD65	15425	2409	1938	1828	1255	799	382	228	292	673	1322	1990	2309		
	CDD50	563	0	0	0	0	3	112	245	188	15	0	0	0		
	CDD65	10	0	0	0	0	0	2	6	2	0	0	0	0		
	CDH74	401	0	0	0	0	0	137	219	45	0	0	0	0		
	CDH80	73	0	0	0	0	0	24	48	1	0	0	0	0		
	WSAvg	3.6	3.5	4.0	4.2	3.7	3.4	3.2	3.3	3.1	3.2	3.9	4.1	4.1		
	PrecAvg	18.1	0.2	0.1	0.4	1.0	1.5	2.4	3.6	3.2	2.8	1.8	0.8	0.3		
(15) Precipitation	PrecMax	23.9	0.9	0.6	1.6	3.1	3.8	5.7	9.2	9.0	6.7	4.2	3.9	1.9		
	PrecMin	9.8	0.0	0.0	0.0	0.0	0.1	0.8	1.0	1.0	0.7	0.2	0.0	0.0		
	PrecStd	4.4	0.2	0.1	0.4	0.8	1.1	1.3	2.1	1.9	1.5	1.1	0.8	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.2	26.9	35.1	48.5	69.3	83.5	88.2	78.9	67.8	47.9	31.0	21.9		
		MCWB	19.1	22.8	27.5	37.6	50.6	61.5	65.1	62.6	53.6	37.4	28.4	19.1		
	2%	DB	15.6	22.9	30.3	44.0	63.2	78.5	80.8	74.8	61.4	42.6	26.6	16.8		
		MCWB	13.0	19.3	24.6	33.8	47.6	58.6	62.4	59.9	50.1	35.0	23.8	14.2		
	5%	DB	10.4	18.9	25.9	40.8	58.7	73.9	76.3	71.7	58.0	38.3	20.9	13.0		
		MCWB	8.5	15.7	20.9	32.0	45.2	56.4	59.9	58.2	48.8	33.0	18.7	10.4		
	10%	DB	6.4	14.2	22.1	37.3	54.7	69.2	72.3	68.0	54.9	35.1	16.7	9.1		
		MCWB	4.8	11.7	18.0	30.1	43.3	54.5	58.4	57.1	48.5	31.0	14.8	7.1		
	0.4%	WB	19.3	23.1	28.5	37.6	52.0	63.1	66.7	64.5	55.8	38.6	28.4	19.5		
		MCDB	20.7	26.6	34.0	47.8	67.4	78.6	83.3	74.3	62.3	45.4	30.6	20.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	13.4	19.6	24.5	34.6	48.7	60.3	64.1	62.0	53.5	35.8	23.4	13.9		
		MCDB	15.8	22.7	29.7	42.6	61.1	75.7	77.2	71.6	57.1	41.0	26.1	16.6		
	5%	WB	8.5	15.8	21.1	32.6	46.0	58.1	61.8	60.0	51.8	33.7	19.0	10.5		
		MCDB	10.4	18.6	25.6	39.3	57.2	70.8	73.5	68.5	54.8	36.9	20.6	12.9		
	10%	WB	4.8	11.6	18.1	30.7	43.9	55.9	59.9	58.1	49.7	32.1	14.8	7.2		
		MCDB	6.3	14.3	22.2	36.6	53.7	66.9	69.1	65.2	53.9	34.6	16.6	9.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.0	19.8	23.4	21.1	21.5	23.5	20.9	19.3	18.2	17.0	15.9	14.1		
		MCDBR	14.9	15.6	22.5	23.7	32.3	36.9	34.2	28.3	24.3	19.6	13.0	13.3		
		MCWBR	13.5	13.2	17.8	15.3	18.1	18.6	17.2	14.8	13.6	13.0	11.1	11.8		
		MCDBR	14.9	15.7	21.8	21.5	29.9	31.6	27.4	23.1	15.5	16.2	12.4	13.0		
	5% WB	MCWBR	13.4	13.5	17.3	14.3	17.3	16.7	14.9	13.3	9.9	11.1	10.8	11.6		
(40) Clear-Sky Solar Irradiance	taub		0.200	0.247	0.300	0.398	0.420	0.392	0.431	0.397	0.319	0.274	0.216	0.173		
	taud		2.077	2.149	2.058	1.819	1.967	2.313	2.231	2.308	2.474	2.260	2.057	1.956		
	Ebn at Noon		185	239	256	245	252	265	249	249	256	224	167	139		
	Edh at Noon		12	22	35	54	51	37	39	33	23	20	12	9		
(44) All-Sky Solar Radiation	RadAvg		134	457	1044	1636	1736	1710	1516	1211	830	492	194	68		
	RadStd		12	29	44	80	148	162	200	138	106	51	19	3		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page