

UEGA, Russian Federation

WMO: 249820

Lat: 60.717N

Lon: 142.783E

Elev: 398

StdP: 96.64

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-39.5	-37.1	-42.0	0.1	-39.2	-39.7	0.1	-36.8	5.1	-14.0	4.5	-15.1	0.6	330	0.721

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.6	(c) 26.3	(d) 15.9	(e) 24.1	(f) 15.1	(g) 22.0	(h) 14.2	(i) 17.2	(j) 24.2	(k) 16.1	(l) 22.0	(m) 15.0	(n) 20.3	(o) 2.1	(p) 170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.7	10.9	18.9	13.7	10.2	17.6	12.8	9.7	16.5	50.1	24.8	46.6	22.0	43.4	20.2	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
4.6	4.1	3.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-41.5	29.4	2.6	1.6	-43.4	30.5	-44.9	31.4	-46.3	32.3	-48.2	33.5		
			-41.2	18.9	2.6	1.7	-43.1	20.2	-44.6	21.2	-46.1	22.1	-47.9	23.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.1	-24.8	-20.1	-14.4	-4.9	4.0	11.3	14.4	13.1	5.9	-5.4	-18.5	-23.0
	DBStd	15.02	6.83	6.81	5.48	4.58	3.47	3.40	2.57	2.84	4.04	5.49	6.23	6.96
	HDD10.0	5836	1080	843	757	447	188	23	1	7	132	476	856	1024
	HDD18.3	8569	1338	1077	1016	697	444	212	127	162	374	734	1106	1283
	CDD10.0	313	0	0	0	0	2	62	136	104	8	0	0	0
	CDD18.3	6	0	0	0	0	0	1	3	1	0	0	0	0
	CDH23.3	223	0	0	0	0	0	76	122	25	0	0	0	0
	CDH26.7	41	0	0	0	0	0	13	27	1	0	0	0	0
Wind	WSAvg	1.6	1.6	1.8	1.9	1.6	1.5	1.5	1.5	1.4	1.4	1.7	1.8	1.8
Precipitation	PrecAvg	459	5	3	11	26	39	61	92	82	71	46	21	7
	PrecMax	606	22	14	41	79	96	144	234	229	169	107	98	47
	PrecMin	249	0	0	1	1	3	20	25	26	19	4	1	0
	PrecStd	112	5	3	11	21	27	34	54	47	39	29	21	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-6.0	-2.8	1.7	9.2	20.7	28.6	31.2	26.0	19.9	8.8	-0.6	-5.6
		MCWB	-7.2	-5.1	-2.5	3.1	10.3	16.4	18.4	17.0	12.0	3.0	-2.0	-7.2
	2%	DB	-9.1	-5.1	-0.9	6.7	17.3	25.8	27.1	23.8	16.3	5.9	-3.0	-8.4
		MCWB	-10.5	-7.0	-4.1	1.0	8.7	14.8	16.9	15.5	10.0	1.6	-4.5	-9.9
	5%	DB	-12.0	-7.3	-3.4	4.9	14.9	23.3	24.6	22.1	14.5	3.5	-6.2	-10.5
		MCWB	-13.1	-9.0	-6.2	0.0	7.4	13.6	15.5	14.5	9.3	0.5	-7.4	-12.0
	10%	DB	-14.2	-9.9	-5.5	3.0	12.6	20.7	22.4	20.0	12.7	1.7	-8.5	-12.7
		MCWB	-15.1	-11.3	-7.8	-1.1	6.3	12.5	14.7	13.9	9.1	-0.6	-9.5	-13.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-7.1	-5.0	-1.9	3.1	11.1	17.3	19.3	18.1	13.2	3.7	-2.0	-7.0
		MCDB	-6.3	-3.0	1.1	8.8	19.6	25.9	28.5	23.5	16.8	7.5	-0.8	-6.2
	2%	WB	-10.3	-6.9	-4.2	1.4	9.3	15.7	17.8	16.6	11.9	2.1	-4.8	-10.0
		MCDB	-9.0	-5.1	-1.3	5.9	16.2	24.3	25.1	22.0	13.9	5.0	-3.3	-8.5
	5%	WB	-13.0	-9.0	-6.1	0.3	7.8	14.5	16.6	15.6	11.0	0.9	-7.2	-11.9
		MCDB	-12.0	-7.5	-3.6	4.0	14.0	21.6	23.1	20.3	12.7	2.7	-6.3	-10.6
	10%	WB	-15.1	-11.3	-7.7	-0.7	6.6	13.3	15.5	14.5	9.8	0.0	-9.6	-13.8
		MCDB	-14.3	-9.8	-5.5	2.5	12.0	19.4	20.6	18.4	12.2	1.4	-8.6	-12.7
Mean Daily Temperature Range	5% DB	MDBR	9.4	11.0	13.0	11.7	11.9	13.1	11.6	10.7	10.1	9.4	8.8	7.8
		MCDBR	8.3	8.6	12.5	13.1	17.9	20.5	19.0	15.7	13.5	10.9	7.2	7.4
		MCWBR	7.5	7.3	9.9	8.5	10.1	10.3	9.6	8.2	7.6	7.2	6.2	6.6
	5% WB	MCDBR	8.3	8.7	12.1	11.9	16.6	17.5	15.2	12.8	8.6	9.0	6.9	7.2
		MCWBR	7.5	7.5	9.6	7.9	9.6	9.3	8.3	7.4	5.5	6.1	6.0	6.5
Clear-Sky Solar Irradiance	taub		0.200	0.247	0.300	0.398	0.420	0.392	0.431	0.397	0.319	0.274	0.216	0.173
	taud		2.077	2.149	2.058	1.819	1.967	2.313	2.231	2.308	2.474	2.260	2.057	1.956
	Ebn at Noon		582	752	808	771	794	836	786	786	808	706	527	439
	Edh at Noon		39	70	109	171	160	116	123	105	74	62	39	27
All-Sky Solar Radiation	RadAvg		0.42	1.44	3.29	5.16	5.47	5.39	4.78	3.82	2.62	1.55	0.61	0.21
	RadStd		0.04	0.09	0.14	0.25	0.47	0.51	0.63	0.43	0.33	0.16	0.06	0.01

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page