

BUHTA AMBARCHIK, Russian Federation

WMO: 250340

Lat: 69.624N

Lon: 162.298E

Elev: 76

StdP: 14.66

Time Zone: 11.00 (E11)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-41.4	-39.0	-44.9	0.4	-40.9	-42.1	0.5	-38.6	39.7	-18.0	36.8	-14.0	8.8	230	1.057

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	70.9	59.0	66.1	56.1	61.4	53.9	60.4	68.8	57.1	65.2	54.0	60.8	13.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.6	68.5	63.9	52.8	59.6	61.7	49.6	52.7	57.9	26.8	69.4	24.6	65.3	22.7	61.0	69.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.9	32.8	28.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.5	-19.2	-19.4	-9.7	9.4	25.9	40.6	46.1	43.3	36.4	18.9	0.4	-13.3
	DBStd	26.56	12.17	13.31	12.68	10.62	9.75	9.84	8.48	8.93	6.92	10.71	13.86	14.05
	HDD50	13503	2144	1944	1852	1218	749	324	186	253	416	965	1488	1964
	HDD65	18822	2609	2364	2317	1668	1213	733	589	674	858	1430	1938	2429
	CDD50	160	0	0	0	0	0	41	65	47	7	0	0	0
	CDD65	6	0	0	0	0	0	1	3	2	0	0	0	0
	CDH74	41	0	0	0	0	0	4	31	6	0	0	0	0
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	12.3	13.7	13.2	12.2	10.3	11.0	11.6	11.1	12.2	11.4	11.9	13.9	15.5
Precipitation	PrecAvg	5.4	0.2	0.2	0.2	0.2	0.2	0.6	0.9	0.9	0.8	0.6	0.4	0.3
	PrecMax	8.9	0.6	0.4	0.6	0.4	0.7	1.4	2.2	2.0	2.3	1.5	0.8	1.2
	PrecMin	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.1	0.1	0.1	0.0
	PrecStd	2.0	0.2	0.1	0.2	0.1	0.2	0.4	0.7	0.5	0.6	0.3	0.2	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.5	26.6	26.3	36.6	55.4	74.2	78.4	73.4	65.9	41.7	33.3	34.5
		MCWB	26.6	22.9	24.9	33.2	44.6	56.2	62.3	64.4	52.9	38.9	30.5	32.0
	2%	DB	14.3	15.0	17.8	33.0	47.6	69.0	71.9	67.5	56.5	37.5	29.7	18.8
		MCWB	13.2	14.1	16.4	30.3	41.4	54.6	60.1	59.8	49.0	36.1	28.3	17.6
	5%	DB	2.1	2.8	13.8	28.8	42.2	64.0	66.5	62.6	50.1	35.3	26.3	11.0
		MCWB	1.3	2.1	12.4	26.4	37.8	52.6	57.1	56.0	45.2	34.5	24.6	10.4
	10%	DB	-3.4	-3.5	9.6	25.0	38.7	58.5	61.4	57.3	45.7	32.6	20.5	5.7
		MCWB	-3.8	-4.0	8.5	23.0	35.1	49.8	55.5	52.3	42.1	31.8	19.1	5.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.1	23.4	25.0	33.9	45.6	57.9	63.4	66.1	53.4	39.3	30.8	31.3
		MCDB	29.0	26.0	26.5	36.2	54.2	71.2	74.0	72.1	63.7	40.7	32.6	33.4
	2%	WB	13.0	13.7	16.6	30.3	41.5	55.3	60.7	61.5	49.3	36.4	28.6	17.7
		MCDB	13.9	15.1	17.9	33.5	47.8	67.3	70.3	66.4	55.1	37.3	30.1	19.1
	5%	WB	1.4	2.3	12.5	26.6	37.8	52.7	58.6	55.7	45.8	34.5	24.5	10.3
		MCDB	2.0	3.0	13.7	28.8	41.8	63.7	65.9	61.6	49.7	35.3	26.2	10.8
	10%	WB	-3.9	-3.9	8.5	23.1	35.2	49.7	55.5	52.4	42.3	31.9	19.1	5.1
		MCDB	-3.4	-3.5	9.6	24.9	37.9	58.5	61.5	57.0	45.3	32.5	20.4	5.7
Mean Daily Temperature Range	5% DB	MDBR	10.2	8.1	10.2	12.3	9.9	11.0	12.1	10.3	7.8	7.3	10.5	9.5
		MCDBR	19.9	17.1	14.2	15.1	14.1	21.7	23.6	19.1	14.5	6.8	12.2	16.2
		MCWBR	18.7	16.6	13.5	13.2	9.2	12.0	14.3	12.4	9.8	6.3	10.5	14.7
	5% WB	MCDBR	19.7	16.8	14.5	14.3	13.5	20.8	22.3	17.7	13.4	6.8	11.8	15.2
		MCWBR	18.6	16.3	13.8	12.7	9.1	12.3	14.8	12.4	9.5	6.3	11.2	14.5
Clear-Sky Solar Irradiance	taub	0.164	0.212	0.285	0.330	0.358	0.350	0.397	0.382	0.313	0.247	N/A	N/A	
	taud	1.907	2.028	2.042	1.973	2.053	2.288	2.269	2.304	2.446	2.117	N/A	N/A	
	Ebn at Noon	10	171	223	248	257	266	246	234	225	148	0	0	
	Edh at Noon	1	13	27	40	42	34	34	30	19	12	0	0	
All-Sky Solar Radiation	RadAvg	3	117	654	1424	1972	1951	1566	1061	534	168	0	0	
	RadStd	1	18	32	49	114	137	129	98	42	23	0	0	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	+3.13	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page