

CHERSKY, Russian Federation

WMO: 251230

Lat: 68.7451N

Lon: 161.3380E

Elev: 92

StdP: 14.65

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-46.9	-43.5	-49.9	0.3	-46.1	-47.2	0.4	-43.1	16.8	-3.6	14.4	-11.4	4.5	130	0.843

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.9	78.1	62.7	73.9	60.4	69.9	58.0	63.9	74.4	61.6	71.8	59.2	68.2	6.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.7	76.6	68.4	56.9	69.2	65.7	54.4	63.2	64.1	29.3	74.3	27.6	72.2	26.0	68.3	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.7	14.5	12.8	-48.8	83.9	4.5	4.0	-52.1	86.8	-54.7	89.1	-57.3	91.4	-60.5	94.3		
			-48.4	68.4	3.6	3.5	-50.9	70.8	-53.0	72.9	-55.1	74.8	-57.7	77.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.9	-25.2	-23.2	-7.3	10.1	32.9	51.0	54.8	50.7	39.2	18.0	-3.9	-20.2
	DBStd	31.68	13.28	13.19	15.51	14.03	11.42	10.55	9.34	8.47	7.59	10.65	14.57	15.30
	HDD50	13278	2331	2049	1775	1197	538	116	54	98	334	992	1616	2178
	HDD65	18311	2796	2469	2240	1647	996	434	341	449	773	1457	2066	2643
	CDD50	485	0	0	0	0	8	145	202	119	11	0	0	0
	CDD65	42	0	0	0	0	0	12	25	5	0	0	0	0
	CDH74	352	0	0	0	0	0	101	211	40	0	0	0	0
	CDH80	57	0	0	0	0	0	11	43	3	0	0	0	0
Wind	WSAvg	6.0	4.8	4.8	5.6	5.8	6.9	7.5	7.1	6.7	6.8	5.7	5.2	5.2
Precipitation	PrecAvg	9.7	0.5	0.4	0.4	0.3	0.5	0.9	1.3	1.4	1.2	1.1	0.9	0.6
	PrecMax	15.9	1.1	1.7	0.9	0.7	1.2	2.1	3.7	3.0	2.2	2.9	1.7	1.6
	PrecMin	7.0	0.1	0.0	0.1	0.0	0.1	0.2	0.2	0.2	0.1	0.2	0.2	0.1
	PrecStd	2.2	0.2	0.4	0.2	0.2	0.3	0.6	0.8	0.7	0.6	0.7	0.4	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.3	25.2	33.4	43.1	66.5	81.6	85.3	78.9	65.1	43.7	34.6	33.5
		MCWB	24.8	22.9	30.2	36.2	51.1	61.9	66.8	64.4	54.5	40.0	31.5	29.8
	2%	DB	14.0	15.1	27.5	39.0	60.1	76.9	79.5	73.1	59.1	37.5	29.3	20.0
		MCWB	12.4	12.8	23.9	33.3	48.0	59.8	64.1	60.7	49.9	35.1	26.5	17.9
	5%	DB	-0.1	0.7	21.5	35.4	54.7	72.6	75.4	68.9	54.9	34.0	24.4	9.1
		MCWB	-0.8	-0.2	18.3	30.3	44.5	57.8	62.4	58.5	47.8	32.2	22.3	8.0
	10%	DB	-7.6	-5.8	16.3	31.0	50.2	68.6	70.9	64.9	50.9	31.1	17.3	0.7
		MCWB	-8.0	-6.2	13.9	27.0	41.9	55.4	60.0	56.4	45.5	29.3	16.1	0.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.0	22.5	29.9	36.7	51.9	63.9	69.2	66.5	55.8	40.4	31.9	29.9
		MCDB	28.4	25.7	33.0	41.6	63.9	77.0	81.3	77.1	63.2	43.5	33.9	33.4
	2%	WB	12.2	12.9	23.8	33.4	48.3	60.9	65.6	62.4	51.3	35.7	26.8	17.9
		MCDB	13.9	15.1	27.2	38.8	59.5	74.0	76.6	70.8	56.7	37.1	29.2	19.9
	5%	WB	-0.9	-0.1	18.3	30.5	45.0	58.7	62.8	59.5	48.6	32.4	22.3	8.0
		MCDB	-0.2	0.5	21.2	35.1	54.0	71.4	73.9	66.9	54.2	33.5	24.3	9.1
	10%	WB	-8.0	-6.3	13.9	27.1	42.0	56.1	60.6	57.1	45.9	29.5	16.1	0.2
		MCDB	-7.5	-5.8	16.4	31.1	49.8	67.2	69.9	64.2	50.4	30.7	17.4	0.7
Mean Daily Temperature Range	5% DB	MDBR	9.8	10.0	14.4	16.5	15.0	16.6	15.9	14.6	10.4	8.6	10.4	10.0
		MCDBR	21.4	20.0	17.3	15.4	21.0	20.8	21.4	20.7	17.8	10.1	16.5	20.8
		MCWBR	20.4	18.7	15.1	11.6	12.8	10.7	11.8	11.7	11.0	8.0	15.1	19.7
	5% WB	MCDBR	20.6	20.0	17.2	15.1	20.4	20.3	20.7	19.5	16.1	9.1	16.7	20.2
		MCWBR	19.5	18.7	15.2	11.5	12.9	11.4	12.9	12.3	10.7	7.7	15.5	19.2
Clear-Sky Solar Irradiance	taub	0.165	0.219	0.289	0.336	0.370	0.358	0.411	0.387	0.315	0.253	0.182	N/A	
	taud	1.921	2.070	2.074	2.015	2.194	2.424	2.264	2.298	2.463	2.146	1.922	N/A	
	Ebn at Noon	27	181	228	249	257	267	243	235	229	158	16	0	
	Edh at Noon	2	14	27	39	37	30	35	30	19	13	2	0	
All-Sky Solar Radiation	RadAvg	7	150	681	1438	1884	1892	1569	1113	573	186	24	0	
	RadStd	1	15	33	48	142	141	142	108	51	25	3	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (3 neighbors)	+3.13	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page