

SREDNEKOLYMSK, Russian FederationWMO: **252060**Lat: **67.468N**Lon: **153.722E**Elev: **69**StdP: **14.66**Time Zone: **11.00 (E11)**Period: **09-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-50.7	-47.7	-54.4	0.2	-50.2	-51.6	0.3	-47.8	14.5	-4.7	11.0	-13.1	2.9	160	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.8	80.2	63.4	75.9	60.9	72.0	59.1	65.6	76.7	62.9	72.8	60.3	69.5	5.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.0	80.4	70.8	58.4	73.2	67.8	55.9	66.6	65.3	30.6	77.8	28.5	73.2	26.7	69.5	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.6	9.5	-53.1	87.7	2.1	4.8	-54.6	91.2	-55.8	94.0	-57.0	96.7	-58.5	100.1		
(5)			-53.1	69.3	2.1	2.0	-54.6	70.7	-55.8	71.9	-57.0	73.0	-58.5	74.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.7	-28.7	-28.1	-9.6	14.9	36.9	53.9	58.0	52.7	40.0	16.6	-9.3	-24.2
	DBStd	33.84	11.97	10.90	13.17	12.07	11.09	8.97	8.69	7.60	7.96	10.75	12.62	11.32
	HDD50	13525	2438	2187	1848	1052	425	63	18	60	318	1036	1780	2300
	HDD65	18427	2903	2607	2313	1502	871	343	256	386	750	1501	2230	2765
	CDD50	628	0	0	0	0	18	181	267	144	18	0	0	0
	CDD65	55	0	0	0	0	0	11	39	5	0	0	0	0
	CDH74	565	0	0	0	0	3	123	378	60	1	0	0	0
	CDH80	127	0	0	0	0	0	11	112	4	0	0	0	0
Wind	WSAvg	4.3	3.3	3.2	3.6	4.5	5.6	5.7	5.0	4.8	4.6	4.3	3.7	3.5
Precipitation	PrecAvg	10.3	0.4	0.4	0.4	0.3	0.5	1.3	1.7	1.8	1.2	0.9	0.9	0.6
	PrecMax	16.9	0.9	1.1	1.1	0.6	1.3	3.1	4.2	4.9	3.1	4.4	1.5	1.7
	PrecMin	6.7	0.1	0.1	0.1	0.0	0.0	0.1	0.1	0.2	0.0	0.2	0.2	0.1
	PrecStd	2.7	0.2	0.2	0.3	0.2	0.4	0.7	0.9	1.1	0.8	0.8	0.4	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	11.1	28.9	44.6	70.6	81.5	87.8	80.2	70.5	38.2	23.0	7.2
		MCWB	12.5	10.4	23.4	35.6	52.6	60.1	65.7	65.0	55.7	34.0	21.5	6.6
	2%	DB	-0.3	-3.9	23.0	41.6	64.3	77.7	83.1	74.9	63.8	34.1	17.3	-0.2
		MCWB	-0.8	-4.2	19.3	33.9	50.7	58.7	65.2	61.7	51.7	32.1	16.4	-1.0
	5%	DB	-6.4	-7.9	17.8	38.5	58.3	74.0	77.9	71.0	58.6	32.3	12.3	-4.0
		MCWB	-6.7	-8.3	15.1	31.6	46.5	57.4	63.4	59.2	49.0	31.2	11.5	-4.4
	10%	DB	-11.5	-12.3	12.2	34.8	54.0	69.9	73.3	66.9	53.0	30.7	7.8	-8.2
		MCWB	-11.9	-12.7	10.6	29.3	43.7	55.6	61.6	57.9	45.9	29.3	7.1	-8.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	10.2	23.5	36.4	54.1	63.8	69.5	66.1	56.5	34.4	21.7	6.2
		MCDB	13.3	11.2	28.6	43.9	67.2	77.3	82.8	77.6	68.9	36.4	23.1	6.8
	2%	WB	-0.7	-4.3	19.1	33.9	50.7	60.4	67.0	63.2	53.3	32.4	16.4	-0.9
		MCDB	-0.3	-3.9	22.7	41.2	64.0	71.5	78.6	72.2	61.5	33.5	17.2	-0.4
	5%	WB	-6.8	-8.3	15.2	31.7	47.3	58.4	65.0	60.6	49.7	31.4	11.6	-4.4
		MCDB	-6.5	-7.9	17.7	37.9	57.5	71.3	75.3	69.3	57.4	32.4	12.3	-4.1
	10%	WB	-11.8	-12.7	10.5	29.3	44.0	56.4	62.3	58.2	46.5	29.2	7.1	-8.5
		MCDB	-11.5	-12.4	12.3	34.8	52.9	68.6	72.3	65.7	52.8	30.7	7.8	-8.1
Mean Daily Temperature Range	5% DB	MDBR	10.2	11.2	21.0	21.6	16.6	16.4	14.8	15.4	11.9	9.3	10.7	9.6
		MCDBR	13.2	13.5	25.5	21.5	22.6	23.8	22.6	24.5	23.6	8.3	14.2	12.1
		MCWBR	13.0	12.9	22.4	15.7	12.3	10.4	10.3	12.6	12.8	6.9	13.8	11.9
	5% WB	MCDBR	13.1	13.3	24.9	20.9	21.9	21.8	19.9	22.1	21.6	7.5	14.2	11.9
		MCWBR	12.8	12.8	21.9	15.5	12.1	10.7	10.9	12.6	12.1	6.6	13.7	11.7
Clear-Sky Solar Irradiance	taub		0.167	0.229	0.291	0.341	0.381	0.368	0.456	0.408	0.338	0.264	0.183	N/A
	taud		1.916	2.073	2.071	2.009	2.173	2.403	2.121	2.238	2.383	2.167	1.921	N/A
	Ebn at Noon		56	190	233	251	255	265	230	230	223	169	41	0
	Edh at Noon		3	16	28	40	38	32	41	33	22	14	3	0
All-Sky Solar Radiation	RadAvg		16	209	748	1526	1851	1812	1545	1122	605	214	40	0
	RadStd		1	16	30	43	128	118	156	113	84	22	5	0