

SREDNEKOLYMSK, Russian FederationWMO: **252060**Lat: **67.468N**Lon: **153.722E**Elev: **21**StdP: **101.07**Time Zone: **11.00 (E11)**Period: **09-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -45.9	(c) -44.3	(d) -48.0	(e) 0.0	(f) -45.7	(g) -46.4	(h) 0.0	(i) -44.3	(j) 6.5	(k) -20.4	(l) 4.9	(m) -25.0	(n) 1.3	(o) 160	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.2	26.8	17.4	24.4	16.0	22.2	15.1	18.7	24.8	17.1	22.7	15.7	20.8	2.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.1	11.5	21.5	14.7	10.5	19.9	13.3	9.5	18.5	53.2	25.4	48.5	22.9	44.3	20.8	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 5.5	(b) 4.7	(c) 4.2	(e) -47.3	(f) 31.0	(g) 1.2	(h) 2.7	(i) -48.1	(j) 32.9	(k) -48.8	(l) 34.4	(m) -49.4	(n) 35.9	(o) -50.3	(p) 37.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.6	-33.7	-33.4	-23.1	-9.5	2.7	12.2	14.5	11.5	4.5	-8.6	-23.0	-31.2
	DBStd	18.80	6.65	6.05	7.31	6.70	6.16	4.98	4.83	4.22	4.42	5.97	7.01	6.29
	HDD10.0	7514	1354	1215	1027	584	236	35	10	33	177	576	989	1278
	HDD18.3	10237	1613	1448	1285	834	484	191	142	214	417	834	1239	1536
	CDD10.0	349	0	0	0	0	10	101	148	80	10	0	0	0
	CDD18.3	31	0	0	0	0	0	6	22	3	0	0	0	0
	CDH23.3	314	0	0	0	0	2	68	210	33	1	0	0	0
	CDH26.7	71	0	0	0	0	0	6	62	2	0	0	0	0
Wind	WSAvg	1.9	1.5	1.4	1.6	2.0	2.5	2.5	2.2	2.1	2.1	1.9	1.7	1.6
Precipitation	PrecAvg	262	10	11	11	7	12	33	42	46	30	24	22	15
	PrecMax	430	22	29	27	16	34	79	106	125	78	112	38	42
	PrecMin	170	2	2	3	0	0	2	3	5	1	5	5	3
	PrecStd	69	5	6	7	5	9	18	24	29	21	21	9	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-10.1	-11.6	-1.7	7.0	21.5	27.5	31.0	26.8	21.4	3.4	-5.0	-13.8
		MCWB	-10.8	-12.0	-4.8	2.0	11.5	15.6	18.7	18.4	13.2	1.1	-5.8	-14.1
	2%	DB	-17.9	-19.9	-5.0	5.3	18.0	25.4	28.4	23.8	17.6	1.2	-8.2	-17.9
		MCWB	-18.2	-20.1	-7.1	1.0	10.4	14.8	18.4	16.5	11.0	0.1	-8.7	-18.3
	5%	DB	-21.3	-22.2	-7.9	3.6	14.6	23.3	25.5	21.7	14.8	0.2	-11.0	-20.0
		MCWB	-21.5	-22.4	-9.4	-0.2	8.0	14.1	17.4	15.1	9.5	-0.5	-11.4	-20.2
	10%	DB	-24.2	-24.6	-11.0	1.6	12.2	21.1	23.0	19.4	11.7	-0.7	-13.4	-22.3
		MCWB	-24.4	-24.8	-11.9	-1.5	6.5	13.1	16.4	14.4	7.7	-1.5	-13.8	-22.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-11.2	-12.1	-4.7	2.4	12.3	17.7	20.9	19.0	13.6	1.3	-5.7	-14.3
		MCDB	-10.4	-11.6	-1.9	6.6	19.5	25.2	28.2	25.3	20.5	2.5	-5.0	-14.0
	2%	WB	-18.2	-20.2	-7.2	1.1	10.4	15.8	19.4	17.4	11.8	0.2	-8.7	-18.3
		MCDB	-18.0	-20.0	-5.2	5.1	17.8	21.9	25.9	22.3	16.4	0.9	-8.2	-18.0
	5%	WB	-21.6	-22.4	-9.4	-0.2	8.5	14.7	18.4	15.9	9.8	-0.3	-11.4	-20.2
		MCDB	-21.4	-22.2	-7.9	3.3	14.2	21.8	24.1	20.7	14.1	0.2	-10.9	-20.0
	10%	WB	-24.3	-24.8	-11.9	-1.5	6.6	13.6	16.9	14.6	8.0	-1.5	-13.8	-22.5
		MCDB	-24.2	-24.7	-10.9	1.6	11.6	20.3	22.4	18.7	11.6	-0.7	-13.5	-22.3
Mean Daily Temperature Range	5% DB	MDBR	5.7	6.2	11.7	12.0	9.2	9.1	8.2	8.6	6.6	5.2	6.0	5.3
		MCDBR	7.3	7.5	14.1	12.0	12.5	13.2	12.6	13.6	13.1	4.6	7.9	6.7
		MCWBR	7.2	7.2	12.4	8.7	6.8	5.8	5.7	7.0	7.1	3.9	7.6	6.6
	5% WB	MCDBR	7.3	7.4	13.8	11.6	12.2	12.1	11.1	12.3	12.0	4.1	7.9	6.6
		MCWBR	7.1	7.1	12.1	8.6	6.7	6.0	6.1	7.0	6.7	3.7	7.6	6.5
Clear-Sky Solar Irradiance	taub		0.167	0.229	0.291	0.341	0.381	0.368	0.456	0.408	0.338	0.264	0.183	N/A
	taud		1.916	2.073	2.071	2.009	2.173	2.403	2.121	2.238	2.383	2.167	1.921	N/A
	Ebn at Noon		178	598	735	791	804	835	726	725	702	532	129	0
	Edh at Noon		11	49	89	127	121	100	129	103	69	44	10	0
All-Sky Solar Radiation	RadAvg		0.05	0.66	2.36	4.81	5.83	5.71	4.87	3.54	1.91	0.68	0.12	0.00
	RadStd		0.00	0.05	0.09	0.14	0.40	0.37	0.49	0.36	0.27	0.07	0.01	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page