

EGVEKINOT, Russian Federation

WMO: 253780

Lat: 66.3582N

Lon: 179.1130W

Elev: 85

StdP: 14.65

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.9	-24.0	-32.7	0.9	-26.6	-29.1	1.1	-23.4	45.4	-4.4	40.2	0.9	1.3	350	0.917

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	64.7	55.0	60.9	52.9	57.9	51.4	56.5	62.4	54.5	59.1	52.7	56.5	8.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.8	61.8	58.0	52.1	58.0	56.0	50.5	54.7	54.2	24.2	62.7	22.9	59.0	21.9	56.9	66.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
33.6	29.2	25.3	DB	-30.1	73.5	6.2	6.2	-34.6	78.0	-38.2	81.6	-41.7	85.1	-46.2	89.5	
			WB	-30.6	60.2	5.9	3.5	-34.8	62.7	-38.3	64.8	-41.6	66.7	-45.8	69.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	23.7	-0.3	1.9	2.7	14.4	30.9	43.9	51.1	49.3	41.2	28.0	14.7	5.2	(6)
(7)		DBStd	21.21	14.29	14.15	12.59	10.34	7.16	6.07	4.73	4.37	5.95	8.15	11.13	13.36	(7)
(8)		HDD50	9733	1558	1348	1467	1068	592	199	41	64	268	681	1058	1389	(8)
(9)		HDD65	15069	2023	1768	1932	1518	1056	632	432	486	714	1146	1508	1854	(9)
(10)		CDD50	140	0	0	0	0	1	17	74	44	4	0	0	0	(10)
(11)		CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)
(12)		CDH74	13	0	0	0	0	0	2	11	0	0	0	0	0	(12)
(13)		CDH80	3	0	0	0	0	0	1	2	0	0	0	0	0	(13)
(14)	Wind	WSAvg	10.0	12.7	12.4	9.8	9.8	8.2	7.3	8.2	8.3	8.2	10.8	10.6	13.5	(14)
(15)	Precipitation	PrecAvg	15.3	0.9	0.8	0.4	0.6	0.6	1.5	3.2	2.8	2.0	0.9	1.2	0.6	(15)
(16)		PrecMax	33.7	2.6	5.2	2.0	2.4	2.0	3.6	7.8	6.5	10.3	3.8	6.0	2.8	(16)
(17)		PrecMin	10.0	0.1	0.0	0.0	0.0	0.0	0.4	0.9	0.5	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	5.2	0.7	0.9	0.4	0.6	0.6	0.8	1.8	1.4	2.3	0.9	1.4	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.5	33.0	32.6	37.4	54.5	68.5	72.9	67.7	57.2	49.3	38.9	36.0	(19)
(20)		0.4%	MCWB	30.9	30.6	31.2	32.7	47.1	53.6	59.1	57.9	48.3	45.2	36.1	32.8	(20)
(21)		2%	DB	31.3	30.7	30.3	34.6	47.8	62.2	65.6	62.4	53.8	45.0	35.9	32.7	(21)
(22)		2%	MCWB	29.7	29.2	29.3	31.3	41.6	50.8	56.2	54.4	47.9	41.5	33.8	30.4	(22)
(23)		5%	DB	26.9	27.8	27.3	32.2	43.8	57.5	61.9	58.7	51.4	41.4	33.4	29.1	(23)
(24)		5%	MCWB	24.5	26.1	25.8	29.9	38.6	48.8	54.4	52.2	46.8	38.0	31.6	27.0	(24)
(25)		10%	DB	20.7	23.8	23.4	29.5	40.2	53.8	58.8	56.1	49.4	38.1	30.6	25.1	(25)
(26)		10%	MCWB	18.4	21.9	21.5	26.9	36.2	46.8	52.7	51.1	45.4	34.7	28.6	23.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.4	31.9	31.8	34.1	47.2	55.1	60.0	59.5	51.2	45.9	36.7	33.9	(27)
(28)		0.4%	MCDWB	32.9	32.5	32.4	36.3	54.5	66.1	68.4	65.6	54.1	48.6	38.2	35.4	(28)
(29)		2%	WB	29.3	29.2	29.4	32.0	42.2	51.8	57.4	55.7	49.3	42.0	34.2	30.8	(29)
(30)		2%	MCDWB	31.5	30.3	30.1	33.7	47.2	59.9	64.2	60.3	51.9	44.6	35.7	32.4	(30)
(31)		5%	WB	24.6	26.1	26.2	30.1	39.1	49.6	55.4	54.0	47.8	38.5	31.7	27.0	(31)
(32)		5%	MCDWB	26.6	27.6	27.3	32.3	43.2	56.3	60.5	57.2	50.2	40.8	33.2	29.2	(32)
(33)		10%	WB	18.2	21.9	21.4	27.0	36.5	47.5	53.6	52.3	46.0	35.0	28.7	23.1	(33)
(34)		10%	MCDWB	20.7	23.9	23.5	29.6	39.6	53.0	57.8	54.9	48.6	37.6	30.7	25.2	(34)
(35)	Mean Daily Temperature Range		MDBR	9.8	11.4	12.0	11.9	8.9	11.2	9.3	8.6	8.5	6.9	8.3	8.9	(35)
(36)		5% DB	MCDBR	14.1	12.7	11.2	11.0	14.3	19.5	16.1	13.5	10.8	6.6	7.0	11.5	(36)
(37)		5% DB	MCWBR	13.1	11.9	10.9	9.1	9.4	11.0	9.2	8.6	7.2	5.3	6.8	10.6	(37)
(38)		5% WB	MCDBR	14.4	12.3	10.9	10.1	13.7	17.6	14.0	11.2	8.9	5.7	6.9	11.2	(38)
(39)		5% WB	MCWBR	13.6	11.9	11.0	8.6	9.1	10.7	8.7	8.0	6.8	5.1	6.9	10.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.170	0.247	0.274	0.336	0.370	0.363	0.365	0.370	0.306	0.265	0.181	0.176	(40)	
(41)		taud	1.904	2.075	2.172	2.011	2.041	2.326	2.436	2.384	2.499	2.208	1.911	1.897	(41)	
(42)		Ebn at Noon	82	191	250	256	259	267	264	248	244	182	68	8	(42)	
(43)		Edh at Noon	5	17	26	41	44	34	30	29	20	15	5	1	(43)	
(44)	All-Sky Solar Radiation	RadAvg	27	208	760	1480	1789	1689	1466	1089	655	226	51	3	(44)	
(45)		RadStd	2	26	61	55	161	157	186	122	68	34	5	0	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (0 neighbors)	(m) N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page