

KORKODON, Russian FederationWMO: **255030**Lat: **64.750N**Lon: **153.967E**Elev: **324**StdP: **14.52**Time Zone: **11.00 (E11)**Period: **09-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -54.0	(c) -51.4	(d) -57.3	(e) 0.2	(f) -53.3	(g) -54.9	(h) 0.2	(i) -50.9	(j) 12.3	(k) -33.2	(l) 11.7	(m) -31.0	(n) 1.5	(o) 100	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	82.8	65.2	78.7	62.9	74.9	60.6	67.0	79.6	64.7	75.7	62.2	72.6	5.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.3	85.0	72.3	59.9	77.8	69.8	57.4	71.1	67.5	31.8	79.5	30.0	75.3	28.2	73.0	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 11.3	(b) 9.8	(c) 9.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.8	-33.2	-30.3	-7.1	18.3	40.9	56.3	60.8	53.2	40.6	15.8	-12.8	-27.5	(6)
(7)		DBStd	35.78	12.59	11.36	13.29	12.70	9.35	6.95	7.31	7.47	8.12	10.73	12.91	12.10	(7)
(8)		HDD50	13592	2579	2250	1770	952	310	26	6	53	298	1061	1885	2402	(8)
(9)		HDD65	18372	3044	2670	2235	1402	748	269	174	371	731	1526	2335	2867	(9)
(10)		CDD50	749	0	0	0	0	27	214	340	151	17	0	0	0	(10)
(11)		CDD65	55	0	0	0	0	0	7	44	4	0	0	0	0	(11)
(12)		CDH74	1020	0	0	0	0	13	210	667	129	1	0	0	0	(12)
(13)		CDH80	262	0	0	0	0	1	29	218	14	0	0	0	0	(13)
(14)	Wind	WSAvg	4.2	4.4	4.1	4.4	4.3	4.7	4.3	3.7	3.6	3.8	4.1	4.4	4.8	(14)
(15)	Precipitation	PrecAvg	10.2	0.7	0.6	0.4	0.3	0.5	0.9	1.7	1.6	1.0	0.8	0.8	0.7	(15)
(16)		PrecMax	15.7	2.6	1.5	1.4	0.9	1.2	2.1	4.2	4.4	3.3	1.8	2.1	1.5	(16)
(17)		PrecMin	5.7	0.1	0.2	0.0	0.0	0.0	0.0	0.1	0.2	0.3	0.1	0.0	0.1	(17)
(18)		PrecStd	2.4	0.5	0.3	0.4	0.3	0.3	0.6	0.9	0.9	0.7	0.4	0.5	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.5	-3.7	30.2	50.5	75.2	84.1	92.0	81.8	70.5	40.9	21.2	4.1	(19)
MCWB			2.4	-4.6	24.5	40.6	57.3	63.6	69.3	65.3	56.3	35.4	19.2	3.4	(20)	
2%		DB	-2.2	-8.3	25.9	44.4	69.1	79.6	85.5	78.0	64.4	35.3	12.4	-2.4	(21)	
		MCWB	-2.7	-9.0	21.2	35.8	52.3	60.7	66.4	63.7	52.6	32.2	11.6	-2.7	(22)	
5%		DB	-8.9	-10.4	21.1	41.4	64.0	76.1	81.4	73.7	59.6	32.7	8.7	-6.9	(23)	
		MCWB	-9.3	-11.0	17.6	33.6	49.7	58.8	65.7	61.1	49.9	30.1	7.7	-7.5	(24)	
10%		DB	-14.2	-13.2	15.1	38.3	59.1	72.4	77.0	69.4	55.2	30.4	5.4	-10.5	(25)	
		MCWB	-14.6	-13.7	12.7	31.7	46.7	57.1	63.1	58.9	48.0	28.0	4.5	-10.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.6	-4.5	24.7	40.7	57.2	65.4	71.6	67.4	57.1	35.8	19.0	3.5	(27)
MDCB			3.3	-3.9	29.7	50.4	75.8	80.1	85.2	76.8	68.7	39.7	20.9	4.0	(28)	
2%		WB	-2.9	-8.9	21.3	36.6	53.3	62.8	68.8	64.7	53.8	32.6	11.6	-2.9	(29)	
		MDCB	-2.4	-8.5	25.7	43.7	66.8	76.3	82.6	76.3	62.0	34.8	12.3	-2.6	(30)	
5%		WB	-9.2	-10.8	17.6	34.2	50.4	60.5	66.4	61.9	51.0	30.3	7.9	-7.3	(31)	
		MDCB	-9.0	-10.2	21.1	40.4	62.8	73.5	78.7	71.9	58.3	32.5	8.6	-6.8	(32)	
10%		WB	-14.4	-13.7	12.7	32.0	47.5	58.2	64.4	59.4	48.5	27.9	4.7	-10.9	(33)	
		MDCB	-14.1	-13.3	15.1	38.2	58.3	69.5	74.4	68.4	54.1	30.0	5.5	-10.6	(34)	
(35)	Mean Daily Temperature Range	MDBR	10.7	14.2	25.6	27.5	22.2	22.3	21.7	21.4	17.4	12.7	11.6	9.8	(35)	
5% DB		MCDBR	13.5	12.8	32.8	24.8	30.5	31.2	31.5	31.9	28.9	13.5	11.9	11.5	(36)	
		MCWBR	13.2	12.5	28.4	17.1	16.4	14.7	14.8	18.0	17.4	10.2	11.3	11.3	(37)	
		MCDBR	13.3	12.9	32.3	22.9	28.3	27.6	27.7	27.7	25.8	12.2	12.6	11.6	(38)	
5% WB		MCWBR	13.0	12.7	28.2	16.0	15.5	14.5	13.9	16.6	16.0	9.3	11.9	11.4	(39)	
																(39)
(40)	Clear-Sky Solar Irradiance	taub	0.166	0.241	0.297	0.353	0.387	0.380	0.467	0.446	0.333	0.275	0.181	0.170	(40)	
(41)		taud	1.924	2.112	2.068	1.973	2.146	2.367	2.101	2.107	2.417	2.223	1.927	1.911	(41)	
(42)		Ebn at Noon	126	211	243	253	258	265	232	223	236	193	107	39	(42)	
(43)		Edh at Noon	7	18	31	44	41	34	43	39	23	16	7	3	(43)	
(44)	All-Sky Solar Radiation	RadAvg	50	297	887	1655	1846	1786	1598	1206	706	305	88	15	(44)	
(45)		RadStd	4	20	26	47	96	134	157	134	114	43	8	1	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (1 neighbor)		+1.24	+2.12	+2.34	N/A	N/A	N/A	-542	-522	N/A	-41	

Nomenclature: See separate page