

KORKODON, Russian FederationWMO: **255030**Lat: **64.750N**Lon: **153.967E**Elev: **99**StdP: **100.14**Time Zone: **11.00 (E11)**Period: **09-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-47.8	-46.3	-49.6	0.0	-47.4	-48.3	0.0	-46.1	5.5	-36.2	5.2	-35.0	0.7	100	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	28.2	18.5	26.0	17.2	23.8	15.9	19.4	26.4	18.1	24.3	16.8	22.5	2.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	12.1	22.4	15.5	11.1	21.0	14.1	10.2	19.7	56.0	26.4	51.8	24.1	47.6	22.8	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
5.1	4.4	4.0	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.5	-36.2	-34.6	-21.7	-7.6	4.9	13.5	16.0	11.8	4.8	-9.0	-24.9	-33.0
	DBStd	19.88	7.00	6.31	7.38	7.05	5.19	3.86	4.06	4.15	4.51	5.96	7.17	6.72
	HDD10.0	7551	1433	1250	983	529	172	14	3	29	166	589	1047	1334
	HDD18.3	10207	1691	1483	1242	779	416	149	97	206	406	848	1297	1593
	CDD10.0	416	0	0	0	0	15	119	189	84	9	0	0	0
	CDD18.3	31	0	0	0	0	0	4	24	2	0	0	0	0
	CDH23.3	567	0	0	0	0	7	117	371	72	1	0	0	0
	CDH26.7	146	0	0	0	0	1	16	121	8	0	0	0	0
(14) Wind	WSAvg	1.9	2.0	1.8	2.0	1.9	2.1	1.9	1.7	1.6	1.7	1.8	1.9	2.1
(15) Precipitation	PrecAvg	260	19	16	11	8	12	23	42	41	25	20	21	18
	PrecMax	398	65	39	35	24	31	53	106	113	84	45	53	39
	PrecMin	145	3	5	0	0	0	0	3	5	7	2	1	2
	PrecStd	60	13	8	9	7	8	14	24	24	17	10	12	10
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-15.8	-19.8	-1.0	10.3	24.0	29.0	33.3	27.6	21.4	5.0	-6.0	-15.5
		MCWB	-16.5	-20.3	-4.2	4.8	14.0	17.5	20.7	18.5	13.5	1.9	-7.1	-15.9
	2%	DB	-19.0	-22.4	-3.4	6.9	20.6	26.5	29.7	25.5	18.0	1.8	-10.9	-19.1
		MCWB	-19.3	-22.8	-6.0	2.1	11.3	15.9	19.1	17.6	11.5	0.1	-11.3	-19.3
	5%	DB	-22.7	-23.5	-6.1	5.2	17.8	24.5	27.5	23.1	15.3	0.4	-13.0	-21.6
		MCWB	-22.9	-23.9	-8.0	0.9	9.8	14.9	18.7	16.2	10.0	-1.0	-13.5	-21.9
	10%	DB	-25.7	-25.1	-9.4	3.5	15.1	22.5	25.0	20.8	12.9	-0.9	-14.8	-23.6
		MCWB	-25.9	-25.4	-10.7	-0.2	8.2	13.9	17.3	14.9	8.9	-2.2	-15.3	-23.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-16.3	-20.3	-4.0	4.9	14.0	18.5	22.0	19.6	13.9	2.1	-7.2	-15.8
		MCDB	-16.0	-19.9	-1.3	10.2	24.3	26.7	29.6	24.9	20.4	4.3	-6.2	-15.6
	2%	WB	-19.4	-22.7	-5.9	2.6	11.8	17.1	20.4	18.2	12.1	0.3	-11.3	-19.4
		MCDB	-19.1	-22.5	-3.5	6.5	19.3	24.6	28.1	24.6	16.6	1.6	-10.9	-19.2
	5%	WB	-22.9	-23.8	-8.0	1.2	10.2	15.8	19.1	16.6	10.5	-0.9	-13.4	-21.8
		MCDB	-22.8	-23.4	-6.1	4.7	17.1	23.1	26.0	22.2	14.6	0.3	-13.0	-21.5
	10%	WB	-25.8	-25.4	-10.7	0.0	8.6	14.5	18.0	15.2	9.2	-2.3	-15.2	-23.9
		MCDB	-25.6	-25.1	-9.4	3.4	14.6	20.8	23.6	20.2	12.3	-1.1	-14.7	-23.7
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	7.9	14.2	15.3	12.3	12.4	12.1	11.9	9.7	7.1	6.4	5.4
		MCDBR	7.5	7.1	18.2	13.8	17.0	17.3	17.5	17.7	16.0	7.5	6.6	6.4
		MCWBR	7.4	6.9	15.8	9.5	9.1	8.1	8.2	10.0	9.6	5.7	6.3	6.3
		MCDBR	7.4	7.2	18.0	12.7	15.7	15.3	15.4	14.3	6.8	7.0	6.5	6.5
	5% WB	MCWBR	7.2	7.0	15.6	8.9	8.6	8.0	7.7	9.2	8.9	5.2	6.6	6.3
(40) Clear-Sky Solar Irradiance	taub		0.166	0.241	0.297	0.353	0.387	0.380	0.467	0.446	0.333	0.275	0.181	0.170
	taud		1.924	2.112	2.068	1.973	2.146	2.367	2.101	2.107	2.417	2.223	1.927	1.911
	Ebn at Noon		398	666	765	797	812	834	731	702	745	608	338	124
	Edh at Noon		23	58	98	138	128	106	135	122	72	52	22	8
(44) All-Sky Solar Radiation	RadAvg		0.16	0.94	2.80	5.22	5.82	5.63	5.04	3.80	2.23	0.96	0.28	0.05
	RadStd		0.01	0.06	0.08	0.15	0.30	0.42	0.49	0.42	0.36	0.13	0.03	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	+0.69	+1.18	+1.30	N/A	N/A	N/A	-301	-290	N/A	-23

Nomenclature: See separate page