

PROVIDENIYA BAY, Russian Federation

WMO: 255940

Lat: 64.378N

Lon: 173.243W

Elev: 22

StdP: 101.06

Time Zone: 12.00 (E12)

Period: 90-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.2	-28.1	-33.3	0.2	-30.0	-31.3	0.2	-27.6	18.7	-10.1	16.8	-11.7	1.0	350	0.918

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.8	15.4	10.7	13.6	9.9	12.1	9.2	11.4	14.3	10.5	12.6	9.7	11.4	4.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.0	7.7	11.6	9.2	7.2	10.8	8.7	7.0	10.3	32.8	14.7	30.4	12.8	28.7	11.5	16.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	15.5	13.1	11.1	DB	-31.9	19.8	3.4	2.3	-34.4	21.4	-36.4	22.7	-38.3	24.0	-40.7	25.6
(5)				WB	-32.1	13.2	3.2	1.4	-34.4	14.2	-36.2	15.0	-38.0	15.8	-40.3	16.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.7	-15.4	-15.2	-14.1	-7.4	-0.1	5.4	8.9	8.4	4.8	-1.0	-6.6	-13.0	(6)	
(7)		DBStd	10.32	7.38	7.71	6.47	5.02	3.66	2.72	2.24	1.90	3.18	3.42	5.55	7.05	(7)	
(8)		HDD10.0	5029	787	704	748	522	314	142	48	55	157	341	497	714	(8)	
(9)		HDD18.3	8046	1045	938	1007	772	573	388	292	307	406	599	747	973	(9)	
(10)		CDD10.0	25	0	0	0	0	0	4	14	6	1	0	0	0	(10)	
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
(12)		CDH23.3	1	0	0	0	0	0	1	0	0	0	0	0	0	(12)	
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14)	Wind	WSAvg	4.5	5.3	5.5	4.6	4.3	3.7	3.6	3.6	4.0	4.2	4.3	5.5	5.6	(14)	
(15)	Precipitation	PrecAvg	666	49	40	31	36	34	33	55	84	74	79	94	57	(15)	
(16)		PrecMax	1125	108	180	93	150	132	104	140	181	232	185	211	143	(16)	
(17)		PrecMin	375	6	1	1	1	3	2	5	2	2	14	10	12	(17)	
(18)		PrecStd	191	33	40	22	35	32	25	40	43	56	48	58	40	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.8	1.3	0.7	2.9	10.2	17.6	19.0	16.2	13.7	6.7	4.0	3.0	(19)	
(20)		MCWB	-0.3	0.4	-0.4	0.6	6.6	10.9	12.7	11.2	9.3	5.3	1.6	1.2	(20)		
(21)		2%	DB	-0.3	-0.3	-0.3	1.2	7.5	14.1	16.0	14.1	11.4	5.4	2.9	0.7	(21)	
(22)		MCWB	-1.0	-0.8	-1.2	-0.1	4.6	9.1	11.3	10.5	8.8	4.2	1.7	-0.2	(22)		
(23)		5%	DB	-1.5	-1.8	-2.4	0.5	5.4	11.8	14.2	12.3	10.0	4.5	2.1	-0.7	(23)	
(24)		MCWB	-2.2	-2.3	-3.4	-0.6	3.2	8.0	10.4	9.7	8.5	3.5	1.1	-1.4	(24)		
(25)		10%	DB	-4.9	-4.1	-4.5	-0.4	4.1	10.0	12.5	11.1	9.1	3.5	1.0	-2.7	(25)	
(26)		MCWB	-5.9	-4.9	-5.4	-1.4	2.3	7.2	9.7	9.3	8.0	2.5	0.1	-3.7	(26)		
(27)		Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.1	0.6	-0.2	1.0	6.7	11.6	13.4	12.7	10.3	5.7	2.8	1.7	(27)
(28)			MCDB	0.3	1.0	0.5	2.0	9.9	16.5	17.7	14.6	12.1	6.3	3.3	2.8	(28)	
(29)	2%		WB	-0.9	-0.8	-1.2	0.2	4.8	9.6	11.8	11.1	9.5	4.5	2.0	0.0	(29)	
(30)	MCDB		-0.3	-0.4	-0.3	1.1	7.0	13.1	14.9	12.9	10.8	5.1	2.6	0.6	(30)		
(31)	5%		WB	-2.2	-2.4	-3.3	-0.3	3.5	8.5	10.7	10.2	8.8	3.6	1.2	-1.5	(31)	
(32)	MCDB		-1.5	-1.9	-2.6	0.5	5.2	11.4	13.4	11.6	9.9	4.3	1.8	-0.7	(32)		
(33)	10%		WB	-5.6	-4.8	-5.3	-1.3	2.5	7.2	10.0	9.6	8.1	2.7	0.1	-3.7	(33)	
(34)	MCDB		-5.0	-4.2	-4.5	-0.5	3.8	9.7	12.0	10.7	9.2	3.4	0.9	-2.8	(34)		
(35)	Mean Daily Temperature Range		MDBR	4.7	5.4	6.0	5.8	4.1	5.3	4.8	4.0	4.0	3.6	4.0	4.6	(35)	
(36)			5% DB	MCDBR	5.3	5.8	5.4	5.1	6.0	9.4	8.4	6.7	4.4	3.9	3.6	5.7	(36)
(37)		MCWBR	5.2	5.8	5.1	4.4	4.1	5.7	5.0	4.4	3.0	3.4	3.5	5.4	(37)		
(38)		5% WB	MCDBR	5.1	5.8	5.1	4.4	5.4	8.6	7.0	5.1	3.6	3.6	3.6	5.5	(38)	
(39)		MCWBR	5.3	5.9	4.9	4.0	3.9	5.6	4.7	3.8	2.6	3.4	3.7	5.4	(39)		
(40)	Clear-Sky Solar Irradiance	taub	0.176	0.256	0.285	0.346	0.381	0.370	0.375	0.387	0.329	0.292	0.392	N/A	(40)		
(41)		taud	1.934	2.117	2.146	2.024	2.090	2.381	2.427	2.342	2.470	2.289	2.639	N/A	(41)		
(42)		Ebn at Noon	400	650	794	811	818	845	830	775	759	605	284	N/A	(42)		
(43)		Edh at Noon	25	60	91	131	136	105	98	97	69	51	26	N/A	(43)		
(44)	All-Sky Solar Radiation	RadAvg	0.14	0.80	2.50	4.30	4.81	5.43	4.45	3.26	2.12	0.81	0.19	0.05	(44)		
(45)		RadStd	0.02	0.13	0.24	0.33	0.55	0.40	0.51	0.35	0.24	0.12	0.03	0.00	(45)		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
											(47)

Nomenclature: See separate page