

SEYMCHAN, Russian Federation

WMO: 257030

Lat: 62.9209N

Lon: 152.4143E

Elev: 689

StdP: 14.33

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-58.8	-55.7	-63.4	0.1	-58.3	-60.1	0.1	-55.4	16.6	-13.8	14.1	-11.8	0.2	210	0.759

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.6	84.1	64.2	80.1	62.3	76.0	60.2	66.1	80.6	63.9	76.7	61.8	73.2	5.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.8	81.5	70.4	58.6	75.3	69.6	56.4	69.6	67.7	31.2	80.5	29.6	77.1	28.0	73.4	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.5	14.0	12.0	DB	-61.8	91.5	2.8	3.2	-63.8	93.8	-65.5	95.6	-67.0	97.4	-69.1	99.7
			WB	-61.8	69.2	2.8	2.8	-63.8	71.3	-65.5	72.9	-67.0	74.5	-69.1	76.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	-33.7	-27.5	-8.6	15.0	40.3	56.4	61.5	54.3	40.8	14.9	-13.9	-30.4	
	DBStd	36.44	14.81	12.99	12.31	12.48	8.81	7.35	7.49	7.02	7.92	11.77	14.85	15.11	
	HDD50	13804	2594	2170	1818	1050	317	23	7	37	290	1089	1917	2492	
	HDD65	18562	3059	2590	2283	1500	764	269	157	336	726	1554	2367	2957	
	CDD50	782	0	0	0	0	17	216	364	171	14	0	0	0	
	CDD65	67	0	0	0	0	0	12	49	6	0	0	0	0	
	CDH74	1272	0	0	0	0	8	297	815	150	2	0	0	0	
	CDH80	354	0	0	0	0	0	64	265	25	0	0	0	0	
Wind	WSAvg	3.8	1.4	2.4	4.0	4.7	6.0	5.3	4.7	4.3	4.5	3.5	2.4	1.7	
Precipitation	PrecAvg	12.2	1.0	0.8	0.6	0.4	0.6	1.2	1.9	1.7	1.1	0.9	1.1	0.9	
	PrecMax	18.8	2.7	1.9	2.0	1.0	1.9	4.4	4.3	3.7	3.1	2.4	2.6	2.1	
	PrecMin	6.7	0.2	0.2	0.0	0.0	0.0	0.0	0.4	0.3	0.1	0.1	0.2	0.2	
	PrecStd	2.5	0.5	0.4	0.4	0.2	0.5	0.8	0.9	0.8	0.7	0.5	0.6	0.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.9	6.6	27.3	47.2	73.8	85.9	91.7	82.8	69.7	46.6	24.0	7.6	
		MCWB	1.0	5.6	22.3	37.6	54.6	63.2	67.6	64.0	54.7	39.0	21.4	6.4	
	2%	DB	-2.9	0.2	22.2	42.0	66.8	81.3	86.5	78.2	64.3	38.8	15.7	0.5	
		MCWB	-3.7	-1.0	18.4	33.8	50.5	61.1	65.7	62.3	52.0	33.0	14.4	-0.2	
	5%	DB	-6.8	-3.2	17.5	38.6	61.6	77.5	82.6	73.9	59.8	34.3	11.5	-4.4	
		MCWB	-7.4	-4.0	14.8	31.5	47.5	58.6	64.0	60.2	49.6	30.6	10.3	-5.1	
	10%	DB	-10.8	-7.4	11.8	35.0	56.8	73.3	78.5	69.8	55.7	30.8	7.4	-7.8	
		MCWB	-11.4	-8.1	9.8	29.2	44.9	56.8	62.6	58.0	47.6	27.8	6.5	-8.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.9	5.8	22.5	37.7	55.9	65.5	71.1	66.5	55.9	38.7	22.0	6.7
			MCDB	1.5	6.7	27.0	46.7	72.5	81.9	85.3	78.7	66.7	45.3	24.2	7.5
2%		WB	-3.6	-0.7	18.5	34.1	51.0	62.7	67.7	63.7	53.4	33.7	14.4	-0.1	
		MCDB	-2.8	0.3	22.0	41.3	65.5	77.5	83.1	74.6	62.4	38.1	15.8	0.5	
5%		WB	-7.4	-4.0	14.7	31.8	48.0	60.2	65.5	61.5	50.8	30.6	10.3	-5.0	
		MCDB	-6.7	-3.3	17.4	38.0	60.5	74.2	79.7	71.4	58.1	34.1	11.4	-4.5	
10%		WB	-11.3	-8.1	9.8	29.5	45.4	57.8	63.5	59.1	48.2	27.8	6.4	-8.4	
		MCDB	-10.8	-7.5	11.8	34.7	55.8	71.0	75.9	68.3	55.1	30.8	7.4	-7.9	
Mean Daily Temperature Range	5% DB	MDBR	13.1	19.0	25.8	24.6	19.3	22.2	22.6	21.9	18.8	16.5	14.7	12.5	
		MCDBR	11.7	13.6	31.5	22.8	29.6	32.0	33.0	32.5	29.5	20.1	15.5	12.9	
		MCWBR	11.4	13.2	28.0	15.9	15.5	14.4	14.7	17.5	17.4	15.1	14.5	12.6	
	5% WB	MCDBR	11.2	13.5	30.8	21.3	27.5	28.7	29.7	28.0	26.1	18.9	15.0	12.5	
		MCWBR	10.9	13.0	27.4	14.8	14.5	13.8	14.2	15.9	15.9	14.4	13.9	12.2	
Clear-Sky Solar Irradiance	taub	0.190	0.250	0.304	0.371	0.402	0.391	0.462	0.450	0.325	0.279	0.202	0.173		
	taud	1.986	2.103	2.036	1.907	2.069	2.325	2.124	2.095	2.450	2.218	1.976	1.901		
	Ebn at Noon	150	220	246	250	255	263	237	225	247	205	134	83		
	Edh at Noon	10	21	34	48	45	36	43	40	23	18	10	5		
All-Sky Solar Radiation	RadAvg	81	343	941	1679	1862	1765	1622	1193	721	361	130	33		
	RadStd	8	31	47	67	114	143	147	127	121	54	15	2		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page