

SEYMCHAN, Russian Federation

WMO: 257030

Lat: 62.9209N

Lon: 152.4143E

Elev: 210

StdP: 98.83

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-50.4	-48.7	-53.0	0.0	-50.1	-51.2	0.0	-48.6	7.4	-25.4	6.3	-24.3	0.1	210	0.759

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	28.9	17.9	26.7	16.8	24.5	15.7	18.9	27.0	17.7	24.8	16.5	22.9	2.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.0	11.6	21.3	14.8	10.8	20.9	13.6	9.9	19.8	54.7	26.9	51.0	25.0	47.3	23.0	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.4	6.3	5.4	-52.1	33.0	1.6	1.8	-53.2	34.3	-54.1	35.4	-55.0	36.3	-56.2	37.6		
			-52.1	20.7	1.6	1.6	-53.2	21.8	-54.1	22.7	-55.0	23.6	-56.2	24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.8	-36.5	-33.1	-22.6	-9.4	4.6	13.6	16.4	12.4	4.9	-9.5	-25.5	-34.7	(6)
(7)		DBStd	20.24	8.23	7.22	6.84	6.93	4.89	4.08	4.16	3.90	4.40	6.54	8.25	8.39	(7)
(8)		HDD10.0	7669	1441	1206	1010	583	176	13	4	21	161	605	1065	1384	(8)
(9)		HDD18.3	10312	1699	1439	1268	833	424	149	87	187	403	863	1315	1643	(9)
(10)		CDD10.0	434	0	0	0	0	9	120	202	95	8	0	0	0	(10)
(11)		CDD18.3	37	0	0	0	0	0	7	27	3	0	0	0	0	(11)
(12)		CDH23.3	707	0	0	0	0	4	165	453	83	1	0	0	0	(12)
(13)		CDH26.7	197	0	0	0	0	0	36	147	14	0	0	0	0	(13)
(14)	Wind	WSAvg	1.7	0.6	1.1	1.8	2.1	2.7	2.4	2.1	1.9	2.0	1.6	1.1	0.7	(14)
(15)	Precipitation	PrecAvg	311	26	21	14	9	14	30	48	42	28	22	29	23	(15)
(16)		PrecMax	478	68	49	50	25	49	111	108	95	79	61	66	54	(16)
(17)		PrecMin	169	6	4	0	0	0	0	9	8	3	2	4	5	(17)
(18)		PrecStd	64	13	10	10	6	12	20	23	21	19	12	14	11	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-16.7	-14.1	-2.6	8.5	23.2	29.9	33.2	28.2	20.9	8.1	-4.4	-13.5	(19)
(20)			MCWB	-17.2	-14.7	-5.4	3.1	12.6	17.3	19.8	17.8	12.6	3.9	-5.9	-14.2	(20)
(21)		2%	DB	-19.4	-17.6	-5.5	5.6	19.3	27.4	30.3	25.7	18.0	3.8	-9.0	-17.5	(21)
(22)			MCWB	-19.8	-18.3	-7.6	1.0	10.3	16.1	18.7	16.8	11.1	0.6	-9.8	-17.9	(22)
(23)		5%	DB	-21.5	-19.6	-8.1	3.6	16.4	25.3	28.1	23.3	15.4	1.3	-11.4	-20.2	(23)
(24)			MCWB	-21.9	-20.0	-9.5	-0.3	8.6	14.8	17.8	15.6	9.8	-0.8	-12.0	-20.6	(24)
(25)		10%	DB	-23.8	-21.9	-11.2	1.7	13.8	23.0	25.9	21.0	13.2	-0.6	-13.7	-22.1	(25)
(26)			MCWB	-24.1	-22.3	-12.3	-1.6	7.1	13.8	17.0	14.4	8.6	-2.3	-14.2	-22.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-17.3	-14.6	-5.3	3.2	13.3	18.6	21.7	19.2	13.3	3.7	-5.6	-14.1	(27)
(28)			MCDWB	-17.0	-14.1	-2.8	8.1	22.5	27.7	29.6	25.9	19.3	7.4	-4.3	-13.6	(28)
(29)		2%	WB	-19.8	-18.2	-7.5	1.2	10.6	17.0	19.8	17.6	11.9	1.0	-9.8	-17.8	(29)
(30)			MCDWB	-19.4	-17.6	-5.6	5.2	18.6	25.3	28.4	23.7	16.9	3.4	-9.0	-17.5	(30)
(31)		5%	WB	-21.9	-20.0	-9.6	-0.1	8.9	15.7	18.6	16.4	10.4	-0.8	-12.0	-20.6	(31)
(32)			MCDWB	-21.5	-19.6	-8.1	3.3	15.8	23.4	26.5	21.9	14.5	1.2	-11.5	-20.3	(32)
(33)		10%	WB	-24.1	-22.3	-12.3	-1.4	7.5	14.3	17.5	15.0	9.0	-2.3	-14.2	-22.4	(33)
(34)			MCDWB	-23.8	-21.9	-11.2	1.5	13.2	21.7	24.4	20.2	12.9	-0.7	-13.7	-22.1	(34)
(35)	Mean Daily Temperature Range	MDBR	7.3	10.6	14.3	13.6	10.7	12.4	12.6	12.2	10.5	9.2	8.2	6.9	(35)	
(36)		5% DB	MCDBR	6.5	7.6	17.5	12.7	16.4	17.8	18.3	18.1	16.4	11.2	8.6	7.1	(36)
(37)			MCWBR	6.3	7.3	15.5	8.8	8.6	8.0	8.2	9.7	9.7	8.4	8.0	7.0	(37)
(38)		5% WB	MCDBR	6.2	7.5	17.1	11.8	15.3	16.0	16.5	15.6	14.5	10.5	8.3	6.9	(38)
(39)			MCWBR	6.1	7.2	15.2	8.2	8.1	7.7	7.9	8.8	8.8	8.0	7.7	6.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.190	0.250	0.304	0.371	0.402	0.391	0.462	0.450	0.325	0.279	0.202	0.173	(40)	
(41)		taud	1.986	2.103	2.036	1.907	2.069	2.325	2.124	2.095	2.450	2.218	1.976	1.901	(41)	
(42)		Ebn at Noon	473	694	776	787	804	829	746	710	778	647	424	261	(42)	
(43)		Edh at Noon	32	66	106	151	141	112	134	127	72	58	31	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.25	1.08	2.96	5.29	5.87	5.56	5.11	3.76	2.27	1.14	0.41	0.10	(44)	
(45)		RadStd	0.03	0.10	0.15	0.21	0.36	0.45	0.46	0.40	0.38	0.17	0.05	0.01	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page