

UST-SREDNEKAN, Russian Federation

WMO: 257050

Lat: 62.4437N

Lon: 152.3211E

Elev: 853

StdP: 14.25

Time Zone: 11.00 (E11)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-52.3	-49.8	-57.1	0.2	-51.1	-54.3	0.2	-49.4	9.1	-9.4	7.5	-16.4	1.7	220	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.9	84.4	63.5	80.1	61.8	76.0	60.1	65.7	79.4	63.6	76.3	61.6	73.2	3.4	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.7	81.7	71.3	58.5	75.5	68.4	56.6	70.4	66.4	31.1	79.5	29.4	76.8	28.0	72.9	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	7.7	6.8	DB	-54.4	91.5	1.9	2.9	-55.8	93.5	-56.9	95.2	-58.0	96.8	-59.4	98.9	(4)
(5)			WB	-54.4	69.8	1.9	3.7	-55.8	72.4	-56.9	74.6	-58.0	76.6	-59.4	79.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	-29.5	-25.5	-7.2	18.1	40.8	56.4	62.2	55.4	41.6	15.7	-10.1	-25.9	(6)
(7)		DBStd	35.07	13.81	12.54	13.21	12.61	8.66	7.30	7.27	7.52	8.47	10.60	12.02	12.83	(7)
(8)		HDD50	13178	2466	2114	1773	958	306	25	6	33	275	1065	1803	2354	(8)
(9)		HDD65	17887	2931	2534	2238	1408	751	271	140	309	703	1530	2253	2819	(9)
(10)		CDD50	842	0	0	0	0	20	216	383	201	22	0	0	0	(10)
(11)		CDD65	74	0	0	0	0	0	11	52	11	0	0	0	0	(11)
(12)		CDH74	1302	0	0	0	0	4	273	832	191	2	0	0	0	(12)
(13)		CDH80	373	0	0	0	0	0	57	276	40	0	0	0	0	(13)
(14)	Wind	WSAvg	2.9	2.1	2.2	2.8	3.5	4.0	3.5	3.0	2.9	3.1	2.9	2.4	2.3	(14)
(15)	Precipitation	PrecAvg	17.0	1.3	1.0	0.7	0.6	0.8	1.5	2.8	2.3	2.1	1.6	1.4	1.1	(15)
(16)		PrecMax	25.2	3.0	1.9	2.6	2.1	2.5	3.6	5.7	6.1	5.6	3.9	3.0	3.0	(16)
(17)		PrecMin	11.4	0.5	0.4	0.2	0.0	0.0	0.3	0.7	0.3	0.2	0.2	0.2	0.3	(17)
(18)		PrecStd	3.4	0.7	0.4	0.6	0.5	0.6	0.9	1.5	1.3	1.2	0.9	0.7	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.5	7.2	27.9	46.4	74.1	85.9	92.5	84.9	70.6	42.2	18.9	9.9	(19)
MCWB			1.0	6.9	22.8	39.0	56.3	62.4	68.8	64.7	54.9	35.1	16.5	9.3	(20)	
2%		DB	-2.5	0.2	23.7	42.2	67.0	80.9	86.9	79.1	65.4	36.0	14.8	-2.2	(21)	
		MCWB	-2.9	-0.4	19.6	34.7	51.0	60.2	64.6	62.1	52.6	32.2	13.6	-2.6	(22)	
5%		DB	-5.1	-4.4	18.7	39.7	62.4	76.7	82.7	74.9	60.2	32.1	11.0	-5.3	(23)	
		MCWB	-5.6	-4.9	15.7	32.9	48.4	58.1	63.3	60.5	49.7	29.4	10.1	-5.7	(24)	
10%		DB	-8.8	-8.5	12.6	36.5	56.7	72.8	78.6	70.3	55.9	29.5	7.4	-8.3	(25)	
		MCWB	-9.1	-9.1	10.8	30.6	45.3	56.3	61.8	58.9	48.0	27.5	6.7	-8.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.9	7.0	23.2	38.8	56.1	64.6	70.2	67.1	55.8	36.0	17.4	9.5	(27)
MCD B			1.2	7.3	27.7	45.8	72.9	82.1	87.4	79.5	67.9	41.7	18.5	10.1	(28)	
2%		WB	-2.8	-0.3	19.6	35.4	51.8	62.2	67.3	64.0	53.5	32.4	13.7	-2.8	(29)	
		MCD B	-2.5	0.0	23.5	41.8	65.0	77.4	82.0	75.6	62.6	35.4	14.7	-2.5	(30)	
5%		WB	-5.5	-4.9	15.6	33.0	48.8	59.7	65.1	61.8	51.3	29.7	10.1	-5.7	(31)	
		MCD B	-5.1	-4.4	18.4	38.8	60.5	73.7	78.6	72.2	59.0	31.6	10.9	-5.3	(32)	
10%		WB	-9.2	-8.9	10.8	31.0	45.9	57.5	63.1	59.7	48.9	27.6	6.6	-8.7	(33)	
		MCD B	-8.8	-8.4	12.7	36.3	56.7	69.9	75.6	69.0	54.8	29.5	7.4	-8.3	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.4	12.1	20.8	21.5	18.9	22.1	21.9	20.1	16.1	12.5	10.4	9.3	(35)
MCDBR			8.4	13.3	25.7	19.1	28.3	31.5	31.5	29.5	27.4	15.0	9.5	9.4	(36)	
MCWBR			8.3	12.8	22.2	13.1	14.8	13.7	12.9	14.0	15.0	11.3	9.1	9.1	(37)	
5% WB		MCDBR	8.7	13.0	25.0	18.4	26.3	28.0	27.2	24.9	24.2	13.0	9.8	9.3	(38)	
		MCWBR	8.6	12.6	21.6	12.7	14.1	13.5	13.1	12.7	13.8	9.7	9.4	9.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.191	0.248	0.300	0.369	0.398	0.387	0.451	0.440	0.321	0.276	0.203	0.170	(40)	
taud		2.007	2.117	2.048	1.912	2.075	2.335	2.158	2.135	2.462	2.227	1.994	1.902	(41)		
Ebn at Noon		159	226	250	252	257	265	240	230	250	210	143	97	(42)		
Edh at Noon		10	21	34	48	45	36	41	39	23	19	10	6	(43)		
(44)	All-Sky Solar Radiation	RadAvg	92	369	961	1703	1884	1754	1629	1184	728	379	144	38	(44)	
(45)		RadStd	9	28	46	63	129	145	145	127	123	57	16	3	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page