

EVENSK, Russian Federation

WMO: 258200

Lat: 61.917N

Lon: 159.217E

Elev: 12

StdP: 101.18

Time Zone: 11.00 (E11)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.5	-29.8	-36.2	0.1	-31.3	-34.3	0.1	-29.4	13.9	-15.0	12.8	-20.2	3.2	10	0.817

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.1	20.4	14.3	18.5	13.4	16.9	12.8	15.2	18.7	14.2	17.4	13.4	16.2	3.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.6	9.7	16.3	12.7	9.2	15.3	11.9	8.7	14.4	42.5	18.9	40.0	17.6	37.8	16.2	20.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	12.5	10.9	9.5	DB	-33.8	25.2	1.4	2.7	-34.8	27.1	-35.6	28.7	-36.4	30.2	-37.5	32.1
(5)				WB	-33.9	17.5	1.4	1.3	-34.9	18.4	-35.8	19.1	-36.5	19.8	-37.6	20.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.2	-17.2	-16.5	-13.1	-4.9	2.4	8.9	12.0	11.7	6.3	-2.0	-10.5	-16.9
	DBStd	12.11	7.34	7.51	6.27	4.60	3.10	2.88	2.32	2.47	3.45	4.63	6.57	6.83
	HDD10.0	4991	842	742	717	446	237	54	4	12	117	372	616	834
	HDD18.3	7873	1100	976	975	696	494	283	196	205	361	630	866	1092
	CDD10.0	159	0	0	0	0	0	21	68	65	6	0	0	0
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH23.3	10	0	0	0	0	0	1	9	1	0	0	0	0
	CDH26.7	3	0	0	0	0	0	0	3	0	0	0	0	0
Wind	WSAvg	3.8	5.0	4.4	4.8	3.7	2.9	2.8	2.6	2.8	3.2	3.7	5.3	4.6
Precipitation	PrecAvg	622	38	35	33	30	30	42	60	89	72	71	68	55
	PrecMax	923	95	71	67	98	64	89	104	185	190	137	235	156
	PrecMin	355	2	6	5	2	8	14	8	18	22	27	20	9
	PrecStd	134	19	17	18	19	14	22	24	45	42	26	43	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.0	2.7	1.0	6.2	15.4	21.6	24.0	21.5	17.9	9.0	2.9	0.3
		MCWB	0.6	1.6	-1.0	2.0	8.9	13.0	16.1	15.4	12.0	5.3	1.3	-1.1
	2%	DB	-1.0	-0.5	-0.9	4.3	11.1	18.3	21.2	19.5	14.4	7.4	1.6	-2.1
		MCWB	-1.9	-2.0	-2.3	1.1	6.2	11.9	14.9	14.2	10.1	4.3	0.4	-2.6
	5%	DB	-3.6	-3.0	-2.2	2.4	9.1	16.2	18.9	18.0	13.1	6.0	0.6	-4.7
		MCWB	-4.6	-4.3	-3.4	0.3	5.2	11.3	13.8	13.6	9.2	3.7	-0.5	-5.7
	10%	DB	-6.7	-5.7	-3.8	1.3	7.5	14.8	17.1	16.6	11.7	4.4	-0.8	-7.3
		MCWB	-7.8	-6.9	-5.1	-0.4	4.3	10.4	13.2	13.2	9.1	2.4	-1.8	-8.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.9	1.5	-0.8	2.7	9.0	14.1	17.1	16.6	12.9	6.4	1.6	-1.0
		MCDB	2.0	2.6	0.8	5.5	15.0	18.9	23.6	19.6	17.0	7.7	2.6	0.0
	2%	WB	-1.9	-1.8	-2.2	1.5	7.1	12.9	15.5	15.1	11.2	5.1	0.7	-2.9
		MCDB	-1.1	-0.6	-1.1	3.4	10.4	17.3	19.8	17.7	13.1	7.0	1.4	-2.2
	5%	WB	-4.6	-4.4	-3.2	0.7	5.5	11.8	14.5	14.3	10.5	3.8	-0.4	-5.7
		MCDB	-3.6	-3.1	-2.2	2.2	8.4	15.6	18.1	17.1	12.3	5.4	0.4	-4.8
	10%	WB	-7.8	-7.1	-4.9	-0.3	4.5	10.8	13.6	13.5	9.6	2.6	-1.8	-8.3
		MCDB	-6.7	-5.8	-3.9	1.1	7.0	13.9	16.5	16.2	11.3	4.3	-0.8	-7.4
Mean Daily Temperature Range	5% DB	MDBR	5.3	6.1	6.8	6.9	6.4	7.2	6.1	7.3	7.6	6.4	5.9	5.4
		MCDBR	5.0	4.2	5.4	6.6	9.8	11.9	11.6	10.7	10.1	6.6	4.9	6.1
		MCWBR	5.0	3.7	4.6	4.7	5.9	6.7	6.5	6.1	6.4	4.6	4.5	6.0
	5% WB	MCDBR	4.9	4.5	4.7	5.4	8.8	10.7	10.2	8.7	7.7	5.4	4.7	6.5
		MCWBR	4.9	4.1	4.0	4.2	5.5	6.5	6.2	5.5	5.3	4.3	4.6	6.3
Clear-Sky Solar Irradiance	taub	0.209	0.264	0.327	0.400	0.441	0.409	0.467	0.437	0.337	0.304	0.236	0.190	
	taud	2.027	2.111	2.009	1.865	1.903	2.246	2.110	2.173	2.458	2.264	2.046	1.928	
	Ebn at Noon	495	694	756	762	766	814	745	733	774	640	429	310	
	Edh at Noon	36	70	113	161	169	123	137	119	74	60	35	22	
All-Sky Solar Radiation	RadAvg	0.31	1.15	2.76	4.61	5.24	5.07	4.70	3.57	2.37	1.19	0.38	0.13	
	RadStd	0.04	0.09	0.20	0.36	0.52	0.50	0.47	0.44	0.26	0.15	0.05	0.01	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page