

TALLINN, Estonia

WMO: 260380

Lat: 59.3981N

Lon: 24.6028E

Elev: 113

StdP: 14.64

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.3	4.8	-5.9	4.0	-0.1	-0.3	5.4	5.8	22.7	30.6	20.6	30.7	5.2	130	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.2	80.4	66.9	76.9	64.7	73.6	63.0	68.6	76.8	66.6	74.0	64.7	71.7	8.5	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	95.7	72.6	64.0	89.5	70.4	61.9	83.0	68.1	32.8	77.0	31.2	73.8	29.8	71.7	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.2	17.8	15.8	DB	-7.7	84.8	8.7	3.7	-14.0	87.5	-19.1	89.6	-24.0	91.7	-30.4	94.4	(4)
(5)			WB	-8.2	71.4	8.5	1.9	-14.3	72.8	-19.3	73.9	-24.1	75.0	-30.2	76.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.0	25.2	24.4	30.1	40.7	49.7	57.5	63.5	61.4	53.5	43.5	35.5	29.7
	DBStd	15.35	9.82	10.24	7.72	6.86	7.16	5.43	5.18	5.09	5.64	6.68	7.09	8.97
	HDD50	3799	768	716	616	291	92	4	0	0	30	216	437	629
	HDD65	8110	1233	1136	1081	730	476	233	92	137	346	666	886	1094
	CDD50	1244	0	0	0	11	84	230	417	352	135	15	0	0
	CDD65	81	0	0	0	0	3	9	44	24	1	0	0	0
	CDH74	656	0	0	0	1	34	94	358	163	6	0	0	0
	CDH80	110	0	0	0	0	5	12	68	25	0	0	0	0
Wind	WSAvg	7.7	8.3	8.1	8.0	7.8	7.6	7.4	6.8	6.5	7.2	7.7	8.3	8.8
Precipitation	PrecAvg	26.3	2.1	1.5	1.4	1.3	1.4	2.4	3.0	3.1	2.2	2.9	2.6	2.2
	PrecMax	37.0	3.9	4.1	2.7	3.5	3.6	4.8	9.1	6.1	5.2	5.4	4.9	4.8
	PrecMin	18.1	0.3	0.2	0.2	0.1	0.2	0.5	0.0	0.4	0.9	0.5	0.2	0.6
	PrecStd	4.1	0.9	0.9	0.7	0.9	0.8	1.1	1.8	1.6	1.1	1.2	1.1	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.6	42.6	53.9	69.0	78.3	81.9	86.2	83.8	73.5	60.8	50.5	47.9
		MCWB	42.0	40.3	42.8	53.3	62.7	66.0	69.4	67.2	61.1	55.1	48.7	46.0
	2%	DB	39.6	39.5	46.5	62.3	71.9	76.7	81.4	78.5	68.5	57.2	48.5	44.8
		MCWB	38.7	37.9	40.5	50.3	58.2	63.7	67.4	66.0	60.2	53.8	47.3	43.5
	5%	DB	37.7	37.7	42.4	57.1	67.5	72.0	78.0	74.9	65.3	55.1	46.8	42.7
		MCWB	36.8	36.5	38.0	46.8	55.9	60.7	66.0	64.1	58.6	52.4	45.5	41.5
	10%	DB	36.0	36.1	39.3	53.2	63.2	68.5	74.8	71.6	62.6	53.1	44.9	40.6
		MCWB	35.2	35.0	36.3	45.2	53.1	58.7	64.4	62.6	57.4	50.7	43.8	39.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.6	40.5	44.4	54.7	65.4	68.7	71.8	70.4	63.6	56.5	49.4	46.3
		MCDB	42.1	41.3	50.5	64.6	74.6	76.8	82.0	78.2	69.5	58.9	50.0	47.2
	2%	WB	38.8	38.3	41.0	51.1	60.8	65.6	69.5	67.4	61.3	54.6	47.5	43.6
		MCDB	39.3	39.1	45.2	60.1	68.9	73.7	78.2	74.8	66.3	56.7	48.3	44.4
	5%	WB	36.9	36.7	38.6	48.4	57.3	62.9	67.5	65.6	59.8	52.9	45.8	41.3
		MCDB	37.5	37.6	41.3	55.8	64.8	69.4	75.1	72.3	64.0	54.8	46.6	42.1
	10%	WB	35.4	35.1	36.8	45.6	54.4	60.3	65.5	63.7	58.1	51.1	43.9	39.2
		MCDB	35.9	36.0	38.7	51.6	61.8	66.9	72.7	70.1	61.8	52.8	44.7	40.1
Mean Daily Temperature Range	5% DB	MDBR	8.5	9.6	12.3	15.8	17.9	16.3	16.2	16.1	14.1	10.2	7.3	7.6
		MCDBR	7.3	8.7	16.0	23.9	24.9	23.3	22.0	21.1	18.0	12.0	8.2	6.8
		MCWBR	7.1	7.8	10.8	13.7	13.5	12.1	10.8	10.7	10.9	8.7	7.8	6.7
	5% WB	MCDBR	7.1	8.0	13.4	22.0	21.1	19.9	19.6	18.2	15.6	10.8	7.8	6.7
		MCWBR	7.0	7.5	9.8	13.6	12.9	11.9	10.5	10.4	10.2	8.6	7.7	6.8
Clear-Sky Solar Irradiance	taub	0.277	0.309	0.332	0.366	0.362	0.360	0.385	0.380	0.350	0.334	0.311	0.266	
	taud	2.140	2.182	2.238	2.320	2.403	2.456	2.409	2.422	2.494	2.406	2.220	2.098	
	Ebn at Noon	160	218	252	265	275	277	266	258	249	212	146	118	
	Edh at Noon	15	24	30	34	33	32	33	30	24	19	14	10	
All-Sky Solar Radiation	RadAvg	82	265	740	1234	1726	1795	1715	1348	823	357	99	51	
	RadStd	14	42	94	134	185	130	150	132	103	49	16	7	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.81	N/A	N/A	N/A	N/A	N/A	-274	-320	N/A	N/A
(47) Regional (59 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	-245	N/A	N/A	N/A

Nomenclature: See separate page