

JOHVI, Estonia

WMO: 260460

Lat: 59.3289N

Lon: 27.3983E

Elev: 74

StdP: 100.44

Time Zone: 2.00 (EUE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.1	-18.5	-24.3	0.4	-22.0	-20.9	0.6	-18.0	11.4	-2.1	10.7	-1.3	2.0	180	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	27.2	19.3	25.2	18.2	23.4	17.4	20.3	25.2	19.3	23.8	18.2	22.3	3.7	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.6	22.5	17.6	12.7	21.5	16.5	11.8	20.3	58.6	25.1	55.1	23.9	51.7	22.2	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	8.4	7.6	DB	-25.2	29.1	5.3	2.1	-29.1	30.6	-32.2	31.8	-35.1	33.0	-39.0	34.5	(4)
(5)			WB	-25.6	21.6	5.3	1.1	-29.5	22.4	-32.6	23.0	-35.6	23.6	-39.5	24.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.4	-5.7	-5.6	-1.9	4.2	10.5	14.0	17.4	16.0	11.4	5.3	1.0	-2.3	(6)
(7)		DBStd	9.13	6.54	6.21	4.87	3.78	4.25	3.27	3.24	3.05	2.94	3.95	3.98	5.37	(7)
(8)		HDD10.0	2338	486	436	369	178	43	4	0	1	19	151	269	381	(8)
(9)		HDD18.3	4764	744	669	628	424	244	137	58	87	209	404	519	639	(9)
(10)		CDD10.0	667	0	0	0	4	59	124	228	186	61	5	0	0	(10)
(11)		CDD18.3	49	0	0	0	0	2	6	28	13	0	0	0	0	(11)
(12)		CDH23.3	414	0	0	0	0	24	53	229	108	1	0	0	0	(12)
(13)		CDH26.7	76	0	0	0	0	3	4	45	23	0	0	0	0	(13)
(14)	Wind	WSAvg	3.6	4.1	4.1	3.9	3.5	3.2	3.2	2.8	3.0	3.2	3.7	4.2	4.6	(14)
(15)	Precipitation	PrecAvg	686	46	34	36	30	50	80	74	89	64	74	63	46	(15)
(16)		PrecMax	921	97	85	69	72	106	145	160	227	144	150	130	80	(16)
(17)		PrecMin	399	17	7	9	6	3	18	16	10	13	19	9	9	(17)
(18)		PrecStd	121	17	16	17	15	29	36	39	53	31	32	24	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.3	4.8	12.1	19.5	25.8	27.3	30.2	29.2	21.7	14.8	9.4	8.6	(19)
(20)			MCWB	4.7	3.4	5.6	10.8	16.8	19.2	20.7	19.2	16.2	12.2	8.4	7.5	(20)
(21)		2%	DB	3.5	3.4	7.9	16.4	23.1	24.9	27.8	26.1	19.5	13.2	8.2	6.5	(21)
(22)			MCWB	2.9	2.5	4.3	9.0	15.5	17.2	19.9	18.5	15.2	11.7	7.4	5.6	(22)
(23)		5%	DB	2.4	2.3	5.4	13.7	20.6	22.7	25.8	23.8	17.9	12.0	7.2	4.8	(23)
(24)			MCWB	1.9	1.7	3.0	7.8	13.9	16.2	19.3	17.8	14.2	10.8	6.6	4.0	(24)
(25)		10%	DB	1.5	1.3	3.7	11.2	18.3	20.6	24.0	22.0	16.5	10.8	6.2	3.5	(25)
(26)			MCWB	1.1	0.9	2.0	6.4	12.6	15.1	18.2	16.9	13.6	9.8	5.5	2.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.7	4.0	7.1	11.6	19.1	20.2	21.9	21.2	16.9	13.1	8.7	7.7	(27)
(28)			MCDWB	5.2	4.5	10.4	17.3	24.6	24.5	27.5	26.0	20.3	14.0	9.1	8.4	(28)
(29)		2%	WB	3.1	2.6	4.7	9.8	16.8	18.6	20.8	19.5	15.9	12.0	7.6	5.7	(29)
(30)			MCDWB	3.4	3.2	7.3	15.1	21.0	23.2	26.1	23.9	18.6	13.0	8.1	6.4	(30)
(31)		5%	WB	2.0	1.7	3.3	8.4	15.0	17.2	19.9	18.5	14.8	11.0	6.7	4.1	(31)
(32)			MCDWB	2.3	2.2	5.0	12.7	19.2	21.6	24.6	22.5	17.1	11.8	7.2	4.7	(32)
(33)		10%	WB	1.1	0.9	2.3	7.0	13.3	15.7	18.9	17.6	13.9	10.0	5.6	2.8	(33)
(34)			MCDWB	1.4	1.3	3.4	10.7	17.6	19.6	23.3	21.2	16.0	10.7	6.1	3.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	5.0	6.5	8.8	10.3	9.3	9.1	9.2	7.4	5.4	3.6	3.7	(35)
(36)			MCDBR	3.4	4.2	8.7	13.5	13.1	12.5	11.7	12.1	10.1	6.7	4.1	4.0	(36)
(37)			MCWBR	3.3	3.7	5.8	7.6	6.9	6.4	5.4	5.8	6.2	5.0	3.9	3.9	(37)
(38)		5% WB	MCDBR	3.4	4.0	7.9	12.0	11.3	10.7	10.5	10.3	8.7	5.9	3.9	3.8	(38)
(39)			MCWBR	3.4	3.6	5.5	7.3	6.5	6.2	5.3	5.7	5.7	4.8	3.8	3.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.276	0.307	0.332	0.371	0.367	0.364	0.387	0.385	0.354	0.333	0.308	0.263	(40)	
(41)		taud	2.127	2.144	2.196	2.289	2.400	2.444	2.400	2.401	2.471	2.400	2.208	2.092	(41)	
(42)		Ebn at Noon	507	686	793	829	863	870	838	809	778	670	465	378	(42)	
(43)		Edh at Noon	47	78	100	109	105	103	105	98	78	62	44	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.26	0.85	2.30	3.84	5.35	5.52	5.41	4.18	2.56	1.06	0.29	0.15	(44)	
(45)		RadStd	0.04	0.16	0.33	0.45	0.56	0.46	0.50	0.43	0.31	0.15	0.05	0.02	(45)	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (38 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	-167	-171	N/A	N/A

Nomenclature: See separate page