

NARVA-JOESUU, Estonia

WMO: 260580

Lat: 59.3894N

Lon: 28.1090E

Elev: 97

StdP: 14.64

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.4	-1.1	-11.7	2.9	-7.3	-5.5	4.1	-0.6	23.1	32.1	21.4	31.9	4.2	140	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	81.8	67.0	78.1	65.3	74.7	63.9	69.2	77.6	67.2	75.2	65.3	72.9	7.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.1	96.5	73.3	64.1	90.0	71.6	62.1	83.8	69.2	33.3	77.3	31.7	75.3	30.2	73.0	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.6	17.4	15.5	-10.6	85.9	8.2	3.9	-16.5	88.7	-21.3	91.0	-25.9	93.2	-31.9	96.1		
(5)			-11.0	71.5	8.1	2.0	-16.9	72.9	-21.6	74.0	-26.2	75.1	-32.0	76.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	42.5	22.9	22.6	29.1	40.3	50.4	58.6	64.5	61.8	53.5	43.1	34.0	27.5	(6)
(7)		DBStd	16.67	11.28	11.45	8.16	7.34	7.95	5.97	5.93	5.40	5.86	6.79	7.97	10.02	(7)
(8)		HDD50	4093	839	767	647	305	91	5	0	0	33	228	479	699	(8)
(9)		HDD65	8342	1304	1187	1112	742	458	209	81	130	347	679	929	1164	(9)
(10)		CDD50	1347	0	0	0	13	104	262	451	366	137	14	0	0	(10)
(11)		CDD65	119	0	0	0	0	5	16	67	30	1	0	0	0	(11)
(12)		CDH74	882	0	0	0	1	57	140	463	217	4	0	0	0	(12)
(13)		CDH80	180	0	0	0	0	9	22	107	42	0	0	0	0	(13)
(14)	Wind	WSAvg	7.5	8.1	8.1	7.9	7.1	7.0	7.2	6.4	6.4	6.8	7.8	8.1	8.9	(14)
(15)	Precipitation	PrecAvg	26.6	1.9	1.5	1.5	1.3	1.8	3.0	2.8	3.4	2.4	2.8	2.4	1.9	(15)
(16)		PrecMax	34.4	3.2	3.3	3.0	2.7	3.6	7.4	5.3	6.9	5.4	4.8	4.6	3.1	(16)
(17)		PrecMin	17.7	0.8	0.2	0.3	0.3	0.3	0.9	0.6	0.4	0.7	0.9	0.2	0.6	(17)
(18)		PrecStd	4.7	0.6	0.7	0.7	0.6	0.9	1.4	1.3	1.7	1.3	1.1	0.9	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.8	41.5	52.2	71.0	80.8	83.2	87.6	84.8	73.2	60.1	50.2	47.4	(19)
(20)			MCWB	39.3	38.7	42.8	53.8	63.5	66.1	69.0	67.0	62.0	54.6	47.7	45.3	(20)
(21)		2%	DB	38.4	38.9	45.4	62.9	73.9	78.3	83.0	79.6	68.3	56.7	47.7	43.5	(21)
(22)			MCWB	36.9	36.8	39.1	50.2	59.6	64.5	68.6	65.5	60.2	53.3	45.7	41.8	(22)
(23)		5%	DB	36.6	37.3	41.7	57.3	68.5	73.9	79.1	75.6	65.0	54.5	45.9	41.1	(23)
(24)			MCWB	35.3	35.5	37.2	47.5	57.0	62.5	66.6	64.2	58.2	51.7	44.1	39.5	(24)
(25)		10%	DB	35.0	35.7	38.8	52.4	64.0	69.4	75.5	72.0	62.4	52.4	44.0	38.5	(25)
(26)			MCWB	33.9	34.3	35.7	44.6	54.9	60.2	65.5	62.9	57.0	49.8	42.2	37.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.8	39.5	43.5	55.2	66.1	68.9	72.0	70.2	63.9	55.8	48.3	45.4	(27)
(28)			MCDWB	40.5	40.7	49.7	66.3	77.0	77.7	82.0	78.2	69.5	58.2	49.7	46.9	(28)
(29)		2%	WB	37.2	37.3	40.1	51.7	61.9	66.3	70.1	67.4	61.5	54.0	46.2	42.2	(29)
(30)			MCDWB	38.1	38.5	44.4	61.5	69.8	75.1	79.1	75.5	66.6	56.1	47.4	43.5	(30)
(31)		5%	WB	35.5	35.8	38.0	48.2	58.7	63.7	68.4	65.6	59.5	52.0	44.4	39.6	(31)
(32)			MCDWB	36.3	37.1	40.9	55.9	66.5	71.5	76.3	73.3	63.7	54.2	45.8	40.8	(32)
(33)		10%	WB	34.1	34.3	36.1	45.3	55.5	61.4	66.5	63.9	57.6	50.2	42.5	37.3	(33)
(34)			MCDWB	34.9	35.5	38.5	51.5	62.5	68.3	74.1	70.7	61.2	52.2	43.7	38.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.0	9.4	11.3	14.3	15.7	14.2	14.3	14.7	12.4	8.7	6.3	6.8	(35)
(36)			MCDBR	6.0	7.4	14.9	23.7	24.1	22.4	20.7	21.5	16.8	10.5	7.1	6.7	(36)
(37)			MCWBR	5.8	6.6	9.9	13.2	12.1	10.9	8.7	9.7	9.8	7.6	6.7	6.5	(37)
(38)		5% WB	MCDWB	5.8	7.2	12.7	21.5	21.6	18.7	17.3	17.4	14.2	9.6	7.1	6.1	(38)
(39)			MCWBR	5.7	6.8	9.0	12.7	11.9	9.9	8.5	9.1	9.2	7.6	6.8	6.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.280	0.312	0.336	0.374	0.370	0.367	0.391	0.387	0.358	0.336	0.310	0.267	(40)	
(41)		taud	2.136	2.150	2.203	2.286	2.396	2.441	2.394	2.398	2.466	2.393	2.217	2.102	(41)	
(42)		Ebn at Noon	159	216	250	262	272	275	265	256	246	211	146	118	(42)	
(43)		Edh at Noon	15	24	31	35	34	33	34	31	25	20	14	10	(43)	
(44)	All-Sky Solar Radiation	RadAvg	86	277	729	1206	1662	1717	1679	1302	799	329	93	48	(44)	
(45)		RadStd	15	55	97	148	174	136	168	136	91	48	14	7	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		+0.86	N/A	N/A	N/A	N/A	N/A	-315	-317	N/A	N/A

Nomenclature: See separate page