

KINGISEPP, Russian FederationWMO: **260590**Lat: **59.3671N**Lon: **28.6012E**Elev: **19**StdP: **101.10**Time Zone: **3.00 (E03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-23.0	-19.5	-25.3	0.4	-22.8	-21.9	0.5	-19.3	6.6	-0.7	6.1	-0.6	1.0	120	0.544

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	28.2	20.1	26.2	19.0	24.4	17.9	21.1	26.3	19.9	24.7	18.8	23.2	2.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.0	23.9	18.0	13.0	22.4	17.0	12.1	21.1	61.1	26.3	56.8	24.8	53.4	23.2	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.6	5.1	4.4	-25.6	30.5	4.3	1.8	-28.7	31.8	-31.2	32.9	-33.6	33.9	-36.8	35.2		
			-25.8	22.7	4.3	1.2	-28.8	23.6	-31.3	24.3	-33.7	25.0	-36.9	25.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.8	-5.6	-5.7	-1.4	5.4	11.0	15.3	18.2	16.4	11.6	5.8	0.7	-2.9
	DBStd	9.51	6.53	6.66	4.54	4.31	4.36	3.46	3.21	3.00	3.39	3.84	4.56	5.77
	HDD10.0	2308	483	440	354	150	39	2	0	0	22	138	280	401
	HDD18.3	4649	741	673	612	389	232	104	43	75	202	389	530	659
	CDD10.0	772	0	0	0	11	70	161	253	199	71	7	0	0
	CDD18.3	70	0	0	0	0	4	13	37	16	1	0	0	0
	CDH23.3	614	0	0	0	1	43	122	314	129	4	0	0	0
	CDH26.7	126	0	0	0	0	8	23	72	23	0	0	0	0
	WSAvg	2.2	2.4	2.3	2.3	2.3	2.2	2.0	1.8	1.7	1.9	2.1	2.4	2.5
	PrecAvg	686	40	30	36	36	46	71	76	89	78	68	60	52
(15) Precipitation	PrecMax	906	84	79	85	87	103	202	133	217	148	147	102	97
	PrecMin	446	6	4	8	7	12	8	19	6	16	10	1	21
	PrecStd	105	18	15	20	21	24	39	35	50	39	33	20	18
	PrecStd	105	18	15	20	21	24	39	35	50	39	33	20	18
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.2	5.4	12.9	22.3	27.7	29.3	30.8	29.3	23.5	16.0	9.9	8.2
		MCWB	4.5	3.7	6.4	13.1	17.8	20.0	21.0	20.1	17.3	12.7	8.5	7.0
	2%	DB	3.6	4.1	8.2	18.6	24.0	26.8	28.7	26.5	20.6	13.8	8.7	6.1
		MCWB	2.8	2.8	4.2	11.4	15.8	18.7	20.8	19.3	15.9	11.8	7.6	5.3
	5%	DB	2.5	2.9	5.9	15.6	21.5	24.4	26.8	24.5	18.7	12.4	7.6	4.9
		MCWB	1.9	2.0	2.8	9.3	14.1	17.4	19.9	18.2	14.7	10.8	6.7	4.2
	10%	DB	1.6	2.0	4.4	13.0	19.2	22.0	24.8	22.6	17.1	11.2	6.3	3.7
		MCWB	1.1	1.3	2.3	7.8	12.9	15.9	18.7	17.2	13.8	9.8	5.5	3.0
	0.4%	WB	4.8	4.1	7.3	14.2	19.6	21.3	22.6	21.9	18.4	13.3	8.8	7.1
		MCDB	5.1	5.1	11.4	20.2	25.7	27.0	28.5	26.4	22.0	15.0	9.6	8.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	3.0	3.0	4.8	11.9	17.0	19.7	21.6	20.0	16.5	12.1	7.7	5.4
		MCDB	3.4	3.8	7.4	17.8	21.6	25.2	27.1	24.7	19.4	13.4	8.5	6.0
	5%	WB	2.0	2.1	3.6	10.0	15.2	18.3	20.5	18.9	15.4	11.1	6.8	4.3
		MCDB	2.4	2.8	5.4	14.5	20.1	23.0	25.5	23.3	17.9	12.3	7.5	4.8
	10%	WB	1.1	1.3	2.5	8.4	13.5	16.8	19.4	17.9	14.3	10.0	5.6	3.0
		MCDB	1.6	1.9	4.0	12.3	18.3	20.8	23.8	21.8	16.5	11.1	6.3	3.5
	5% DB	MDBR	4.8	6.0	7.4	9.3	10.3	9.1	9.0	9.0	7.8	5.4	3.8	4.0
		MCDBR	3.4	4.8	9.7	14.3	14.2	13.0	11.9	12.6	10.4	6.6	4.3	3.7
		MCWBR	3.2	4.1	6.4	7.9	6.9	6.3	5.4	6.1	4.7	3.9	3.4	3.4
		MCWBR	3.5	4.3	7.9	12.8	12.2	11.5	10.7	10.8	8.9	6.1	4.1	3.5
(35) Mean Daily Temperature Range	5% WB	MCWBR	3.4	3.8	5.5	7.4	6.6	6.2	5.2	5.7	5.6	4.6	3.8	3.4
		MCWBR	3.4	3.8	5.5	7.4	6.6	6.2	5.2	5.7	5.6	4.6	3.8	3.4
	Clear-Sky Solar Irradiance	taub	0.279	0.312	0.338	0.376	0.371	0.368	0.392	0.388	0.359	0.336	0.309	0.266
		taud	2.126	2.138	2.196	2.282	2.385	2.426	2.377	2.384	2.450	2.388	2.217	2.095
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	501	678	786	823	858	866	832	805	771	664	463	373
		Edh at Noon	47	78	100	110	107	104	107	99	79	62	44	33
(44) All-Sky Solar Radiation	RadStd	RadAvg	0.28	0.90	2.31	3.78	5.17	5.34	5.21	4.06	2.50	1.03	0.29	0.15
		RadStd	0.05	0.18	0.29	0.48	0.54	0.41	0.56	0.43	0.27	0.15	0.04	0.02

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46) Station Only		+0.53	N/A	N/A	N/A	N/A	N/A	-194	-222	N/A	N/A	
(47) Regional (25 neighbors)		+0.49	N/A	N/A	N/A	N/A	N/A	-177	-176	N/A	N/A	

Nomenclature: See separate page