

KUUSIKU, Estonia

WMO: 261340

Lat: 58.9733N

Lon: 24.7339E

Elev: 178

StdP: 14.60

Time Zone: 2.00 (EUE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.1	(c) -0.1	(d) -11.4	(e) 3.0	(f) -7.3	(g) -4.4	(h) 4.4	(i) 0.7	(j) 19.1	(k) 28.0	(l) 17.6	(m) 27.7	(n) 2.8	(o) 70	(p) 0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	81.7	66.9	78.3	65.1	75.1	63.6	69.2	78.3	67.2	75.1	65.3	72.7	7.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.1	96.8	73.4	64.2	90.4	71.1	62.2	84.2	69.1	33.4	78.6	31.7	75.0	30.3	72.7	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 16.6	(b) 14.5	(c) 13.3	(e) -13.2	(f) 84.9	(g) 8.9	(h) 3.0	(i) -19.5	(j) 87.0	(k) -24.7	(l) 88.8	(m) -29.7	(n) 90.4	(o) -36.2	(p) 92.6		
(4) 16.6	(5) 14.5	(6) 13.3	(7) -13.4	(8) 71.5	(9) 8.4	(10) 2.4	(11) -19.4	(12) 73.2	(13) -24.3	(14) 74.6	(15) -29.0	(16) 76.0	(17) -35.1	(18) 77.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.5	23.0	23.5	29.9	40.4	51.1	57.2	63.3	60.8	52.4	42.0	35.1	29.8
	DBStd	15.88	11.66	10.90	8.68	6.42	7.54	5.71	5.56	5.28	5.71	7.44	7.64	9.33
	HDD50	3953	836	743	624	293	74	7	0	1	41	260	447	627
	HDD65	8299	1301	1163	1089	737	435	243	101	151	377	713	897	1092
	CDD50	1215	0	0	0	6	109	224	413	337	114	12	0	0
	CDD65	85	0	0	0	0	5	10	49	21	0	0	0	0
	CDH74	916	0	0	0	0	75	132	504	204	1	0	0	0
	CDH80	161	0	0	0	0	7	13	109	32	0	0	0	0
(14) Wind	WSAvg	6.3	6.7	6.7	6.9	6.6	6.1	6.2	5.6	5.4	5.4	6.4	6.9	7.5
(15) Precipitation	PrecAvg	28.3	2.0	1.5	1.4	1.6	1.7	2.4	3.5	3.1	3.3	2.8	3.2	2.4
	PrecMax	38.9	4.1	5.5	3.2	4.7	3.1	5.2	6.5	7.2	7.0	6.6	6.9	4.4
	PrecMin	19.0	0.2	0.1	0.1	0.0	0.0	0.1	1.1	0.4	0.9	0.4	1.2	0.6
	PrecStd	4.7	0.9	1.0	0.8	1.0	0.9	1.3	1.5	1.7	1.4	1.4	1.3	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.6	41.5	56.3	68.1	80.2	81.8	86.5	84.0	71.6	59.4	50.1	48.2
		MCWB	41.2	39.1	44.9	51.6	62.4	65.1	69.3	68.0	60.9	54.6	48.3	46.5
	2%	DB	40.1	39.1	48.1	63.0	75.6	78.0	83.2	79.2	68.0	56.5	48.1	45.2
		MCWB	39.3	37.5	41.0	49.0	60.3	63.6	68.3	66.1	59.8	53.7	46.7	43.5
	5%	DB	37.6	37.1	43.4	58.3	71.5	74.0	79.8	75.5	65.2	54.6	46.5	42.3
		MCWB	36.7	36.0	38.4	46.8	57.7	61.8	66.9	64.5	58.2	52.5	45.3	41.0
	10%	DB	35.9	35.4	39.8	53.9	67.1	70.4	76.2	72.3	62.5	52.6	44.9	40.1
		MCWB	35.2	34.6	36.6	44.4	55.3	59.4	65.0	62.8	57.3	50.7	43.9	39.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.5	40.0	46.0	53.1	66.9	69.5	72.2	70.3	63.1	56.3	48.8	46.6
		MCDB	42.3	40.6	54.3	63.7	74.5	76.5	82.3	79.4	68.3	57.6	49.6	47.8
	2%	WB	39.2	37.8	41.6	50.3	62.8	65.9	70.1	67.8	61.0	54.5	47.0	43.7
		MCDB	39.7	38.7	46.7	60.3	72.4	74.0	80.1	75.8	65.7	55.8	47.9	44.9
	5%	WB	36.8	36.1	39.1	48.0	59.8	63.2	68.3	66.0	59.4	52.9	45.5	41.2
		MCDB	37.3	36.9	42.5	56.6	68.1	71.8	76.5	73.1	63.5	54.3	46.3	42.1
	10%	WB	35.1	34.6	37.0	45.4	56.6	60.6	66.3	64.1	57.8	51.0	43.9	39.1
		MCDB	35.7	35.3	39.4	52.5	65.4	69.0	74.6	70.2	61.5	52.3	44.7	40.0
(35) Mean Daily Temperature Range	5% DB	MDBR	9.1	10.1	13.6	18.4	21.3	18.6	18.4	18.4	15.5	11.5	7.3	7.2
		MCDBR	6.6	7.7	18.2	28.2	28.2	25.2	24.2	24.4	20.6	12.9	7.7	6.5
	5% WB	MCWBR	6.5	6.9	11.8	16.0	14.2	12.8	11.1	13.0	12.6	9.8	7.2	6.3
		MCWBR	6.8	7.3	15.7	24.9	23.1	20.9	21.5	21.2	17.2	11.0	7.7	6.2
(40) Clear-Sky Solar Irradiance	taub	taub	0.276	0.306	0.332	0.368	0.364	0.362	0.388	0.384	0.352	0.334	0.313	0.268
		taud	2.126	2.158	2.221	2.317	2.392	2.420	2.370	2.380	2.459	2.401	2.214	2.100
	Ebn at Noon	Ebn at Noon	165	221	253	265	275	277	266	257	248	214	149	124
		Edh at Noon	15	25	31	34	34	33	34	32	25	20	14	11
(44) All-Sky Solar Radiation	RadAvg	RadAvg	92	286	753	1245	1717	1778	1689	1333	828	370	108	58
	RadStd	RadStd	17	50	95	136	180	129	154	132	100	51	16	9

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (52 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	-236	N/A	N/A	N/A

Nomenclature: See separate page