

KUUSIKU, Estonia

WMO: 261340

Lat: 58.9733N

Lon: 24.7339E

Elev: 54

StdP: 100.68

Time Zone: 2.00 (EUE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.7	-17.8	-24.1	0.4	-21.9	-20.2	0.6	-17.4	8.5	-2.2	7.9	-2.4	1.3	70	0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	27.6	19.4	25.7	18.4	24.0	17.6	20.7	25.7	19.5	23.9	18.5	22.6	3.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.9	13.8	23.0	17.9	12.9	21.7	16.8	12.0	20.6	59.8	25.9	56.0	23.9	52.5	22.6	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.5	6.0	-25.1	29.4	4.9	1.6	-28.6	30.6	-31.5	31.5	-34.3	32.5	-37.9	33.7		
(5)			-25.2	21.9	4.7	1.3	-28.6	22.9	-31.3	23.7	-33.9	24.4	-37.3	25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.8	-5.0	-4.7	-1.2	4.7	10.6	14.0	17.4	16.0	11.3	5.6	1.7	-1.2
	DBStd	8.82	6.48	6.06	4.82	3.57	4.19	3.17	3.09	2.94	3.17	4.13	4.25	5.18
	HDD10.0	2196	464	413	347	163	41	4	0	1	23	144	248	348
	HDD18.3	4611	723	646	605	409	242	135	56	84	209	396	498	607
	CDD10.0	675	0	0	0	3	61	124	229	187	63	7	0	0
	CDD18.3	47	0	0	0	0	3	6	27	12	0	0	0	0
	CDH23.3	509	0	0	0	0	42	73	280	113	1	0	0	0
	CDH26.7	89	0	0	0	0	4	7	61	18	0	0	0	0
Wind	WSAvg	2.8	3.0	3.0	3.1	2.9	2.7	2.8	2.5	2.4	2.4	2.8	3.1	3.3
Precipitation	PrecAvg	720	50	37	36	40	42	60	88	79	85	71	82	60
	PrecMax	987	104	140	81	119	80	131	164	183	178	168	176	112
	PrecMin	483	6	3	3	1	1	3	28	9	24	11	30	14
	PrecStd	120	24	25	20	26	22	32	37	44	36	36	32	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.9	5.3	13.5	20.0	26.8	27.7	30.3	28.9	22.0	15.2	10.1	9.0
		MCWB	5.1	3.9	7.2	10.9	16.9	18.4	20.7	20.0	16.1	12.5	9.0	8.0
	2%	DB	4.5	3.9	9.0	17.2	24.2	25.6	28.4	26.2	20.0	13.6	8.9	7.3
		MCWB	4.0	3.1	5.0	9.4	15.7	17.6	20.2	18.9	15.5	12.0	8.2	6.4
	5%	DB	3.1	2.8	6.3	14.6	21.9	23.3	26.5	24.2	18.4	12.5	8.1	5.7
		MCWB	2.6	2.2	3.6	8.2	14.3	16.5	19.4	18.0	14.5	11.4	7.4	5.0
	10%	DB	2.2	1.9	4.3	12.2	19.5	21.3	24.5	22.4	16.9	11.5	7.1	4.5
		MCWB	1.8	1.5	2.5	6.9	12.9	15.2	18.3	17.1	14.1	10.4	6.6	3.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.3	4.4	7.8	11.7	19.4	20.9	22.4	21.3	17.3	13.5	9.3	8.1
		MCDB	5.7	4.8	12.4	17.6	23.6	24.7	27.9	26.3	20.2	14.2	9.8	8.8
	2%	WB	4.0	3.2	5.3	10.2	17.1	18.9	21.2	19.9	16.1	12.5	8.3	6.5
		MCDB	4.3	3.7	8.2	15.7	22.4	23.4	26.7	24.3	18.7	13.2	8.8	7.1
	5%	WB	2.7	2.3	3.9	8.9	15.4	17.3	20.1	18.9	15.2	11.6	7.5	5.1
		MCDB	3.0	2.7	5.8	13.7	20.1	22.1	24.7	22.8	17.5	12.4	8.0	5.6
	10%	WB	1.7	1.5	2.8	7.5	13.6	15.9	19.1	17.8	14.3	10.6	6.6	4.0
		MCDB	2.0	1.9	4.1	11.4	18.5	20.5	23.7	21.2	16.4	11.3	7.1	4.5
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.6	7.5	10.2	11.8	10.4	10.2	10.2	8.6	6.4	4.1	4.0
		MCDBR	3.7	4.3	10.1	15.7	15.7	14.0	13.5	13.6	11.5	7.2	4.3	3.6
		MCWBR	3.6	3.8	6.6	8.9	7.9	7.1	6.2	7.2	7.0	5.5	4.0	3.5
	5% WB	MCDBR	3.8	4.1	8.7	13.8	12.9	11.6	12.0	11.8	9.6	6.1	4.3	3.4
		MCWBR	3.6	3.7	6.0	8.3	7.0	6.7	6.0	6.9	6.4	5.1	4.0	3.4
Clear-Sky Solar Irradiance	taub	0.276	0.306	0.332	0.368	0.364	0.362	0.388	0.384	0.352	0.334	0.313	0.268	
	taud	2.126	2.158	2.221	2.317	2.392	2.420	2.370	2.380	2.459	2.401	2.214	2.100	
	Ebn at Noon	519	696	798	835	867	873	837	811	783	675	471	391	
	Edh at Noon	48	78	98	107	106	105	108	100	79	62	45	35	
All-Sky Solar Radiation	RadAvg	0.29	0.90	2.37	3.93	5.41	5.61	5.32	4.20	2.61	1.17	0.34	0.18	
	RadStd	0.06	0.16	0.30	0.43	0.57	0.41	0.49	0.42	0.32	0.16	0.05	0.03	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (52 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	-131	N/A	N/A	N/A

Nomenclature: See separate page