

JOGEVA, Estonia

WMO: 261440

Lat: 58.7497N

Lon: 26.4150E

Elev: 72

StdP: 100.47

Time Zone: 2.00 (EUE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -24.1	(c) -20.1	(d) -26.4	(e) 0.3	(f) -24.1	(g) -22.2	(h) 0.5	(i) -19.9	(j) 8.6	(k) -2.5	(l) 7.7	(m) -3.7	(n) 1.2	(o) 70	(p) 0.572

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	27.8	19.3	26.0	18.3	24.1	17.5	20.7	25.5	19.5	24.0	18.4	22.8	2.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	13.8	23.0	17.8	12.9	21.8	16.7	12.0	20.5	59.8	25.5	55.8	24.0	52.4	22.9	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.4	6.3	5.6	-26.4	29.6	5.6	1.6	-30.4	30.7	-33.7	31.7	-36.8	32.6	-40.8	33.7
			-26.4	22.0	5.3	1.0	-30.3	22.7	-33.4	23.3	-36.4	23.8	-40.3	24.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	-5.9	-5.6	-1.6	4.9	11.0	14.4	17.5	16.0	11.3	5.4	1.3	-2.1		
	DBStd	9.28	7.05	6.74	5.29	3.67	4.28	3.21	3.25	2.99	3.17	4.05	4.18	5.52		
	HDD10.0	2294	492	436	359	158	37	3	0	1	22	148	261	376		
	HDD18.3	4692	751	669	618	404	231	125	56	84	210	401	511	634		
	CDD10.0	696	0	0	0	4	68	134	233	188	62	6	0	0		
	CDD18.3	51	0	0	0	0	3	6	29	13	0	0	0	0		
	CDH23.3	538	0	0	0	0	38	86	290	123	2	0	0	0		
	CDH26.7	95	0	0	0	0	4	9	61	20	0	0	0	0		
(14) Wind	WSAvg	2.7	2.7	2.7	2.9	2.8	2.6	2.7	2.4	2.2	2.4	2.6	2.8	3.0		
(15) Precipitation	PrecAvg	668	50	38	36	31	50	82	71	85	52	67	56	50		
	PrecMax	883	101	83	69	66	101	179	163	196	101	113	88	103		
	PrecMin	475	18	7	13	7	3	10	14	3	6	8	9	18		
	PrecStd	113	20	17	16	15	24	38	34	44	26	24	21	19		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.9	5.2	13.3	20.4	27.1	28.0	30.4	29.0	22.8	15.1	9.7	8.5		
		MCWB	5.4	3.8	7.0	11.3	17.7	19.2	20.5	19.5	16.4	12.3	8.5	7.4		
	2%	DB	4.3	3.9	8.8	17.5	23.8	25.9	28.4	26.4	20.1	13.6	8.6	6.7		
		MCWB	3.8	3.0	4.9	9.6	15.7	17.4	19.8	19.0	15.4	11.9	7.7	5.7		
	5%	DB	2.9	2.7	6.2	14.8	21.6	23.6	26.6	24.4	18.4	12.4	7.7	5.4		
		MCWB	2.4	2.0	3.5	8.3	14.7	16.8	19.2	17.7	14.4	11.1	7.0	4.6		
	10%	DB	1.9	1.7	4.3	12.3	19.3	21.5	24.6	22.5	16.9	11.3	6.6	4.0		
		MCWB	1.4	1.2	2.6	7.0	13.2	15.4	18.3	16.9	13.7	10.2	6.0	3.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	4.4	7.6	12.0	19.7	21.2	22.1	21.4	17.2	13.2	8.7	7.8		
		MCDB	5.9	5.0	12.0	18.2	23.7	25.2	27.8	26.4	20.4	14.1	9.2	8.5		
	2%	WB	3.8	3.1	5.2	10.3	17.5	19.1	21.1	19.7	16.1	12.2	7.9	5.9		
		MCDB	4.2	3.6	8.1	16.4	22.1	23.8	26.4	23.9	18.9	13.2	8.4	6.6		
	5%	WB	2.5	2.1	3.8	9.0	15.7	17.5	20.1	18.7	15.1	11.4	7.1	4.6		
		MCDB	2.8	2.6	5.6	13.7	19.9	21.9	24.7	22.8	17.7	12.3	7.6	5.3		
	10%	WB	1.4	1.2	2.9	7.6	14.0	16.1	19.0	17.7	14.1	10.3	6.0	3.3		
		MCDB	1.8	1.7	4.2	11.3	18.1	20.8	23.7	21.7	16.3	11.2	6.5	3.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	5.7	7.7	9.8	11.1	10.2	10.3	10.1	8.5	6.0	3.7	3.9		
		MCDBR	3.5	4.1	9.4	15.6	13.9	14.0	13.2	13.5	11.3	7.0	4.3	3.9		
	5% WB	MCWBR	3.3	3.6	6.1	8.5	7.0	6.9	5.8	6.6	6.8	5.4	3.9	3.7		
		MCWBR	3.6	3.7	8.1	13.6	11.7	11.5	11.5	11.2	9.8	6.0	4.0	3.7		
(40) Clear-Sky Solar Irradiance	taub		0.273	0.304	0.332	0.370	0.365	0.363	0.387	0.386	0.354	0.333	0.309	0.263		
		taud	2.111	2.133	2.192	2.305	2.388	2.420	2.373	2.373	2.450	2.400	2.205	2.087		
	Ebn at Noon		528	699	798	834	867	872	839	811	782	680	481	405		
		Edh at Noon	50	80	101	108	107	105	108	101	80	63	46	36		
(44) All-Sky Solar Radiation	RadAvg		0.31	0.94	2.39	3.86	5.32	5.44	5.28	4.14	2.60	1.12	0.33	0.19		
	RadStd		0.06	0.17	0.31	0.46	0.56	0.45	0.51	0.42	0.31	0.16	0.05	0.03		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)		+0.44	N/A	N/A	N/A	N/A	N/A	-160	-165	N/A	N/A

Nomenclature: See separate page