

TILRIKOJA, Estonia

WMO: 261450

Lat: 58.8653N

Lon: 26.9522E

Elev: 111

StdP: 14.64

Time Zone: 2.00 (EUE)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-8.2	-1.5	-12.5	2.8	-8.1	-5.6	4.1	-1.2	20.4	20.0	16.9	27.3	2.5	330	0.551

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.2	79.1	68.4	76.3	66.9	73.8	65.1	70.8	76.8	68.6	74.6	66.4	71.8	5.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.6	105.3	74.8	66.2	97.1	72.5	64.1	89.8	70.2	34.7	77.1	32.9	74.8	31.1	71.8	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	13.2	11.2	DB	-11.9	83.4	10.7	3.3	-19.6	85.8	-25.8	87.7	-31.8	89.6	-39.6	92.0	(4)
(5)			WB	-12.0	72.5	9.8	2.5	-19.0	74.4	-24.7	75.8	-30.2	77.2	-37.3	79.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.5	22.8	22.4	29.2	39.7	51.0	58.0	63.8	61.2	52.9	42.7	35.0	29.6
	DBStd	16.22	12.10	11.91	8.44	6.36	7.05	5.50	5.36	4.93	5.47	6.86	6.93	9.09
	HDD50	4013	845	773	646	315	73	5	0	1	35	238	449	633
	HDD65	8305	1310	1193	1111	759	437	217	88	139	364	690	899	1098
	CDD50	1265	0	0	0	7	102	246	429	348	120	13	0	0
	CDD65	83	0	0	0	0	2	8	52	21	0	0	0	0
	CDH74	517	0	0	0	0	19	66	313	119	0	0	0	0
	CDH80	43	0	0	0	0	1	3	32	7	0	0	0	0
Wind	WSAvg	5.0	5.7	5.2	5.1	4.6	4.6	4.7	4.1	4.3	4.4	5.2	5.9	6.2
Precipitation	PrecAvg	25.4	1.9	1.4	1.3	1.2	1.9	3.1	2.8	3.1	2.0	2.5	2.2	1.9
	PrecMax	34.3	3.5	3.0	2.4	2.4	4.3	6.9	6.3	8.6	4.1	4.3	4.1	3.6
	PrecMin	16.7	0.7	0.4	0.4	0.3	0.1	0.6	0.4	0.2	0.4	0.4	0.4	0.6
	PrecStd	4.4	0.7	0.6	0.6	0.6	1.0	1.3	1.2	1.9	1.0	0.9	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.0	42.2	51.7	67.2	76.3	79.8	83.3	80.7	70.5	60.0	50.4	48.2
		MCWB	41.8	38.6	43.6	52.2	60.7	64.9	70.2	69.9	61.4	54.6	47.5	45.5
	2%	DB	39.8	39.3	45.9	59.4	70.9	75.7	80.1	77.1	67.1	57.0	48.2	44.8
		MCWB	38.5	37.0	39.1	49.3	58.8	63.5	70.4	68.1	60.1	53.8	46.3	42.8
	5%	DB	37.5	37.3	42.0	54.4	67.3	72.3	77.6	74.5	64.5	54.8	46.4	42.5
		MCWB	36.2	35.9	37.6	46.3	56.9	62.2	68.7	66.1	58.7	52.3	44.8	40.8
	10%	DB	35.8	35.7	39.1	50.8	63.7	69.3	75.0	71.4	62.1	52.7	44.4	40.0
		MCWB	34.8	34.4	36.0	44.0	55.2	60.6	67.1	63.9	57.2	50.3	43.0	38.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	40.0	43.5	54.6	65.5	69.5	74.4	72.1	64.2	56.0	48.3	46.1
		MCDB	42.9	41.2	50.4	64.3	70.2	75.3	80.3	77.8	68.1	57.9	49.5	47.7
	2%	WB	38.6	37.6	40.3	50.0	61.7	66.5	72.1	69.3	61.3	54.3	46.5	43.2
		MCDB	39.5	38.9	44.4	57.9	67.9	72.8	77.8	75.6	65.3	56.4	47.8	44.7
	5%	WB	36.4	36.0	38.2	47.5	59.1	63.8	70.1	67.3	59.4	52.6	44.9	40.9
		MCDB	37.3	37.2	41.1	53.3	64.5	69.6	76.1	72.8	63.1	54.6	46.3	42.3
	10%	WB	34.8	34.5	36.4	44.7	56.2	61.6	67.9	65.2	57.7	50.7	43.0	38.7
		MCDB	35.6	35.5	38.8	50.2	62.4	67.5	73.9	70.0	61.2	52.4	44.1	39.9
Mean Daily Temperature Range	5% DB	MDBR	8.5	10.0	12.3	15.3	18.2	17.0	16.2	16.1	14.0	10.2	6.5	6.4
		MCDBR	6.5	8.2	14.7	22.7	23.8	22.3	19.4	19.9	17.1	12.3	8.3	7.3
		MCWBR	6.3	7.0	9.8	13.5	12.9	12.0	10.7	11.4	10.6	9.3	7.2	6.8
	5% WB	MCDBR	6.3	7.7	12.9	20.8	19.8	18.7	17.0	17.9	15.2	11.2	7.4	6.8
MCWBR		6.2	6.9	9.2	13.4	11.9	11.9	10.4	11.6	10.4	9.1	6.8	6.5	
Clear-Sky Solar Irradiance	taub	0.274	0.306	0.335	0.375	0.369	0.367	0.390	0.389	0.358	0.335	0.310	0.263	
	taud	2.104	2.123	2.186	2.294	2.384	2.421	2.374	2.372	2.446	2.397	2.196	2.078	
	Ebn at Noon	165	220	252	263	273	276	265	256	246	214	151	126	
	Edh at Noon	16	26	32	35	34	33	34	32	25	20	15	11	
All-Sky Solar Radiation	RadAvg	95	292	753	1222	1686	1729	1684	1314	823	351	102	57	
	RadStd	16	54	99	144	180	144	162	135	99	51	15	9	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
Regional (39 neighbors)		+0.81	N/A	N/A	N/A	N/A	N/A	-288	-297	N/A

Nomenclature: See separate page