

TILRIKOJA, Estonia

WMO: 261450

Lat: 58.8653N

Lon: 26.9522E

Elev: 34

StdP: 100.92

Time Zone: 2.00 (EUE)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-22.3	-18.6	-24.7	0.4	-22.3	-20.9	0.6	-18.4	9.1	-6.7	7.5	-2.6	1.1	330	0.551

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	26.1	20.2	24.6	19.4	23.2	18.4	21.6	24.9	20.3	23.7	19.1	22.1	2.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.0	23.8	19.0	13.9	22.5	17.8	12.8	21.2	62.9	25.1	58.6	23.8	54.5	22.1	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	5.9	5.0	-24.4	28.6	5.9	1.8	-28.6	29.9	-32.1	31.0	-35.5	32.0	-39.8	33.3		
(5)			-24.4	22.5	5.4	1.4	-28.3	23.5	-31.5	24.4	-34.6	25.1	-38.5	26.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.8	-5.1	-5.3	-1.6	4.3	10.5	14.5	17.7	16.2	11.6	6.0	1.7	-1.3
	DBStd	9.01	6.72	6.62	4.69	3.53	3.92	3.05	2.98	2.74	3.04	3.81	3.85	5.05
	HDD10.0	2229	469	429	359	175	41	3	0	1	19	132	249	352
	HDD18.3	4614	728	663	617	422	243	121	49	77	202	383	499	610
	CDD10.0	703	0	0	0	4	57	137	238	193	67	7	0	0
	CDD18.3	46	0	0	0	0	1	4	29	12	0	0	0	0
	CDH23.3	287	0	0	0	0	11	37	174	66	0	0	0	0
	CDH26.7	24	0	0	0	0	1	2	18	4	0	0	0	0
Wind	WSAvg	2.2	2.5	2.3	2.3	2.1	2.1	2.1	1.9	1.9	2.0	2.3	2.6	2.8
Precipitation	PrecAvg	644	47	36	34	30	49	78	70	80	52	64	56	47
	PrecMax	872	90	76	62	60	110	175	160	219	105	110	103	91
	PrecMin	425	17	9	10	7	2	14	10	4	9	11	10	15
	PrecStd	113	18	16	16	15	25	34	31	48	26	22	23	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.1	5.7	10.9	19.5	24.6	26.5	28.5	27.1	21.4	15.5	10.2	9.0
		MCWB	5.4	3.7	6.5	11.2	15.9	18.3	21.2	21.1	16.4	12.5	8.6	7.5
	2%	DB	4.4	4.0	7.7	15.2	21.6	24.3	26.7	25.1	19.5	13.9	9.0	7.1
		MCWB	3.6	2.8	3.9	9.6	14.9	17.5	21.3	20.1	15.6	12.1	7.9	6.0
	5%	DB	3.1	3.0	5.6	12.5	19.6	22.4	25.3	23.6	18.1	12.7	8.0	5.8
		MCWB	2.3	2.2	3.1	8.0	13.8	16.8	20.4	18.9	14.8	11.3	7.1	4.9
	10%	DB	2.1	2.0	4.0	10.4	17.6	20.7	23.9	21.9	16.7	11.5	6.9	4.4
		MCWB	1.5	1.3	2.2	6.7	12.9	15.9	19.5	17.7	14.0	10.2	6.1	3.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	4.5	6.4	12.6	18.6	20.8	23.5	22.3	17.9	13.4	9.0	7.8
		MCDB	6.0	5.1	10.2	17.9	21.2	24.0	26.8	25.4	20.1	14.4	9.7	8.7
	2%	WB	3.7	3.1	4.6	10.0	16.5	19.2	22.3	20.7	16.3	12.4	8.1	6.2
		MCDB	4.2	3.8	6.9	14.4	19.9	22.6	25.4	24.2	18.5	13.6	8.8	7.1
	5%	WB	2.5	2.2	3.5	8.6	15.0	17.6	21.2	19.6	15.2	11.5	7.2	4.9
		MCDB	3.0	2.9	5.0	11.8	18.1	20.9	24.5	22.6	17.3	12.6	7.9	5.7
	10%	WB	1.5	1.4	2.4	7.1	13.5	16.5	20.0	18.4	14.3	10.4	6.1	3.7
		MCDB	2.0	1.9	3.8	10.1	16.9	19.7	23.3	21.1	16.2	11.4	6.7	4.4
Mean Daily Temperature Range	5% DB	MDBR	4.7	5.5	6.8	8.5	10.1	9.5	9.0	8.9	7.8	5.6	3.6	3.6
		MCDBR	3.6	4.6	8.1	12.6	13.2	12.4	10.8	11.1	9.5	6.9	4.6	4.0
		MCWBR	3.5	3.9	5.4	7.5	7.1	6.7	5.9	6.4	5.9	5.2	4.0	3.8
	5% WB	MCDBR	3.5	4.3	7.2	11.6	11.0	10.4	9.4	9.9	8.4	6.2	4.1	3.8
		MCWBR	3.4	3.8	5.1	7.5	6.6	6.6	5.8	6.5	5.8	5.1	3.8	3.6
Clear-Sky Solar Irradiance	taub	0.274	0.306	0.335	0.375	0.369	0.367	0.390	0.389	0.358	0.335	0.310	0.263	
	taud	2.104	2.123	2.186	2.294	2.384	2.421	2.374	2.372	2.446	2.397	2.196	2.078	
	Ebn at Noon	521	693	794	828	862	869	836	806	776	675	475	396	
	Edh at Noon	49	81	102	110	107	105	108	101	80	63	46	36	
All-Sky Solar Radiation	RadAvg	0.30	0.92	2.37	3.85	5.31	5.45	5.31	4.14	2.59	1.11	0.32	0.18	
	RadStd	0.05	0.17	0.31	0.46	0.57	0.46	0.51	0.42	0.31	0.16	0.05	0.03	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	-160	-165	N/A	N/A

Nomenclature: See separate page