

RETYUN', Russian Federation

WMO: 261670

Lat: 58.567N

Lon: 29.800E

Elev: 91

StdP: 100.24

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-22.8	-19.8	-25.2	0.4	-22.5	-22.2	0.5	-19.6	7.6	-0.2	6.9	-0.9	1.0	20	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	27.6	19.8	25.8	18.8	24.1	17.9	21.1	25.7	19.9	23.9	18.8	22.7	2.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.5	14.4	23.4	18.4	13.4	22.1	17.3	12.5	20.7	61.5	25.9	57.3	23.9	53.7	22.9	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.6	5.9	5.2	DB	-26.0	30.1	4.1	1.7	-28.9	31.3	-31.3	32.3	-33.6	33.2	-36.6	34.4	(4)
(5)			WB	-26.6	22.6	3.5	1.5	-29.1	23.7	-31.1	24.5	-33.1	25.4	-35.6	26.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.5	-6.0	-6.0	-1.3	5.6	11.2	15.2	18.0	16.1	11.3	5.3	-0.1	-3.8	(6)
(7)		DBStd	9.66	6.60	6.71	4.51	4.42	4.36	3.49	3.12	3.00	3.37	3.94	4.91	5.88	(7)
(8)		HDD10.0	2389	496	449	352	145	38	3	0	1	24	152	303	428	(8)
(9)		HDD18.3	4736	754	682	609	382	223	105	44	82	210	404	553	686	(9)
(10)		CDD10.0	758	0	0	0	13	76	159	249	190	65	6	0	0	(10)
(11)		CDD18.3	63	0	0	0	0	3	12	34	14	1	0	0	0	(11)
(12)		CDH23.3	514	0	0	0	1	32	102	264	112	3	0	0	0	(12)
(13)		CDH26.7	90	0	0	0	0	4	14	55	17	0	0	0	0	(13)
(14)	Wind	WSAvg	2.5	2.7	2.7	2.8	2.6	2.4	2.3	2.0	2.1	2.3	2.6	2.8	2.9	(14)
(15)	Precipitation	PrecAvg	652	40	30	37	39	48	63	80	87	67	56	59	46	(15)
(16)		PrecMax	829	71	79	92	87	90	133	155	238	148	118	116	90	(16)
(17)		PrecMin	444	7	6	7	2	10	7	30	22	12	7	2	20	(17)
(18)		PrecStd	99	18	15	18	24	21	29	35	52	33	24	21	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.4	5.3	13.0	22.3	26.6	28.5	30.6	28.8	23.4	16.4	9.5	7.4	(19)
(20)			MCWB	4.6	3.5	6.2	12.5	17.3	19.9	21.7	20.2	17.5	12.6	8.5	6.1	(20)
(21)		2%	DB	3.1	3.7	8.8	19.1	23.7	26.2	28.1	26.1	20.4	13.4	8.1	5.5	(21)
(22)			MCWB	2.3	2.3	4.4	10.9	15.8	18.5	20.6	18.7	16.0	11.6	7.2	4.7	(22)
(23)		5%	DB	2.1	2.7	6.1	16.1	21.5	24.1	26.3	24.3	18.4	12.1	7.1	4.0	(23)
(24)			MCWB	1.5	1.8	2.8	9.4	14.2	17.4	19.7	18.2	14.5	10.8	6.4	3.4	(24)
(25)		10%	DB	1.2	1.6	4.3	13.4	19.2	22.1	24.4	22.2	16.6	10.9	5.8	2.8	(25)
(26)			MCWB	0.7	1.0	2.3	8.2	13.0	16.4	18.7	17.2	13.8	9.7	5.2	2.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.7	3.9	7.3	13.7	19.9	21.4	22.8	22.1	18.5	13.4	8.6	6.2	(27)
(28)			MADB	5.1	4.8	12.0	20.4	24.7	26.0	28.2	26.7	22.0	15.0	9.1	6.9	(28)
(29)		2%	WB	2.6	2.7	4.9	11.8	17.2	19.7	21.6	20.1	16.7	12.0	7.4	4.8	(29)
(30)			MADB	2.9	3.4	7.5	17.5	21.7	24.4	26.5	23.8	19.1	13.2	7.9	5.3	(30)
(31)		5%	WB	1.6	1.9	3.6	10.2	15.4	18.4	20.6	18.9	15.4	11.0	6.4	3.5	(31)
(32)			MADB	2.0	2.6	5.5	15.2	19.5	22.5	24.9	22.8	17.5	12.0	7.0	4.1	(32)
(33)		10%	WB	0.7	1.0	2.5	8.7	13.8	17.2	19.4	17.8	14.2	9.9	5.2	2.2	(33)
(34)			MADB	1.1	1.6	4.0	12.8	18.0	20.9	23.3	21.4	16.2	10.8	5.7	2.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.5	5.7	6.7	9.1	10.2	9.2	9.1	7.7	5.2	3.7	4.0	(35)	
(36)			MADB	3.4	4.4	9.0	14.0	13.5	12.5	12.0	12.5	10.4	6.6	4.4	3.6	(36)
(37)			MCWBR	3.3	3.7	5.8	7.2	6.7	5.9	5.4	5.9	6.0	4.8	4.0	3.4	(37)
(38)		5% WB	MADB	3.4	4.2	7.6	12.2	11.6	10.6	10.9	11.0	8.8	6.4	4.1	3.4	(38)
(39)			MCWBR	3.4	3.7	5.3	6.7	6.5	5.7	5.4	6.0	5.6	4.9	3.9	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.278	0.314	0.337	0.378	0.371	0.368	0.393	0.391	0.361	0.337	0.313	0.270	(40)
(41)		taud		2.125	2.128	2.187	2.282	2.377	2.412	2.359	2.359	2.423	2.383	2.223	2.109	(41)
(42)		Ebn at Noon		529	687	793	826	861	868	833	806	773	675	486	408	(42)
(43)		Edh at Noon		50	81	103	111	108	106	110	103	83	64	47	36	(43)
(44)	All-Sky Solar Radiation	RadAvg		0.33	0.98	2.38	3.83	5.20	5.38	5.20	4.11	2.56	1.08	0.33	0.19	(44)
(45)		RadStd		0.07	0.19	0.31	0.49	0.52	0.51	0.59	0.38	0.29	0.19	0.05	0.04	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	-171	N/A	N/A	N/A	
(47)	Regional (14 neighbors)	+0.49	N/A	N/A	N/A	N/A	N/A	-185	-197	N/A	N/A	

Nomenclature: See separate page