

PJARNU-SAUGA, Estonia

WMO: 262310

Lat: 58.4197N

Lon: 24.4697E

Elev: 43

StdP: 14.67

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.6	3.3	-7.8	3.6	-2.9	-1.5	5.1	4.1	25.0	33.9	22.8	33.7	4.4	80	0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.8	81.5	68.0	78.3	66.3	75.1	64.6	70.1	78.3	68.1	75.8	66.2	72.9	7.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.1	100.0	74.6	65.2	93.3	72.1	63.4	87.6	70.3	34.1	78.1	32.4	75.8	30.9	72.6	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.9	20.0	17.7	DB	-7.0	86.3	8.1	2.8	-12.8	88.3	-17.6	90.0	-22.1	91.5	-27.9	93.6	
			WB	-7.5	73.5	7.9	2.3	-13.2	75.1	-17.8	76.4	-22.2	77.7	-27.9	79.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.9	25.1	24.4	30.8	41.8	51.9	59.2	64.7	62.7	54.4	44.1	36.0	29.9
	DBStd	15.86	10.18	10.38	7.01	7.13	7.34	5.73	5.33	4.91	5.52	6.75	7.29	9.02
	HDD50	3683	772	717	597	265	61	2	0	0	23	203	420	623
	HDD65	7835	1237	1137	1062	697	411	192	71	104	317	649	870	1088
	CDD50	1443	0	0	0	18	120	279	456	395	156	19	0	0
	CDD65	121	0	0	0	0	6	18	62	34	1	0	0	0
	CDH74	896	0	0	0	1	66	141	474	212	2	0	0	0
	CDH80	154	0	0	0	0	6	19	98	31	0	0	0	0
Wind	WSAvg	8.2	8.7	8.4	8.3	8.1	7.8	8.1	7.2	7.3	7.7	8.4	8.8	9.3
Precipitation	PrecAvg	25.9	1.7	1.1	1.3	1.6	1.5	2.0	2.9	2.9	2.8	2.8	2.9	2.4
	PrecMax	39.1	3.5	2.9	2.7	5.3	3.1	5.1	6.4	7.6	5.4	7.4	5.3	5.1
	PrecMin	17.6	0.2	0.2	0.2	0.1	0.2	0.2	0.8	0.2	1.2	0.4	0.9	0.6
	PrecStd	5.1	0.7	0.6	0.7	1.1	0.7	1.1	1.7	1.8	1.2	1.8	1.0	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.5	41.4	54.0	70.1	80.2	82.7	86.6	84.0	72.8	60.5	50.2	46.8
		MCWB	41.5	38.9	44.2	54.7	62.7	68.0	71.1	68.2	62.9	56.0	48.4	45.1
	2%	DB	39.6	38.4	45.5	64.2	75.1	78.2	82.8	79.2	68.6	57.3	48.3	44.5
		MCWB	38.5	36.8	40.0	51.7	60.6	65.1	69.3	67.5	61.0	54.3	46.8	43.1
	5%	DB	37.5	36.9	41.8	59.3	70.4	73.8	79.3	75.8	65.9	55.3	46.8	42.4
		MCWB	36.5	35.6	37.7	48.9	57.7	63.0	67.6	65.9	59.3	53.0	45.4	41.1
	10%	DB	35.7	35.5	38.8	54.8	65.8	70.3	75.9	72.6	63.3	53.6	45.2	40.3
		MCWB	34.9	34.6	35.9	46.4	55.4	61.0	66.0	64.0	58.2	51.5	44.0	39.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.0	39.5	45.2	56.8	67.1	70.0	73.4	72.0	64.7	57.0	48.6	45.9
		MCDB	42.6	40.8	51.5	67.6	75.7	79.4	83.7	78.9	70.2	59.0	49.4	46.6
	2%	WB	38.9	37.2	40.9	53.0	62.8	67.3	71.1	69.2	62.4	55.0	47.1	43.4
		MCDB	39.5	38.0	44.9	62.0	72.3	75.4	80.0	76.3	66.9	56.7	47.9	44.3
	5%	WB	36.6	35.8	38.4	50.1	59.4	64.6	69.0	67.1	60.6	53.5	45.7	41.3
		MCDB	37.2	36.6	41.2	57.7	67.7	71.4	76.9	73.9	64.4	55.1	46.6	42.2
	10%	WB	35.0	34.7	36.3	47.2	56.4	62.1	67.1	65.3	59.1	51.8	44.2	39.3
		MCDB	35.6	35.4	38.0	53.5	64.6	68.8	74.2	71.1	62.4	53.3	45.1	40.1
Mean Daily Temperature Range	5% DB	MDBR	8.0	9.3	11.4	15.2	17.6	15.6	15.8	15.6	13.5	10.0	6.8	6.9
		MCDBR	6.4	6.9	15.1	23.7	25.4	21.4	21.6	20.7	16.9	11.1	7.2	6.1
		MCWBR	6.1	6.2	10.5	13.3	13.4	11.3	10.5	11.4	10.7	8.7	6.9	5.8
	5% WB	MCDBR	6.0	6.7	13.3	20.5	21.4	18.5	18.9	17.5	13.8	9.4	6.8	5.8
		MCWBR	5.8	6.2	9.8	12.4	12.1	11.1	10.6	10.9	9.6	8.1	6.8	5.7
Clear-Sky Solar Irradiance	taub	0.285	0.311	0.338	0.374	0.369	0.368	0.396	0.391	0.359	0.339	0.322	0.279	
	taud	2.156	2.177	2.229	2.304	2.391	2.424	2.366	2.377	2.450	2.404	2.232	2.137	
	Ebn at Noon	168	222	253	264	274	276	264	256	247	215	153	129	
	Edh at Noon	16	25	31	35	34	33	35	32	26	20	15	12	
All-Sky Solar Radiation	RadAvg	105	313	769	1260	1710	1765	1666	1321	838	387	120	67	
	RadStd	22	59	96	139	172	127	158	132	97	54	18	11	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page