

RUJIENA, Latvia

WMO: 262380

Lat: 57.8865N

Lon: 25.3718E

Elev: 226

StdP: 14.58

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.5	1.1	-9.8	3.3	-4.9	-3.5	4.6	2.8	20.7	32.0	18.7	32.6	4.6	90	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	81.9	67.5	78.9	65.3	76.0	64.2	69.5	78.2	67.4	75.8	65.5	73.4	7.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	97.6	74.6	64.2	90.8	71.7	62.4	85.0	69.4	33.7	78.1	31.9	75.8	30.5	73.5	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.2	16.2	14.4	DB	-14.1	87.2	6.7	2.8	-19.0	89.2	-22.9	90.8	-26.7	92.4	-31.6	94.4	
			WB	-12.4	71.9	7.3	2.3	-17.7	73.5	-21.9	74.9	-26.0	76.2	-31.3	77.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.3	22.3	24.9	31.5	42.6	52.7	59.7	64.0	61.9	53.3	42.3	35.5	27.5
	DBStd	16.33	10.55	11.09	7.49	7.00	8.26	6.61	5.87	5.19	5.66	6.67	7.57	9.88
	HDD50	3861	858	703	575	240	64	5	0	0	33	251	434	698
	HDD65	8055	1323	1123	1040	671	389	186	92	126	353	705	884	1163
	CDD50	1410	0	0	0	19	149	296	433	370	131	12	0	0
	CDD65	126	0	0	0	0	8	27	60	31	0	0	0	0
	CDH74	1041	0	0	0	0	80	222	462	274	3	0	0	0
	CDH80	170	0	0	0	0	6	28	89	47	0	0	0	0
Wind	WSAvg	7.1	7.5	7.5	7.9	7.4	6.8	6.8	6.2	5.9	6.6	7.0	7.7	7.5
Precipitation	PrecAvg	27.9	2.2	1.7	1.6	1.4	2.0	3.1	2.9	3.1	2.2	3.2	2.4	2.1
	PrecMax	33.4	4.3	3.4	3.3	4.4	4.0	5.0	5.4	6.0	4.3	5.2	4.1	3.9
	PrecMin	19.5	0.7	0.4	0.5	0.3	0.4	0.8	0.2	0.0	0.6	1.9	0.4	1.1
	PrecStd	3.7	1.0	0.8	0.8	0.9	0.9	1.3	1.4	1.7	1.0	1.0	1.0	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.5	42.9	53.0	70.8	80.3	83.3	85.8	85.8	73.6	61.1	51.4	44.9
		MCWB	40.8	39.2	43.7	52.6	62.2	68.1	69.0	67.9	61.8	54.9	48.9	42.8
	2%	DB	38.5	40.0	47.0	65.4	76.3	79.8	82.7	80.1	69.1	56.7	48.4	42.0
		MCWB	37.1	37.7	40.7	50.4	61.4	65.4	68.6	66.0	59.0	53.1	46.4	40.2
	5%	DB	36.5	37.7	43.3	60.1	72.1	76.2	79.2	77.1	65.6	54.1	46.7	40.5
		MCWB	35.3	36.3	38.7	48.7	58.2	64.2	66.8	64.1	57.7	51.3	45.1	39.1
	10%	DB	35.0	36.0	40.5	55.7	67.6	72.3	75.8	73.6	62.7	51.9	45.1	38.9
		MCWB	33.9	34.8	37.3	46.4	56.2	61.9	65.7	63.0	57.1	49.5	43.8	37.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.3	40.1	45.0	54.6	65.5	70.9	72.0	71.7	63.4	56.5	49.0	43.3
		MCDB	42.3	41.7	50.8	63.6	76.3	79.3	81.7	81.5	70.2	59.7	50.6	44.7
	2%	WB	37.4	37.9	41.5	52.0	62.7	67.5	70.1	68.2	61.1	53.7	46.7	40.5
		MCDB	38.2	39.1	45.7	62.7	72.4	76.4	79.3	77.5	66.4	56.0	47.9	41.4
	5%	WB	35.4	36.4	39.3	49.7	60.1	65.0	68.2	65.8	59.1	52.0	45.4	39.3
		MCDB	36.3	37.5	42.7	58.9	69.0	73.7	76.4	73.7	63.9	53.9	46.6	40.5
	10%	WB	34.0	35.0	37.6	46.9	57.8	63.0	66.4	64.0	57.4	49.9	43.8	37.6
		MCDB	34.9	36.0	40.1	54.7	65.8	70.4	74.1	71.8	61.6	51.5	45.0	38.6
Mean Daily Temperature Range	5% DB	MDBR	8.1	8.5	10.9	16.2	18.4	16.3	16.3	17.2	13.6	10.0	6.1	6.3
		MCDBR	6.2	8.0	13.8	24.4	24.4	21.4	21.2	23.3	19.1	12.0	6.8	5.8
		MCWBR	5.8	6.4	9.2	12.7	11.3	9.9	9.0	10.3	10.5	8.6	6.3	5.7
	5% WB	MCDBR	6.1	7.1	12.3	21.5	20.3	19.4	18.8	19.6	15.6	10.4	6.7	6.0
		MCWBR	5.9	6.0	8.9	12.0	10.3	9.9	8.7	9.7	9.6	8.1	6.4	6.0
Clear-Sky Solar Irradiance	taub		0.279	0.307	0.337	0.375	0.368	0.368	0.395	0.392	0.359	0.337	0.319	0.275
	taud		2.147	2.157	2.207	2.297	2.379	2.407	2.348	2.358	2.433	2.405	2.237	2.142
	Ebn at Noon		176	226	254	264	275	276	264	256	248	219	160	139
	Edh at Noon		16	26	32	35	35	34	36	33	26	21	16	12
All-Sky Solar Radiation	RadAvg		121	337	784	1268	1708	1775	1690	1334	856	398	126	76
	RadStd		27	65	105	137	169	129	151	131	92	57	18	12

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)		+0.70	N/A	N/A	N/A	N/A	N/A	-248	N/A	N/A	N/A

Nomenclature: See separate page