

RUJIENA, Latvia

WMO: 262380

Lat: 57.8865N

Lon: 25.3718E

Elev: 69

StdP: 100.50

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.8	-17.2	-23.2	0.5	-20.5	-19.7	0.7	-16.2	9.2	0.0	8.4	0.4	2.1	90	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	27.7	19.7	26.1	18.5	24.4	17.9	20.8	25.7	19.7	24.3	18.6	23.0	3.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	13.9	23.7	17.9	13.0	22.0	16.9	12.1	20.8	60.5	25.6	56.4	24.3	53.0	23.0	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.2	6.4	DB	-25.6	30.7	3.7	1.6	-28.3	31.8	-30.5	32.7	-32.6	33.6	-35.3	34.7	(4)
(5)			WB	-24.7	22.2	4.0	1.3	-27.6	23.1	-30.0	23.8	-32.2	24.6	-35.2	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.3	-5.4	-3.9	-0.3	5.9	11.5	15.4	17.8	16.6	11.8	5.7	2.0	-2.5	(6)
(7)		DBStd	9.07	5.86	6.16	4.16	3.89	4.59	3.67	3.26	2.88	3.14	3.70	4.20	5.49	(7)
(8)		HDD10.0	2145	477	391	319	133	36	3	0	0	18	139	241	388	(8)
(9)		HDD18.3	4475	735	624	578	373	216	103	51	70	196	392	491	646	(9)
(10)		CDD10.0	783	0	0	0	11	83	164	241	206	73	7	0	0	(10)
(11)		CDD18.3	70	0	0	0	0	4	15	33	17	0	0	0	0	(11)
(12)		CDH23.3	578	0	0	0	0	44	123	257	152	2	0	0	0	(12)
(13)		CDH26.7	94	0	0	0	0	3	16	49	26	0	0	0	0	(13)
(14)	Wind	WSAvg	3.2	3.3	3.4	3.5	3.3	3.0	3.1	2.8	2.6	2.9	3.1	3.5	3.4	(14)
(15)	Precipitation	PrecAvg	709	57	43	40	36	52	80	74	80	56	81	61	54	(15)
(16)		PrecMax	849	109	87	83	111	102	128	138	153	110	133	104	100	(16)
(17)		PrecMin	496	17	11	13	8	10	21	5	0	14	48	11	29	(17)
(18)		PrecStd	94	25	21	20	23	24	34	35	44	26	26	26	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.8	6.1	11.7	21.6	26.8	28.5	29.9	29.9	23.1	16.2	10.8	7.2	(19)
(20)			MCWB	4.9	4.0	6.5	11.4	16.8	20.1	20.5	20.0	16.6	12.7	9.4	6.0	(20)
(21)		2%	DB	3.6	4.4	8.3	18.6	24.6	26.6	28.2	26.7	20.6	13.7	9.1	5.5	(21)
(22)			MCWB	2.8	3.1	4.8	10.2	16.3	18.5	20.3	18.9	15.0	11.7	8.0	4.6	(22)
(23)		5%	DB	2.5	3.2	6.3	15.6	22.3	24.6	26.2	25.0	18.7	12.3	8.2	4.7	(23)
(24)			MCWB	1.8	2.4	3.7	9.3	14.6	17.9	19.3	17.8	14.3	10.7	7.3	3.9	(24)
(25)		10%	DB	1.7	2.2	4.7	13.2	19.8	22.4	24.3	23.1	17.0	11.1	7.3	3.8	(25)
(26)			MCWB	1.1	1.5	2.9	8.0	13.5	16.6	18.7	17.2	13.9	9.7	6.5	3.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	4.5	7.2	12.5	18.6	21.6	22.2	22.1	17.4	13.6	9.5	6.3	(27)
(28)			MCDWB	5.7	5.4	10.4	17.6	24.6	26.3	27.6	27.5	21.2	15.4	10.4	7.1	(28)
(29)		2%	WB	3.0	3.3	5.3	11.1	17.0	19.7	21.2	20.1	16.2	12.0	8.1	4.7	(29)
(30)			MCDWB	3.4	4.0	7.6	17.0	22.5	24.7	26.3	25.3	19.1	13.3	8.8	5.2	(30)
(31)		5%	WB	1.9	2.4	4.1	9.8	15.6	18.3	20.1	18.8	15.1	11.1	7.4	4.1	(31)
(32)			MCDWB	2.4	3.1	6.0	15.0	20.6	23.2	24.7	23.2	17.7	12.2	8.1	4.7	(32)
(33)		10%	WB	1.1	1.6	3.1	8.3	14.3	17.2	19.1	17.8	14.1	9.9	6.6	3.1	(33)
(34)			MCDWB	1.6	2.2	4.5	12.6	18.8	21.4	23.4	22.1	16.4	10.8	7.2	3.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.5	4.7	6.1	9.0	10.2	9.1	9.5	7.6	5.5	3.4	3.5	(35)	
(36)			MCDBR	3.4	4.4	7.7	13.5	13.6	11.9	11.8	13.0	10.6	6.7	3.8	3.2	(36)
(37)			MCWBR	3.2	3.5	5.1	7.1	6.3	5.5	5.0	5.7	5.8	4.8	3.5	3.2	(37)
(38)		5% WB	MCDWR	3.4	4.0	6.9	11.9	11.3	10.8	10.4	10.9	8.6	5.8	3.7	3.4	(38)
(39)			MCWBR	3.3	3.3	5.0	6.7	5.7	5.5	4.8	5.4	5.3	4.5	3.6	3.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.279	0.307	0.337	0.375	0.368	0.368	0.395	0.392	0.359	0.337	0.319	0.275	(40)	
(41)		taud	2.147	2.157	2.207	2.297	2.379	2.407	2.348	2.358	2.433	2.405	2.237	2.142	(41)	
(42)		Ebn at Noon	555	713	801	833	866	870	833	808	782	689	504	439	(42)	
(43)		Edh at Noon	52	81	102	110	109	107	112	103	83	65	49	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.38	1.06	2.47	4.00	5.38	5.60	5.33	4.21	2.70	1.26	0.40	0.24	(44)	
(45)		RadStd	0.09	0.20	0.33	0.43	0.53	0.41	0.48	0.41	0.29	0.18	0.06	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)		+0.39	N/A	N/A	N/A	N/A	N/A	-138	N/A	N/A	N/A

Nomenclature: See separate page