

PSKOV, Russian Federation

WMO: 262580

Lat: 57.817N

Lon: 28.333E

Elev: 144

StdP: 14.62

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.6	-2.6	-13.6	2.6	-9.0	-6.9	3.8	-2.0	18.8	28.9	16.7	30.2	2.5	100	0.544

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	83.9	68.7	80.5	66.6	77.2	64.9	70.6	80.5	68.6	77.6	66.6	74.8	6.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.9	99.5	75.5	64.9	92.5	73.0	63.0	86.7	70.9	34.6	80.7	32.8	77.6	31.2	74.6	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	14.9	13.3	DB	-14.9	88.4	8.0	3.1	-20.7	90.6	-25.4	92.4	-29.9	94.2	-35.7	96.4	(4)
(5)			WB	-15.2	74.1	8.0	2.9	-20.9	76.2	-25.5	77.9	-30.0	79.6	-35.8	81.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.3	22.4	22.2	30.5	43.6	53.6	60.6	65.7	62.7	53.5	42.7	34.2	26.9	(6)	
	DBStd	17.36	11.76	12.41	8.47	7.53	7.91	6.24	5.88	5.45	6.00	7.16	7.75	10.47	(7)	
	HDD50	3978	857	779	604	219	52	3	0	0	33	243	473	715	(8)	
	HDD65	8071	1322	1199	1069	641	365	160	64	111	345	692	923	1180	(9)	
	CDD50	1547	0	0	0	28	162	322	487	393	139	16	0	0	(10)	
	CDD65	164	0	0	0	0	10	29	85	39	1	0	0	0	(11)	
	CDH74	1497	0	0	0	5	118	268	733	356	17	0	0	0	(12)	
	CDH80	331	0	0	0	0	23	46	192	69	1	0	0	0	(13)	
(14) Wind	WSAvg	5.8	6.2	6.0	6.4	6.2	5.7	5.5	4.8	4.8	5.1	5.8	6.5	7.0	(14)	
(15) Precipitation	PrecAvg	24.8	1.5	1.2	1.3	1.5	2.0	3.0	3.0	3.0	2.6	2.1	2.1	1.7	(15)	
	PrecMax	35.4	3.3	2.3	2.6	3.3	4.0	7.6	6.8	7.9	5.3	4.0	3.8	3.2	(16)	
	PrecMin	17.0	0.4	0.4	0.3	0.1	0.3	0.4	0.6	1.1	0.7	0.6	0.0	0.0	(17)	
	PrecStd	4.0	0.7	0.5	0.6	0.8	0.9	1.6	1.7	1.6	1.3	0.9	0.8	0.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.8	43.1	57.1	73.7	82.7	85.1	89.7	86.0	76.7	62.9	51.3	48.4	(19)	
		MCWB	42.3	39.7	46.1	57.1	65.6	68.5	72.5	70.3	64.0	55.6	48.5	46.2	(20)	
	2%	DB	39.1	40.0	49.7	67.7	76.9	80.6	84.9	81.5	71.2	57.7	48.3	44.0	(21)	
		MCWB	37.7	37.5	42.1	53.6	61.8	65.8	69.6	67.0	61.8	53.4	46.4	42.2	(22)	
	5%	DB	36.8	37.7	44.5	62.4	72.7	77.0	81.4	78.0	67.3	55.3	46.3	41.2	(23)	
		MCWB	35.6	36.0	38.9	50.9	59.4	64.2	68.2	65.3	59.0	52.2	44.7	40.0	(24)	
	10%	DB	35.2	36.0	41.1	57.6	68.4	73.3	78.0	74.4	64.0	53.1	44.3	38.8	(25)	
		MCWB	34.1	34.6	37.6	48.2	56.8	61.8	66.3	63.7	57.3	50.3	43.0	37.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.3	40.5	47.1	59.7	68.9	71.0	74.1	72.7	65.2	57.1	49.2	46.4	(27)	
		MCDB	43.3	42.0	55.0	69.3	80.5	81.4	85.4	82.2	73.0	61.0	50.5	48.3	(28)	
	2%	WB	37.7	37.8	42.3	55.2	64.2	68.2	71.4	69.1	62.6	54.6	46.7	42.2	(29)	
		MCDB	38.5	39.1	48.1	64.0	73.5	77.7	81.9	77.6	69.3	57.3	47.8	43.4	(30)	
	5%	WB	35.6	36.3	39.8	52.3	61.2	65.7	69.5	66.8	60.3	52.6	44.8	40.0	(31)	
		MCDB	36.3	37.5	43.1	60.7	69.3	74.0	79.1	75.2	65.6	55.1	45.9	41.0	(32)	
	10%	WB	34.1	34.7	37.8	49.2	58.5	63.6	67.4	64.8	58.3	50.6	42.8	37.5	(33)	
		MCDB	35.0	35.9	40.6	56.7	66.5	70.9	75.7	72.8	62.8	52.7	43.8	38.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	11.4	13.8	18.0	19.6	18.2	18.1	18.4	16.0	11.4	7.4	7.5	(35)	
		MCDBR	6.8	8.5	18.1	26.9	26.3	23.6	23.5	24.1	21.8	13.9	9.1	7.2	(36)	
		MCWBR	6.6	7.3	12.3	15.5	13.9	12.1	11.0	11.9	12.7	10.2	8.2	6.6	(37)	
	5% WB	MCDBR	6.4	8.2	15.2	24.0	22.6	20.3	21.2	20.8	19.0	13.1	8.1	6.8	(38)	
		MCWBR	6.3	7.5	11.3	14.6	13.2	11.4	11.0	11.6	11.9	10.2	7.8	6.5	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.280	0.313	0.341	0.383	0.375	0.372	0.398	0.398	0.366	0.341	0.320	0.274	(40)	
	taud		2.122	2.118	2.163	2.267	2.366	2.402	2.348	2.344	2.410	2.383	2.221	2.123	(41)	
	Ebn at Noon		175	222	252	261	272	275	264	254	245	216	159	139	(42)	
	Edh at Noon		17	27	34	36	35	34	36	33	27	21	16	12	(43)	
(44) All-Sky Solar Radiation	RadAvg		128	359	799	1242	1665	1740	1676	1330	839	367	121	73	(44)	
	RadStd		28	65	118	158	172	139	175	120	92	62	17	17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.04	N/A	N/A	N/A	N/A	N/A	-394	-430	N/A	N/A
Regional (21 neighbors)		+0.76	N/A	N/A	N/A	N/A	N/A	-310	-304	N/A	N/A

Nomenclature: See separate page