

PSKOV, Russian Federation

WMO: 262580

Lat: 57.817N

Lon: 28.333E

Elev: 44

StdP: 100.80

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-23.1	-19.2	-25.3	0.4	-22.8	-21.6	0.5	-18.9	8.4	-1.7	7.5	-1.0	1.1	100	0.544

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	28.9	20.4	27.0	19.2	25.1	18.3	21.4	26.9	20.3	25.3	19.2	23.8	2.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.2	24.2	18.3	13.2	22.8	17.2	12.4	21.6	62.5	27.1	58.4	25.4	54.7	23.7	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.7	5.9	DB	-26.0	31.3	4.5	1.7	-29.3	32.6	-31.9	33.6	-34.4	34.5	-37.6	35.8	(4)
(5)			WB	-26.2	23.4	4.4	1.6	-29.4	24.5	-32.0	25.5	-34.4	26.4	-37.7	27.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.3	-5.4	-5.5	-0.8	6.5	12.0	15.9	18.7	17.0	12.0	5.9	1.2	-2.8	(6)	
	DBStd	9.64	6.53	6.89	4.70	4.19	4.39	3.46	3.26	3.03	3.33	3.98	4.30	5.82	(7)	
	HDD10.0	2210	476	433	336	122	29	2	0	0	18	135	263	397	(8)	
	HDD18.3	4484	734	666	594	356	203	89	36	62	192	384	513	656	(9)	
	CDD10.0	859	0	0	0	16	90	179	271	218	77	9	0	0	(10)	
	CDD18.3	91	0	0	0	0	6	16	47	22	1	0	0	0	(11)	
	CDH23.3	832	0	0	0	3	66	149	407	198	9	0	0	0	(12)	
	CDH26.7	184	0	0	0	0	13	26	107	38	1	0	0	0	(13)	
(14) Wind	WSAvg	2.6	2.8	2.7	2.9	2.8	2.6	2.5	2.1	2.1	2.3	2.6	2.9	3.1	(14)	
(15) Precipitation	PrecAvg	629	38	30	32	37	50	77	77	76	66	54	53	43	(15)	
	PrecMax	898	84	58	65	85	102	192	172	200	134	101	96	81	(16)	
	PrecMin	433	9	9	8	2	8	11	14	27	17	14	0	0	(17)	
	PrecStd	101	18	12	14	21	24	40	44	40	32	22	21	17	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.5	6.1	13.9	23.2	28.2	29.5	32.0	30.0	24.8	17.1	10.7	9.1	(19)	
		MCWB	5.7	4.3	7.9	13.9	18.7	20.3	22.5	21.3	17.8	13.1	9.2	7.9	(20)	
	2%	DB	4.0	4.5	9.8	19.9	25.0	27.0	29.4	27.5	21.8	14.3	9.0	6.7	(21)	
		MCWB	3.2	3.1	5.6	12.0	16.6	18.8	20.9	19.5	16.6	11.9	8.0	5.7	(22)	
	5%	DB	2.7	3.2	6.9	16.9	22.6	25.0	27.5	25.5	19.6	13.0	8.0	5.1	(23)	
		MCWB	2.0	2.2	3.9	10.5	15.2	17.9	20.1	18.5	15.0	11.2	7.0	4.5	(24)	
	10%	DB	1.8	2.2	5.1	14.2	20.2	22.9	25.6	23.6	17.8	11.7	6.8	3.8	(25)	
		MCWB	1.2	1.4	3.1	9.0	13.8	16.6	19.1	17.6	14.1	10.2	6.1	3.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	4.7	8.4	15.4	20.5	21.7	23.4	22.6	18.4	14.0	9.6	8.0	(27)	
		MCDB	6.3	5.6	12.8	20.7	26.9	27.5	29.7	27.9	22.8	16.1	10.3	9.1	(28)	
	2%	WB	3.2	3.2	5.7	12.9	17.9	20.1	21.9	20.6	17.0	12.6	8.1	5.7	(29)	
		MCDB	3.6	4.0	8.9	17.8	23.1	25.4	27.7	25.3	20.7	14.0	8.8	6.3	(30)	
	5%	WB	2.0	2.4	4.3	11.3	16.2	18.7	20.8	19.3	15.7	11.4	7.1	4.4	(31)	
		MCDB	2.4	3.1	6.2	15.9	20.7	23.3	26.2	24.0	18.6	12.9	7.7	5.0	(32)	
	10%	WB	1.2	1.5	3.2	9.6	14.7	17.5	19.7	18.2	14.6	10.3	6.0	3.0	(33)	
		MCDB	1.6	2.1	4.8	13.7	19.1	21.6	24.3	22.7	17.1	11.5	6.6	3.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	6.3	7.7	10.0	10.9	10.1	10.0	10.2	8.9	6.3	4.1	4.1	(35)	
		MCDBR	3.8	4.7	10.0	15.0	14.6	13.1	13.1	13.4	12.1	7.7	5.1	4.0	(36)	
	5% WB	MCWBR	3.7	4.1	6.9	8.6	7.7	6.7	6.1	6.6	7.0	5.6	4.6	3.7	(37)	
		MCWBR	3.6	4.6	8.4	13.3	12.5	11.3	11.8	11.6	10.6	7.3	4.5	3.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.280	0.313	0.341	0.383	0.375	0.372	0.398	0.398	0.366	0.341	0.320	0.274	(40)	
		taud	2.122	2.118	2.163	2.267	2.366	2.402	2.348	2.344	2.410	2.383	2.221	2.123	(41)	
	Edn at Noon		551	701	794	824	859	866	831	802	773	682	501	439	(42)	
		Edh at Noon	53	84	107	114	110	108	112	105	85	66	50	39	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.40	1.13	2.52	3.92	5.25	5.49	5.28	4.19	2.65	1.16	0.38	0.23	(44)	
	RadStd		0.09	0.21	0.37	0.50	0.54	0.44	0.55	0.38	0.29	0.20	0.05	0.05	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.58	N/A	N/A	N/A	N/A	N/A	-219	-239	N/A	N/A	(46)
(47)	Regional (21 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	-172	-169	N/A	N/A	(47)

Nomenclature: See separate page