

KOLKA, Latvia

WMO: 263130

Lat: 57.7467N

Lon: 22.5891E

Elev: 18

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.2	13.5	3.3	6.5	10.4	8.0	8.3	15.4	23.9	27.7	21.4	26.5	7.3	230	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	75.8	67.3	73.3	65.9	71.0	64.3	69.1	74.2	67.1	71.9	65.3	69.8	6.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.0	99.3	72.5	65.0	92.7	70.7	63.2	86.8	68.6	33.2	74.3	31.6	71.9	30.2	69.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.7	18.1	16.0	4.3	80.5	8.5	3.6	-1.8	83.1	-6.7	85.2	-11.5	87.2	-17.6	89.9
			3.4	70.2	8.2	2.5	-2.5	72.0	-7.4	73.4	-12.0	74.8	-18.0	76.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.7	29.7	28.3	32.1	39.9	48.8	56.9	63.0	62.3	55.5	46.5	38.9	33.4	
	DBStd	13.54	7.43	8.61	6.62	5.42	6.03	4.75	4.70	4.22	4.75	5.53	5.82	7.12	
	HDD50	3189	629	609	554	306	95	4	0	0	10	135	333	514	
	HDD65	7465	1094	1029	1019	752	502	245	97	106	286	574	782	979	
	CDD50	1258	0	0	0	4	58	212	402	381	175	26	0	0	
	CDD65	60	0	0	0	0	0	3	34	22	1	0	0	0	
	CDH74	168	0	0	0	0	0	9	115	43	1	0	0	0	
	CDH80	7	0	0	0	0	0	1	3	3	0	0	0	0	
Wind	WSAvg	8.0	9.6	8.9	8.1	7.3	7.0	7.1	6.8	6.8	7.7	8.6	9.2	9.4	
Precipitation	PrecAvg	25.7	1.9	1.5	1.4	1.3	1.5	2.6	3.0	3.2	2.2	2.6	2.3	2.0	
	PrecMax	34.7	3.7	2.8	2.4	2.8	2.8	5.2	6.7	8.4	4.4	4.8	4.1	4.0	
	PrecMin	18.0	0.4	0.2	0.3	0.3	0.4	0.5	0.1	0.4	0.3	0.3	0.2	0.8	
	PrecStd	4.2	0.9	0.6	0.7	0.7	0.7	1.0	1.6	1.9	1.0	1.1	1.1	0.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.3	46.2	50.3	61.4	70.5	74.4	79.9	78.1	71.0	60.5	52.8	49.3	
		MCWB	43.1	42.2	43.2	51.0	59.3	63.4	69.3	67.4	62.1	56.4	49.6	46.9	
	2%	DB	42.3	42.7	45.0	55.6	65.5	70.8	77.3	74.6	67.6	58.1	50.2	46.4	
		MCWB	40.6	39.8	40.7	48.0	57.3	61.7	68.7	66.7	60.9	54.6	48.0	44.4	
	5%	DB	40.3	40.6	42.6	51.9	61.9	68.3	74.6	72.3	65.1	56.2	48.4	44.2	
		MCWB	38.7	38.5	39.3	46.0	55.2	60.7	67.0	65.5	59.8	53.3	46.3	42.3	
	10%	DB	38.5	38.6	40.5	48.6	58.9	65.8	72.1	70.2	63.0	54.5	46.8	42.3	
		MCWB	37.0	36.9	37.9	43.7	52.8	59.1	65.8	64.2	58.5	51.9	45.0	40.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.6	42.9	44.0	52.4	61.9	66.5	72.3	70.7	63.9	57.2	50.2	47.3
			MCDB	44.9	45.8	48.3	58.9	67.3	71.6	77.4	75.2	67.9	59.3	52.0	48.7
2%		WB	40.8	40.4	41.2	48.6	58.6	63.6	70.0	68.2	62.2	55.2	48.3	44.7	
		MCDB	41.9	42.2	44.1	54.2	63.8	68.7	75.3	72.7	66.3	57.5	50.0	46.1	
5%		WB	38.9	38.7	39.5	46.4	55.9	61.6	68.2	66.5	60.6	53.7	46.7	42.6	
		MCDB	40.1	40.3	42.0	50.9	61.3	66.5	73.4	71.0	64.2	55.7	48.2	44.0	
10%		WB	37.2	36.9	37.9	44.0	53.4	59.7	66.4	64.8	59.2	52.2	45.2	40.7	
		MCDB	38.4	38.5	40.1	47.8	58.0	64.3	71.2	69.2	62.3	54.2	46.6	42.1	
Mean Daily Temperature Range		5% DB	MDBR	6.2	7.4	9.1	11.3	12.8	12.0	11.9	11.9	10.3	8.2	6.1	6.1
			MCDBR	6.8	8.0	11.6	17.8	17.3	16.6	14.9	14.8	13.4	9.9	7.3	6.0
	MCWBR		6.4	6.5	8.3	11.1	10.1	9.4	8.1	8.7	7.5	6.6	5.7	5.7	
	5% WB	MCDBR	6.6	7.8	10.8	16.1	15.4	14.0	13.2	13.1	12.4	9.1	6.9	6.2	
		MCWBR	6.4	6.8	8.4	10.9	9.6	9.0	7.9	8.4	8.7	7.6	6.6	5.9	
Clear-Sky Solar Irradiance	taub	0.295	0.319	0.342	0.377	0.371	0.370	0.400	0.394	0.362	0.344	0.331	0.292		
	taud	2.202	2.221	2.260	2.304	2.407	2.448	2.385	2.399	2.466	2.410	2.251	2.176		
	Ebn at Noon	174	224	254	264	274	276	263	256	248	217	157	136		
	Edh at Noon	16	24	31	35	34	33	34	32	26	21	16	12		
All-Sky Solar Radiation	RadAvg	110	309	780	1282	1779	1870	1761	1388	892	416	126	73		
	RadStd	22	56	99	148	155	109	140	122	108	53	23	9		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page