

STENDE, Latvia

WMO: 263180

Lat: 57.1833N

Lon: 22.5508E

Elev: 266

StdP: 14.56

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.1	7.2	-2.7	4.8	3.8	1.7	6.1	8.4	22.3	22.2	19.7	22.1	4.0	140	0.574

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.7	80.9	66.4	77.8	65.0	74.8	63.4	68.8	76.6	66.8	74.9	65.0	72.8	7.9	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.1	97.1	73.1	63.7	89.3	70.5	61.9	83.6	68.5	33.1	76.1	31.5	74.8	30.1	72.8	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.9	15.8	14.1	DB	-4.8	86.1	7.0	2.6	-9.8	88.0	-13.9	89.5	-17.8	91.0	-22.8	92.9	
			WB	-5.8	72.9	6.1	1.4	-10.1	73.9	-13.7	74.7	-17.1	75.5	-21.5	76.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.1	25.2	27.5	32.5	42.7	51.9	58.9	63.2	61.7	53.9	43.6	36.5	30.3
	DBStd	15.07	9.24	9.67	7.69	7.18	8.05	6.44	5.66	5.25	5.64	6.62	7.42	8.76
	HDD50	3516	768	631	542	238	70	6	0	0	27	216	406	612
	HDD65	7739	1233	1051	1006	668	413	205	105	131	333	662	855	1077
	CDD50	1354	0	0	0	20	129	271	408	362	145	19	0	0
	CDD65	104	0	0	0	0	6	21	48	28	1	0	0	0
	CDH74	800	0	0	0	0	54	172	363	206	5	0	0	0
	CDH80	116	0	0	0	0	4	24	61	27	0	0	0	0
Wind	WSAvg	7.0	7.8	8.0	7.7	7.3	6.5	6.1	5.7	5.7	6.3	7.1	7.6	7.8
Precipitation	PrecAvg	27.9	2.1	1.5	1.5	1.4	1.9	2.9	3.2	3.3	2.6	2.9	2.3	2.2
	PrecMax	36.7	4.6	2.9	2.8	3.3	3.5	5.0	6.6	7.9	5.2	5.6	4.1	4.1
	PrecMin	20.4	0.6	0.1	0.3	0.4	0.7	1.2	0.3	0.1	1.3	0.3	0.2	1.2
	PrecStd	3.7	1.0	0.7	0.8	0.8	0.8	1.1	1.7	1.7	1.0	1.1	1.0	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.2	44.5	54.4	69.4	79.5	83.0	85.1	83.4	72.9	62.4	52.3	47.8
		MCWB	42.1	40.5	45.5	53.9	63.5	67.6	68.8	67.9	61.5	55.3	49.0	46.1
	2%	DB	40.3	41.3	49.1	64.5	74.8	78.7	81.6	78.8	69.0	58.1	49.7	45.2
		MCWB	38.9	38.5	42.5	51.7	60.7	64.2	67.1	65.4	59.2	54.3	47.4	43.5
	5%	DB	38.1	39.3	44.9	59.8	71.0	75.0	78.3	76.1	66.1	55.2	47.3	42.7
		MCWB	37.0	37.6	40.2	49.1	58.8	63.2	66.2	64.1	58.6	52.2	45.5	41.2
	10%	DB	36.3	37.7	41.9	55.4	67.0	71.5	74.5	72.8	63.3	53.3	45.7	40.8
		MCWB	35.3	36.1	38.5	46.7	56.3	61.1	64.7	62.7	57.1	50.7	44.3	39.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	40.9	46.9	55.4	65.3	70.9	71.7	71.4	63.5	56.8	49.9	46.5
		MCDB	42.9	43.7	52.7	64.0	75.9	79.3	79.8	79.3	70.3	60.1	51.4	47.3
	2%	WB	39.3	39.1	43.2	52.5	62.8	66.7	69.2	68.2	61.2	54.6	47.5	43.7
		MCDB	40.0	40.7	47.7	62.3	72.9	75.9	76.9	76.2	66.1	57.6	49.2	44.8
	5%	WB	37.1	37.8	40.8	50.0	60.0	64.5	67.4	65.5	59.5	53.0	45.8	41.4
		MCDB	37.8	39.2	43.9	58.7	68.0	72.4	74.9	72.7	64.0	55.1	47.1	42.4
	10%	WB	35.4	36.3	38.8	47.4	57.6	62.2	65.7	63.8	58.1	51.1	44.3	39.6
		MCDB	36.3	37.6	41.7	54.3	66.6	69.7	73.9	70.7	62.4	53.1	45.7	40.7
Mean Daily Temperature Range	5% DB	MDBR	7.6	8.1	11.4	16.6	18.9	17.4	16.7	16.9	14.0	10.7	6.3	6.5
		MCDBR	6.3	8.0	14.9	24.1	23.2	22.5	21.3	21.5	18.6	12.8	7.5	6.9
		MCWBR	6.1	6.0	9.7	13.5	12.0	11.3	9.5	9.9	10.7	9.1	6.6	6.7
	5% WB	MCDBR	6.3	8.1	13.6	21.5	20.3	19.0	18.4	18.3	15.1	11.2	7.5	6.7
		MCWBR	6.3	6.6	9.8	12.7	11.4	10.6	9.2	9.9	9.5	8.6	7.0	6.5
Clear-Sky Solar Irradiance	taub	0.290	0.317	0.343	0.377	0.371	0.369	0.399	0.393	0.361	0.342	0.327	0.288	
	taud	2.197	2.216	2.264	2.297	2.377	2.414	2.351	2.370	2.440	2.410	2.265	2.180	
	Ebn at Noon	181	228	255	265	275	276	264	257	249	220	165	145	
	Edh at Noon	17	25	31	35	35	34	36	33	26	21	16	13	
All-Sky Solar Radiation	RadAvg	127	336	787	1277	1749	1830	1728	1371	903	431	138	82	
	RadStd	27	63	111	156	152	115	140	126	108	59	23	10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page