

MERSRAGS, Latvia

WMO: 263240

Lat: 57.3333N

Lon: 23.1131E

Elev: 19

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.6	9.4	-1.7	5.0	3.5	4.0	6.8	11.7	20.3	36.7	18.6	34.4	3.0	260	0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.2	78.4	67.1	75.4	65.7	72.8	64.5	69.2	75.4	67.3	73.6	65.5	71.6	6.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.8	98.8	73.4	64.7	91.7	71.3	62.8	85.5	69.4	33.3	75.6	31.8	73.4	30.4	71.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	15.0	13.3	DB	-3.7	84.4	9.7	3.3	-10.7	86.7	-16.3	88.7	-21.8	90.6	-28.9	93.0	(4)
(5)			WB	-4.1	72.4	9.6	4.2	-11.0	75.4	-16.6	77.9	-22.0	80.3	-29.0	83.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.2	27.5	27.1	32.3	41.6	49.9	58.0	63.0	61.5	54.0	44.9	37.8	31.4
	DBStd	14.34	8.09	10.51	7.08	6.79	7.06	5.81	5.08	4.67	5.35	6.10	6.57	8.18
	HDD50	3393	697	640	549	266	88	5	0	0	24	180	367	577
	HDD65	7671	1162	1060	1014	703	469	222	101	130	329	623	816	1042
	CDD50	1268	0	0	0	13	85	244	402	356	145	22	1	0
	CDD65	74	0	0	0	0	2	12	39	21	0	0	0	0
	CDH74	428	0	0	0	2	21	77	222	104	2	0	0	0
	CDH80	57	0	0	0	0	2	12	34	9	0	0	0	0
Wind	WSAvg	6.4	7.0	7.0	7.0	6.3	6.2	6.1	5.7	5.4	5.9	6.4	6.5	6.9
Precipitation	PrecAvg	25.6	1.9	1.4	1.3	1.4	1.8	2.7	3.2	3.1	2.2	2.8	2.2	1.9
	PrecMax	35.9	3.8	2.4	2.8	3.0	3.6	6.2	5.6	7.7	4.0	5.3	3.7	4.1
	PrecMin	18.6	0.5	0.1	0.3	0.2	0.5	0.5	0.3	0.1	1.0	0.3	0.2	0.9
	PrecStd	4.2	0.9	0.6	0.7	0.8	0.9	1.3	1.5	1.7	0.8	1.1	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.3	45.9	53.6	69.9	76.9	81.8	84.0	81.2	72.6	62.3	53.1	49.2
		MCWB	42.5	41.4	44.5	53.9	63.1	66.0	69.9	66.4	61.9	56.4	49.9	46.3
	2%	DB	41.3	42.8	47.8	61.8	70.2	75.5	79.1	76.7	68.1	58.9	50.3	46.3
		MCWB	39.4	39.5	41.7	51.8	59.3	64.4	69.3	66.4	60.4	54.7	47.8	44.2
	5%	DB	39.2	40.6	44.3	57.3	66.3	71.8	76.0	73.8	65.6	56.1	48.2	43.8
		MCWB	37.5	38.3	40.0	49.2	57.3	62.5	67.1	65.2	59.1	52.7	46.3	42.1
	10%	DB	37.4	38.9	41.5	53.0	62.5	69.0	73.3	71.4	63.1	54.0	46.5	41.5
		MCWB	36.0	37.0	38.0	46.3	55.1	60.8	65.8	64.1	57.6	50.9	44.8	39.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.2	42.2	45.9	56.2	64.3	68.3	72.5	71.4	63.9	57.3	50.5	47.2
		MCDB	44.2	44.7	50.9	65.3	76.0	76.4	80.4	76.6	68.6	60.9	52.2	48.6
	2%	WB	39.7	40.3	42.6	52.5	60.9	65.7	70.1	68.1	61.8	55.1	48.2	44.5
		MCDB	40.8	42.4	46.7	60.9	67.7	73.2	76.7	74.0	66.2	57.8	50.1	45.7
	5%	WB	37.8	38.7	40.4	49.6	58.4	63.7	68.3	66.2	60.0	53.4	46.5	42.2
		MCDB	38.9	40.2	43.7	56.0	65.1	70.5	74.6	72.2	64.3	55.9	47.9	43.6
	10%	WB	36.2	37.1	38.4	47.0	55.7	61.8	66.6	64.5	58.3	51.3	44.9	40.1
		MCDB	37.3	38.8	41.2	52.2	61.6	67.9	72.6	70.3	62.4	53.6	46.3	41.4
Mean Daily Temperature Range	5% DB	MDBR	7.3	9.3	11.0	14.6	16.2	15.3	15.2	16.0	13.4	10.5	7.0	6.7
		MCDBR	6.0	8.6	14.4	23.3	22.0	20.5	19.3	19.6	17.1	11.9	8.5	7.3
		MCWBR	5.7	6.6	9.7	13.4	12.5	10.9	10.4	11.5	10.8	8.5	7.2	7.0
	5% WB	MCDBR	6.0	8.4	13.2	20.7	19.2	18.2	17.0	17.4	15.7	11.0	8.1	7.1
		MCWBR	5.9	7.0	9.8	12.8	11.8	10.6	10.2	11.4	10.8	8.7	7.3	7.0
Clear-Sky Solar Irradiance	taub	0.295	0.320	0.346	0.381	0.375	0.373	0.404	0.398	0.366	0.346	0.333	0.293	
	taud	2.202	2.206	2.228	2.284	2.388	2.431	2.365	2.382	2.449	2.411	2.260	2.188	
	Ebn at Noon	177	226	253	263	273	275	262	255	247	218	161	141	
	Edh at Noon	16	25	32	36	34	33	35	32	26	21	16	13	
All-Sky Solar Radiation	RadAvg	121	328	786	1280	1760	1844	1742	1378	900	427	134	79	
	RadStd	25	61	109	153	152	113	140	124	109	57	23	10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page