

MERSRAGS, Latvia

WMO: 263240

Lat: 57.3333N

Lon: 23.1131E

Elev: 6

StdP: 101.26

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.4	-12.5	-18.7	0.7	-15.9	-15.6	1.0	-11.3	9.1	2.6	8.3	1.3	1.4	260	0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	25.8	19.5	24.1	18.7	22.7	18.0	20.7	24.1	19.6	23.1	18.6	22.0	3.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.1	23.0	18.2	13.1	21.8	17.1	12.2	20.8	59.6	24.2	56.0	23.0	52.7	22.0	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.7	5.9	DB	-19.8	29.1	5.4	1.8	-23.7	30.4	-26.9	31.5	-29.9	32.5	-33.8	33.9	(4)
(5)			WB	-20.0	22.4	5.3	2.4	-23.9	24.1	-27.0	25.5	-30.0	26.8	-33.9	28.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.8	-2.5	-2.7	0.2	5.3	10.0	14.4	17.2	16.4	12.2	7.2	3.2	-0.3
	DBStd	7.96	4.50	5.84	3.94	3.77	3.92	3.23	2.82	2.60	2.97	3.39	3.65	4.54
	HDD10.0	1885	387	356	305	148	49	3	0	0	13	100	204	321
	HDD18.3	4262	646	589	563	391	261	123	56	72	183	346	453	579
	CDD10.0	704	0	0	0	7	47	136	223	198	81	12	1	0
	CDD18.3	41	0	0	0	0	1	7	22	12	0	0	0	0
	CDH23.3	238	0	0	0	1	12	43	123	58	1	0	0	0
	CDH26.7	32	0	0	0	0	1	7	19	5	0	0	0	0
Wind	WSAvg	2.8	3.1	3.1	3.1	2.8	2.8	2.7	2.5	2.4	2.7	2.9	2.9	3.1
Precipitation	PrecAvg	651	47	35	34	36	46	69	82	79	55	70	56	48
	PrecMax	911	96	61	72	76	91	157	141	196	101	134	95	103
	PrecMin	472	12	3	7	4	12	13	8	2	25	8	6	22
	PrecStd	107	23	15	18	20	22	33	39	43	21	28	24	18
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	7.7	12.0	21.1	24.9	27.7	28.9	27.3	22.6	16.8	11.7	9.6
		MCWB	5.8	5.2	6.9	12.2	17.3	18.9	21.1	19.1	16.6	13.6	9.9	8.0
	2%	DB	5.1	6.0	8.8	16.6	21.2	24.2	26.2	24.9	20.1	14.9	10.2	7.9
		MCWB	4.1	4.2	5.4	11.0	15.2	18.0	20.7	19.1	15.8	12.6	8.8	6.8
	5%	DB	4.0	4.8	6.8	14.0	19.0	22.1	24.5	23.2	18.6	13.4	9.0	6.5
		MCWB	3.0	3.5	4.4	9.5	14.1	17.0	19.5	18.4	15.1	11.5	8.0	5.6
	10%	DB	3.0	3.8	5.3	11.7	16.9	20.5	23.0	21.9	17.3	12.2	8.0	5.3
		MCWB	2.2	2.8	3.3	8.0	12.8	16.0	18.8	17.8	14.2	10.5	7.1	4.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.2	5.7	7.7	13.4	17.9	20.2	22.5	21.9	17.7	14.1	10.3	8.4
		MCDB	6.8	7.0	10.5	18.5	24.5	24.6	26.9	24.8	20.3	16.0	11.2	9.2
	2%	WB	4.3	4.6	5.9	11.4	16.1	18.7	21.2	20.1	16.6	12.8	9.0	6.9
		MCDB	4.9	5.8	8.2	16.0	19.8	22.9	24.8	23.3	19.0	14.4	10.0	7.6
	5%	WB	3.2	3.7	4.7	9.8	14.7	17.6	20.2	19.0	15.6	11.9	8.1	5.7
		MCDB	3.8	4.6	6.5	13.4	18.4	21.4	23.7	22.3	17.9	13.3	8.9	6.4
	10%	WB	2.3	2.8	3.6	8.3	13.2	16.6	19.2	18.1	14.6	10.7	7.2	4.5
		MCDB	3.0	3.8	5.1	11.2	16.4	19.9	22.6	21.3	16.9	12.0	8.0	5.2
Mean Daily Temperature Range	5% DB	MDBR	4.0	5.2	6.1	8.1	9.0	8.5	8.4	8.9	7.4	5.8	3.9	3.7
		MCDBR	3.3	4.8	8.0	12.9	12.2	11.4	10.7	10.9	9.5	6.6	4.7	4.1
		MCWBR	3.1	3.6	5.4	7.4	7.0	6.1	5.8	6.4	6.0	4.7	4.0	3.9
	5% WB	MCDBR	3.3	4.6	7.3	11.5	10.7	10.1	9.5	9.6	8.7	6.1	4.5	3.9
		MCWBR	3.3	3.9	5.5	7.1	6.5	5.9	5.7	6.4	6.0	4.9	4.0	3.9
Clear-Sky Solar Irradiance	taub	0.295	0.320	0.346	0.381	0.375	0.373	0.404	0.398	0.366	0.346	0.333	0.293	
	taud	2.202	2.206	2.228	2.284	2.388	2.431	2.365	2.382	2.449	2.411	2.260	2.188	
	Ebn at Noon	559	711	798	828	862	867	827	805	780	688	507	446	
	Edh at Noon	52	79	101	113	108	105	110	102	83	66	50	40	
All-Sky Solar Radiation	RadAvg	0.38	1.03	2.48	4.04	5.55	5.81	5.49	4.34	2.84	1.35	0.42	0.25	
	RadStd	0.08	0.19	0.34	0.48	0.48	0.36	0.44	0.39	0.34	0.18	0.07	0.03	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page