

PRIEKULI, Latvia

WMO: 263350

Lat: 57.3156N

Lon: 25.3379E

Elev: 404

StdP: 14.48

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	2.5	-9.4	3.4	-3.2	-2.9	4.8	5.4	22.4	33.7	20.5	31.2	3.5	50	0.575

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.1	81.9	67.0	78.9	64.9	76.0	63.8	69.4	78.6	67.0	75.1	65.2	73.3	7.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.1	97.7	73.7	63.9	90.3	71.3	62.0	84.2	69.4	33.7	79.0	31.7	75.0	30.3	73.1	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.2	17.1	15.5	DB -9.9	86.2	6.5	2.9	-14.6	88.3	-18.4	90.0	-22.1	91.6	-26.9	93.7		
(5)			WB -10.3	71.8	6.5	1.8	-15.0	73.1	-18.8	74.1	-22.4	75.2	-27.1	76.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.7	23.1	25.4	32.1	43.3	52.7	60.6	64.2	62.5	53.6	43.1	36.2	26.3		
	DBStd	16.45	10.04	10.71	7.83	7.98	8.34	6.70	6.16	5.46	6.15	6.83	7.81	9.37		
	HDD50	3791	834	689	555	230	65	3	0	0	35	230	415	735		
	HDD65	7933	1299	1109	1020	651	391	167	90	117	345	679	865	1200		
	CDD50	1484	0	0	0	29	149	321	441	387	141	16	0	0		
	CDD65	152	0	0	0	0	10	35	66	39	2	0	0	0		
	CDH74	1055	0	0	0	1	67	238	467	276	6	0	0	0		
	CDH80	170	0	0	0	0	4	27	91	48	0	0	0	0		
(14) Wind	WSAvg	7.4	8.4	8.4	8.6	7.3	6.8	6.5	5.8	5.9	7.0	7.6	7.8	9.0		
(15) Precipitation	PrecAvg	29.1	2.3	1.7	1.6	1.6	2.4	3.0	3.3	3.3	2.2	3.1	2.4	2.2		
	PrecMax	37.1	4.9	3.1	3.3	4.4	4.6	5.2	6.9	6.7	3.7	5.6	4.2	3.7		
	PrecMin	19.9	0.7	0.5	0.4	0.3	0.5	0.7	0.2	0.0	0.3	0.4	0.3	1.1		
	PrecStd	4.4	1.0	0.7	0.9	0.9	1.1	1.3	1.8	1.8	0.8	1.1	1.1	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.4	43.0	55.4	70.4	79.8	83.1	85.8	85.1	74.6	62.2	51.5	44.0		
		MCWB	39.9	38.9	43.6	52.4	61.9	65.4	69.9	69.6	61.0	54.7	49.5	41.8		
	2%	DB	37.8	40.0	48.9	66.2	75.4	79.9	82.5	80.5	69.2	57.6	49.0	40.8		
		MCWB	36.5	37.0	41.8	50.7	60.8	64.4	68.0	66.8	58.6	53.7	47.1	39.0		
	5%	DB	36.1	37.8	44.7	61.4	70.9	76.7	79.4	77.0	66.0	54.7	47.0	39.0		
		MCWB	35.1	36.1	39.5	49.2	57.9	63.9	66.1	64.4	57.4	51.8	45.4	37.8		
	10%	DB	34.8	36.3	41.8	57.2	66.4	72.8	75.7	73.8	62.9	52.5	45.3	37.2		
		MCWB	33.9	34.9	38.0	46.8	56.0	62.3	64.8	62.5	56.4	49.9	44.0	36.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.5	39.3	46.3	54.5	64.7	70.0	72.1	72.2	63.3	56.7	50.0	42.2		
		MCDB	41.2	41.2	53.9	64.0	75.7	76.7	81.4	82.2	71.0	59.9	51.2	43.5		
	2%	WB	36.9	37.6	42.7	51.9	62.6	66.6	70.0	68.5	60.5	54.0	47.4	39.3		
		MCDB	37.4	39.2	46.6	63.5	71.5	75.5	79.8	77.3	65.9	56.5	48.5	40.3		
	5%	WB	35.3	36.3	40.3	49.7	60.1	64.7	68.0	65.9	58.7	52.2	45.6	37.9		
		MCDB	35.9	37.7	43.8	59.4	67.5	73.9	76.6	73.9	64.6	54.4	46.8	38.9		
	10%	WB	33.9	35.0	38.3	47.5	57.7	63.1	65.9	64.1	57.1	50.4	44.1	36.0		
		MCDB	34.6	36.2	41.3	56.3	65.5	71.6	73.0	72.2	61.7	52.3	45.2	37.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	8.2	10.4	15.2	16.3	15.0	15.1	15.4	12.0	9.0	5.7	5.9		
		MCDBR	5.9	7.6	13.6	21.4	21.2	19.7	19.0	20.0	16.9	10.4	6.9	6.0		
	5% WB	MCWBR	5.6	6.2	8.8	10.6	9.5	8.5	7.8	8.5	8.9	7.7	6.4	5.7		
		MCWBR	6.0	7.4	11.8	18.8	17.9	17.1	17.3	17.0	13.5	9.8	6.5	5.9		
(40) Clear-Sky Solar Irradiance	taub	taub	0.280	0.310	0.342	0.379	0.372	0.370	0.400	0.397	0.362	0.339	0.321	0.278		
		taud	2.152	2.155	2.195	2.275	2.366	2.397	2.333	2.341	2.416	2.402	2.243	2.156		
	Ebn at Noon	Ebn at Noon	181	228	254	263	274	276	264	256	248	220	165	146		
		Edh at Noon	17	26	33	36	35	35	36	34	27	21	16	13		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	135	358	795	1269	1703	1779	1701	1345	874	411	133	84		
	RadStd	RadStd	32	70	115	140	165	133	147	130	91	62	19	12		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page