

PRIEKULI, Latvia

WMO: 263350

Lat: 57.3156N

Lon: 25.3379E

Elev: 123

StdP: 99.86

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.1	-16.4	-23.0	0.5	-19.5	-19.4	0.7	-14.8	10.0	0.9	9.2	-0.5	1.6	50	0.575

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	27.7	19.5	26.0	18.3	24.4	17.7	20.8	25.9	19.4	24.0	18.4	22.9	3.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	14.0	23.2	17.7	12.9	21.8	16.6	12.0	20.8	60.5	26.1	55.9	23.9	52.6	22.9	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.6	7.7	6.9	DB	-23.3	30.1	3.6	1.6	-25.9	31.3	-28.0	32.2	-30.1	33.1	-32.7	34.3	(4)
(5)			WB	-23.5	22.1	3.6	1.0	-26.1	22.8	-28.2	23.4	-30.2	24.0	-32.8	24.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.5	-5.0	-3.7	0.1	6.3	11.5	15.9	17.9	16.9	12.0	6.2	2.3	-3.2
	DBStd	9.14	5.58	5.95	4.35	4.43	4.63	3.72	3.42	3.03	3.42	3.79	4.34	5.21
	HDD10.0	2106	463	383	308	128	36	2	0	0	19	128	231	408
	HDD18.3	4407	722	616	567	362	217	93	50	65	192	377	481	667
	CDD10.0	824	0	0	0	16	83	178	245	215	78	9	0	0
	CDD18.3	84	0	0	0	0	6	19	37	22	1	0	0	0
	CDH23.3	586	0	0	0	1	37	132	259	153	3	0	0	0
	CDH26.7	94	0	0	0	0	2	15	51	27	0	0	0	0
Wind	WSAvg	3.3	3.8	3.8	3.9	3.3	3.0	2.9	2.6	2.6	3.1	3.4	3.5	4.0
Precipitation	PrecAvg	740	59	43	41	40	61	76	84	85	56	78	62	56
	PrecMax	943	125	79	83	113	116	131	176	171	93	141	107	94
	PrecMin	505	17	12	11	8	13	17	4	1	8	9	8	28
	PrecStd	111	26	18	22	23	27	34	46	46	21	29	27	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.2	6.1	13.0	21.3	26.6	28.4	29.9	29.5	23.6	16.8	10.8	6.7
		MCWB	4.4	3.8	6.4	11.3	16.6	18.5	21.1	20.9	16.1	12.6	9.7	5.4
	2%	DB	3.2	4.4	9.4	19.0	24.1	26.6	28.1	26.9	20.7	14.2	9.5	4.9
		MCWB	2.5	2.8	5.4	10.4	16.0	18.0	20.0	19.3	14.8	12.1	8.4	3.9
	5%	DB	2.3	3.2	7.0	16.4	21.6	24.8	26.3	25.0	18.9	12.6	8.3	3.9
		MCWB	1.7	2.3	4.2	9.6	14.4	17.7	18.9	18.0	14.1	11.0	7.5	3.2
	10%	DB	1.5	2.4	5.4	14.0	19.1	22.7	24.3	23.2	17.2	11.4	7.4	2.9
		MCWB	1.0	1.6	3.3	8.2	13.3	16.8	18.2	16.9	13.6	9.9	6.6	2.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.7	4.0	7.9	12.5	18.2	21.1	22.3	22.3	17.4	13.7	10.0	5.6
		MCDB	5.1	5.1	12.2	17.8	24.3	24.8	27.4	27.9	21.6	15.5	10.7	6.4
	2%	WB	2.7	3.1	5.9	11.1	17.0	19.2	21.1	20.3	15.8	12.2	8.5	4.1
		MCDB	3.0	4.0	8.1	17.5	21.9	24.1	26.5	25.2	18.9	13.6	9.2	4.6
	5%	WB	1.8	2.4	4.6	9.8	15.6	18.2	20.0	18.8	14.8	11.2	7.6	3.3
		MCDB	2.2	3.2	6.6	15.2	19.7	23.3	24.8	23.3	18.1	12.5	8.2	3.8
	10%	WB	1.1	1.7	3.5	8.6	14.3	17.3	18.8	17.8	13.9	10.2	6.7	2.2
		MCDB	1.5	2.4	5.1	13.5	18.6	22.0	22.8	22.3	16.5	11.3	7.3	2.8
Mean Daily Temperature Range	5% DB	MDBR	4.0	4.5	5.8	8.5	9.0	8.4	8.4	8.5	6.7	5.0	3.2	3.3
		MCDBR	3.3	4.2	7.6	11.9	11.8	11.0	10.6	11.1	9.4	5.8	3.8	3.3
		MCWBR	3.1	3.4	4.9	5.9	5.3	4.7	4.3	4.7	4.9	4.3	3.6	3.2
	5% WB	MCDBR	3.3	4.1	6.6	10.5	9.9	9.5	9.6	9.5	7.5	5.4	3.6	3.3
		MCWBR	3.3	3.6	4.8	5.6	4.8	4.9	4.5	4.8	4.4	4.4	3.4	3.3
Clear-Sky Solar Irradiance	taub	0.280	0.310	0.342	0.379	0.372	0.370	0.400	0.397	0.362	0.339	0.321	0.278	
	taud	2.152	2.155	2.195	2.275	2.366	2.397	2.333	2.341	2.416	2.402	2.243	2.156	
	Ebn at Noon	572	718	800	830	864	870	831	806	782	695	519	461	
	Edh at Noon	54	83	104	114	111	109	114	106	85	66	51	41	
All-Sky Solar Radiation	RadAvg	0.42	1.13	2.51	4.00	5.37	5.61	5.36	4.24	2.75	1.29	0.42	0.27	
	RadStd	0.10	0.22	0.36	0.44	0.52	0.42	0.46	0.41	0.29	0.19	0.06	0.04	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page