

ZOSENI, Latvia

WMO: 263390

Lat: 57.1350N

Lon: 25.9056E

Elev: 620

StdP: 14.37

Time Zone: 2.00 (EUE)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.8	(c) -0.9	(d) -11.9	(e) 3.0	(f) -6.7	(g) -5.3	(h) 4.2	(i) 0.2	(j) 17.5	(k) 32.3	(l) 16.2	(m) 29.1	(n) 1.6	(o) 40	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	81.3	67.3	78.3	65.3	75.2	63.9	69.4	78.3	67.1	75.0	65.3	72.8	5.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.1	98.4	74.2	64.1	91.7	71.2	62.4	86.2	68.8	33.9	78.4	31.9	75.1	30.5	73.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.0	(b) 13.5	(c) 12.0	(e) -15.6	(f) 84.6	(g) 7.2	(h) 3.0	(i) -20.8	(j) 86.7	(k) -25.0	(l) 88.5	(m) -29.1	(n) 90.1	(o) -34.3	(p) 92.3		
(a) 15.0	(b) 13.5	(c) 12.0	(e) -15.8	(f) 72.2	(g) 7.4	(h) 2.0	(i) -21.2	(j) 73.6	(k) -25.5	(l) 74.7	(m) -29.7	(n) 75.8	(o) -35.1	(p) 77.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.4	21.0	22.8	30.3	41.7	52.0	58.9	63.4	60.3	52.5	41.1	34.9	28.1
	DBStd	16.40	11.31	11.56	8.45	7.31	7.85	6.32	5.57	5.41	5.41	6.93	7.43	8.80
	HDD50	4063	900	761	610	264	69	6	0	1	34	285	454	679
	HDD65	8356	1365	1181	1075	699	408	200	97	168	374	741	904	1144
	CDD50	1272	0	0	0	15	130	275	415	319	110	8	0	0
	CDD65	90	0	0	0	0	4	18	47	21	0	0	0	0
	CDH74	888	0	0	0	0	67	175	448	197	1	0	0	0
	CDH80	130	0	0	0	0	2	11	81	36	0	0	0	0
Wind	WSAvg	5.8	6.5	6.2	6.7	6.0	5.3	5.5	4.4	4.7	5.2	6.0	6.3	6.6
Precipitation	PrecAvg	28.2	2.3	1.8	1.6	1.5	2.4	3.1	3.2	3.1	2.1	3.0	2.3	2.2
	PrecMax	35.5	4.6	4.3	3.5	4.7	4.8	5.4	6.7	5.4	3.7	5.4	4.4	3.9
	PrecMin	18.3	0.7	0.6	0.4	0.2	0.3	0.8	0.3	0.2	0.7	0.4	0.2	1.3
	PrecStd	4.0	1.1	0.9	0.9	0.9	1.1	1.3	1.5	1.6	0.9	1.2	1.1	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.9	41.1	54.0	70.0	79.6	81.5	85.1	84.7	71.7	59.7	49.3	47.0
		MCWB	40.9	37.6	43.5	51.6	63.0	65.3	69.8	70.0	62.6	55.1	47.5	45.7
	2%	DB	37.9	37.9	48.3	65.3	75.7	78.7	82.4	79.7	67.8	56.2	46.9	42.8
		MCWB	37.0	35.9	40.6	50.4	60.9	64.3	68.2	67.4	59.0	53.2	45.4	41.5
	5%	DB	35.6	36.4	43.9	60.3	71.9	75.7	79.1	75.5	64.5	53.4	45.4	40.4
		MCWB	34.7	35.0	38.7	48.4	58.3	63.4	66.9	64.6	57.6	50.9	44.1	39.4
	10%	DB	34.1	34.9	40.7	55.5	67.3	72.0	75.6	72.0	62.0	51.4	43.9	38.4
		MCWB	33.4	33.9	37.2	45.5	55.3	61.1	65.3	62.7	56.6	49.1	42.8	37.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.0	38.4	45.3	54.4	65.6	68.7	72.0	73.2	63.6	56.7	47.9	45.5
		MCDB	41.6	39.9	52.1	66.4	76.1	76.9	82.0	82.4	69.8	59.3	48.6	46.2
	2%	WB	37.2	36.5	41.7	51.4	62.8	66.3	70.1	68.5	60.8	53.5	45.8	41.7
		MCDB	37.7	37.6	46.2	62.5	72.0	75.1	79.6	76.2	64.2	55.3	46.7	42.3
	5%	WB	35.0	35.2	39.4	49.2	59.9	64.5	68.1	65.8	59.1	51.6	44.3	39.5
		MCDB	35.4	36.2	43.1	58.1	68.3	73.6	76.2	73.1	63.8	53.3	45.2	40.3
	10%	WB	33.4	33.9	37.4	46.7	57.5	62.7	66.2	63.7	57.0	49.4	42.8	37.4
		MCDB	34.0	34.7	40.0	54.3	64.6	70.3	73.4	70.2	61.0	51.0	43.8	38.3
Mean Daily Temperature Range	5% DB	MDBR	8.4	9.9	12.2	17.5	20.8	17.8	17.6	17.4	13.6	10.3	6.0	5.8
		MCDBR	5.9	6.8	15.3	26.2	26.4	23.6	23.3	23.5	18.8	12.1	6.8	6.0
		MCWBR	5.7	5.5	9.8	13.8	12.8	11.0	11.0	11.9	11.3	9.2	6.2	5.9
	5% WB	MCDBR	5.9	6.3	13.1	23.3	21.6	20.2	20.8	20.1	16.5	10.3	6.7	5.9
		MCWBR	5.9	5.4	9.4	12.9	11.9	10.3	10.6	10.9	10.9	8.8	6.1	5.8
Clear-Sky Solar Irradiance	taub	0.277	0.308	0.340	0.379	0.371	0.368	0.398	0.395	0.361	0.337	0.318	0.275	
	taud	2.152	2.152	2.192	2.272	2.364	2.397	2.333	2.338	2.413	2.405	2.247	2.158	
	Ebn at Noon	185	229	255	264	275	277	265	256	249	222	168	150	
	Edh at Noon	17	26	33	36	35	35	36	34	27	21	16	13	
All-Sky Solar Radiation	RadAvg	143	371	808	1259	1688	1758	1675	1337	869	405	134	87	
	RadStd	33	72	116	148	167	138	157	130	93	63	20	15	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page