

ZOSENI, Latvia

WMO: 263390

Lat: 57.1350N

Lon: 25.9056E

Elev: 189

StdP: 99.08

Time Zone: 2.00 (EUE)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.1	-18.3	-24.4	0.4	-21.5	-20.7	0.6	-17.7	7.8	0.2	7.2	-1.6	0.7	40	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	27.4	19.6	25.7	18.5	24.0	17.7	20.8	25.7	19.5	23.9	18.5	22.7	2.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.9	14.1	23.4	17.8	13.1	21.8	16.9	12.3	20.4	60.9	25.8	56.4	24.0	53.0	22.8	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.7	6.0	5.4	-26.4	29.2	4.0	1.6	-29.3	30.4	-31.7	31.4	-33.9	32.3	-36.8	33.5		
(5)			-26.6	22.3	4.1	1.1	-29.5	23.1	-31.9	23.7	-34.3	24.3	-37.3	25.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.8	-6.1	-5.1	-0.9	5.4	11.1	15.0	17.4	15.7	11.4	5.0	1.6	-2.2
	DBStd	9.11	6.28	6.42	4.69	4.06	4.36	3.51	3.09	3.00	3.00	3.85	4.13	4.89
	HDD10.0	2257	500	423	339	147	38	3	0	1	19	158	252	377
	HDD18.3	4642	758	656	597	388	227	111	54	93	208	412	502	636
	CDD10.0	707	0	0	0	8	72	153	231	177	61	4	0	0
	CDD18.3	50	0	0	0	0	2	10	26	12	0	0	0	0
	CDH23.3	493	0	0	0	0	37	97	249	109	1	0	0	0
	CDH26.7	72	0	0	0	0	1	6	45	20	0	0	0	0
Wind	WSAvg	2.6	2.9	2.7	3.0	2.7	2.4	2.4	2.0	2.1	2.3	2.7	2.8	2.9
Precipitation	PrecAvg	716	58	45	41	39	60	78	81	78	54	75	59	56
	PrecMax	902	118	108	90	119	123	137	170	136	95	137	113	100
	PrecMin	464	18	14	9	4	8	20	8	4	19	9	5	32
	PrecStd	101	28	22	22	24	28	32	38	40	22	30	27	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.5	5.1	12.2	21.1	26.5	27.5	29.5	29.3	22.1	15.4	9.6	8.3
		MCWB	4.9	3.1	6.4	10.9	17.2	18.5	21.0	21.1	17.0	12.9	8.6	7.6
	2%	DB	3.3	3.3	9.1	18.5	24.3	25.9	28.0	26.5	19.9	13.5	8.3	6.0
		MCWB	2.8	2.2	4.8	10.2	16.0	17.9	20.1	19.7	15.0	11.8	7.4	5.3
	5%	DB	2.0	2.4	6.6	15.7	22.2	24.3	26.2	24.2	18.1	11.9	7.5	4.7
		MCWB	1.5	1.7	3.7	9.1	14.6	17.5	19.4	18.1	14.2	10.5	6.7	4.1
	10%	DB	1.1	1.6	4.8	13.0	19.6	22.2	24.2	22.2	16.7	10.8	6.6	3.6
		MCWB	0.8	1.1	2.9	7.5	13.0	16.2	18.5	17.0	13.7	9.5	6.0	3.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.0	3.6	7.4	12.5	18.7	20.4	22.2	22.9	17.5	13.7	8.8	7.5
		MCDB	5.3	4.4	11.2	19.1	24.5	24.9	27.8	28.0	21.0	15.1	9.2	7.9
	2%	WB	2.9	2.5	5.4	10.8	17.1	19.1	21.1	20.3	16.0	11.9	7.6	5.4
		MCDB	3.2	3.1	7.9	16.9	22.2	23.9	26.5	24.6	17.9	12.9	8.2	5.7
	5%	WB	1.6	1.8	4.1	9.5	15.5	18.1	20.1	18.8	15.1	10.9	6.8	4.2
		MCDB	1.9	2.3	6.2	14.5	20.2	23.1	24.6	22.8	17.7	11.8	7.3	4.6
	10%	WB	0.8	1.1	3.0	8.2	14.2	17.0	19.0	17.6	13.9	9.7	6.0	3.0
		MCDB	1.1	1.5	4.5	12.4	18.1	21.3	23.0	21.2	16.1	10.6	6.6	3.5
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.5	6.8	9.7	11.6	9.9	9.8	9.7	7.5	5.7	3.3	3.2
		MCDBR	3.3	3.8	8.5	14.5	14.7	13.1	13.0	13.1	10.5	6.7	3.8	3.3
		MCWBR	3.2	3.1	5.4	7.7	7.1	6.1	6.1	6.6	6.3	5.1	3.5	3.3
	5% WB	MCDBR	3.3	3.5	7.3	13.0	12.0	11.2	11.5	11.2	9.2	5.7	3.7	3.3
		MCWBR	3.3	3.0	5.2	7.2	6.6	5.7	5.9	6.1	6.0	4.9	3.4	3.2
Clear-Sky Solar Irradiance	taub	0.277	0.308	0.340	0.379	0.371	0.368	0.398	0.395	0.361	0.337	0.318	0.275	
	taud	2.152	2.152	2.192	2.272	2.364	2.397	2.333	2.338	2.413	2.405	2.247	2.158	
	Ebn at Noon	582	723	804	832	866	872	834	808	785	700	529	474	
	Edh at Noon	54	83	105	114	111	109	114	106	85	66	51	41	
All-Sky Solar Radiation	RadAvg	0.45	1.17	2.55	3.97	5.32	5.54	5.28	4.21	2.74	1.28	0.42	0.27	
	RadStd	0.10	0.23	0.37	0.47	0.53	0.44	0.49	0.41	0.29	0.20	0.06	0.05	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page