

ALUKSNE, Latvia

WMO: 263460

Lat: 57.4396N

Lon: 27.0353E

Elev: 655

StdP: 14.35

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.8	0.5	-9.8	3.3	-5.2	-4.1	4.5	1.5	17.5	31.7	16.0	31.0	3.1	100	0.558

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 14.9	(c) 79.9	(d) 66.0	(e) 76.9	(f) 64.0	(g) 74.1	(h) 62.8	(i) 68.4	(j) 76.3	(k) 66.4	(l) 73.4	(m) 64.5	(n) 71.6	(o) 5.4	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.5	96.6	72.3	63.6	90.1	70.3	61.7	84.3	68.2	33.1	77.0	31.3	73.5	29.9	71.4	
											</				

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.6	(b) 13.1	(c) 11.7	(e) -10.4	(f) 84.4	(g) 7.1	(h) 3.1	(i) -15.5	(j) 86.6	(k) -19.6	(l) 88.4	(m) -23.6	(n) 90.1	(o) -28.7	(p) 92.3		
(4) 14.6	(5) 13.1	(6) 11.7	(7) -10.8	(8) 70.8	(9) 6.9	(10) 1.8	(11) -15.8	(12) 72.1	(13) -19.9	(14) 73.1	(15) -23.7	(16) 74.2	(17) -28.8	(18) 75.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.4	21.7	22.5	29.9	41.8	52.1	58.5	63.3	61.2	52.6	41.7	34.1	27.8
	DBStd	16.46	11.08	10.94	8.46	7.22	8.08	6.00	5.92	5.44	5.93	6.81	7.25	8.97
	HDD50	4083	877	770	622	264	70	6	0	1	41	266	478	688
	HDD65	8357	1342	1190	1087	697	406	208	105	145	374	722	928	1153
	CDD50	1300	0	0	0	17	135	262	412	348	117	9	0	0
	CDD65	100	0	0	0	0	6	14	52	27	1	0	0	0
	CDH74	632	0	0	0	0	44	96	333	155	4	0	0	0
	CDH80	83	0	0	0	0	2	7	55	19	0	0	0	0
Wind	WSAvg	5.7	6.3	6.0	6.4	5.8	5.2	5.1	4.5	4.6	5.1	5.8	6.5	6.6
Precipitation	PrecAvg	28.3	2.1	1.7	1.6	1.5	2.6	3.3	3.3	3.0	2.3	2.8	2.4	2.0
	PrecMax	35.7	3.9	3.0	3.4	3.6	4.3	7.2	7.2	6.2	4.2	5.1	4.1	3.0
	PrecMin	20.9	0.8	0.5	0.7	0.3	0.3	0.9	0.3	0.2	0.6	0.4	0.1	1.3
	PrecStd	3.9	0.8	0.6	0.7	0.9	1.1	1.5	1.7	1.6	1.0	1.0	1.0	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.2	41.3	55.3	69.6	79.2	80.5	85.1	82.8	73.6	59.9	49.4	47.1
		MCWB	42.1	37.9	44.3	51.2	63.5	65.3	68.9	69.3	62.3	55.2	47.4	45.7
	2%	DB	38.8	38.1	48.5	64.0	74.4	76.8	81.0	78.2	68.0	55.9	46.7	42.8
		MCWB	37.5	36.1	40.1	49.7	60.1	62.5	66.9	65.9	59.5	52.4	44.8	41.4
	5%	DB	35.9	36.0	43.3	59.1	70.1	73.6	77.7	74.9	64.5	53.4	44.8	40.0
		MCWB	35.1	34.8	37.9	47.1	57.0	61.4	65.3	64.3	57.5	50.9	43.5	39.0
	10%	DB	34.2	34.6	40.2	54.6	66.1	70.1	74.5	71.7	61.7	51.3	43.2	37.9
		MCWB	33.4	33.6	36.7	44.7	55.1	59.8	64.1	62.7	56.3	49.2	42.1	36.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	38.8	45.7	53.5	66.5	68.2	71.2	71.3	63.3	55.8	48.0	45.9
		MCDB	43.1	40.2	54.6	64.3	75.6	76.0	80.8	80.1	69.0	58.9	49.4	46.9
	2%	WB	38.0	36.4	41.2	50.8	62.4	65.4	69.0	68.0	60.7	53.1	45.3	41.6
		MCDB	38.8	37.4	46.0	61.8	70.3	72.6	77.5	74.8	65.8	55.1	46.3	42.4
	5%	WB	35.2	35.1	39.1	48.4	59.6	63.0	67.0	65.5	58.9	51.3	43.8	39.1
		MCDB	35.6	35.9	42.1	57.2	67.3	70.4	74.6	72.0	63.1	53.1	44.7	39.9
	10%	WB	33.5	33.7	37.1	45.8	56.8	61.1	65.2	63.6	56.9	49.4	42.2	36.9
		MCDB	34.0	34.5	39.7	52.6	64.3	68.1	72.3	70.4	60.9	51.1	43.0	37.6
Mean Daily Temperature Range	5% DB	MDBR	7.4	8.8	11.1	15.7	17.1	15.6	14.9	14.5	12.2	8.6	5.6	6.0
		MCDBR	6.3	7.3	15.3	22.6	21.7	20.0	19.4	19.1	16.4	11.0	7.2	6.0
		MCWBR	6.2	6.2	9.4	11.5	10.1	8.9	7.8	8.6	9.0	8.0	6.4	6.0
	5% WB	MCDBR	6.3	6.7	12.9	20.3	18.8	16.5	17.0	16.5	14.3	9.3	6.5	5.9
		MCWBR	6.2	6.2	9.1	11.2	10.2	9.2	8.0	8.7	8.7	7.7	6.1	6.0
Clear-Sky Solar Irradiance	taub	0.271	0.303	0.333	0.374	0.367	0.364	0.392	0.390	0.358	0.333	0.312	0.267	
	taud	2.137	2.136	2.181	2.286	2.375	2.411	2.350	2.352	2.423	2.408	2.240	2.137	
	Ebn at Noon	184	229	256	265	275	278	266	258	249	222	167	149	
	Edh at Noon	17	27	33	36	35	34	36	33	27	21	16	13	
All-Sky Solar Radiation	RadAvg	147	376	820	1253	1667	1726	1646	1319	850	383	131	87	
	RadStd	30	68	107	153	175	142	171	130	95	60	20	16	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page