

PAVILOSTA, Latvia

WMO: 264030

Lat: 56.8883N

Lon: 21.1894E

Elev: 30

StdP: 14.68

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.3	9.4	-2.5	4.8	6.5	2.2	6.2	11.2	23.0	29.6	21.0	30.5	4.5	150	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	79.9	66.3	75.8	64.7	72.7	63.9	68.8	75.7	66.7	72.8	65.1	71.0	7.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	97.2	72.4	64.3	90.4	70.1	62.7	85.3	68.7	33.0	75.6	31.4	72.9	30.1	71.1	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	15.8	14.0	DB	0.5	85.4	9.0	3.3	-6.0	87.8	-11.3	89.7	-16.4	91.5	-22.9	93.9	(4)
(5)			WB	-1.4	71.1	8.7	2.6	-7.7	73.0	-12.8	74.6	-17.7	76.1	-24.0	78.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.3	28.0	29.0	33.8	42.0	50.5	58.7	62.8	62.4	55.8	46.2	39.7	33.1
	DBStd	13.99	9.01	9.33	6.29	6.42	7.45	6.02	4.98	4.30	5.22	5.80	6.22	8.28
	HDD50	3102	683	587	502	255	79	3	0	0	15	146	308	524
	HDD65	7292	1148	1007	967	689	454	211	103	103	279	584	758	989
	CDD50	1368	0	0	0	16	95	262	396	385	187	27	0	0
	CDD65	83	0	0	0	0	5	20	34	23	1	0	0	0
	CDH74	550	0	0	0	1	44	155	202	140	8	0	0	0
	CDH80	110	0	0	0	0	4	26	56	23	1	0	0	0
Wind	WSAvg	6.9	8.0	7.7	7.3	6.8	6.1	6.1	5.4	5.7	6.4	7.5	7.7	7.8
Precipitation	PrecAvg	29.2	2.4	1.9	1.7	1.3	1.4	2.3	2.4	3.3	2.6	3.8	3.5	2.7
	PrecMax	40.0	5.3	3.1	3.5	2.7	3.1	4.8	5.7	7.4	4.7	7.4	6.0	4.6
	PrecMin	21.3	0.3	0.3	0.3	0.3	0.5	0.6	0.0	0.3	1.0	1.7	0.4	1.1
	PrecStd	4.4	1.1	0.7	0.8	0.7	0.7	0.9	1.4	1.7	1.2	1.6	1.4	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.2	44.8	54.6	69.0	79.4	83.6	86.5	83.5	73.5	62.2	52.0	45.9
		MCWB	41.6	41.3	47.8	53.5	64.0	66.4	70.3	68.2	61.4	55.8	49.8	43.5
	2%	DB	41.7	42.0	46.8	62.9	72.8	78.5	78.9	77.7	68.8	58.5	50.4	44.9
		MCWB	40.2	39.7	41.6	50.5	59.2	65.7	67.0	64.5	60.5	54.8	48.2	42.9
	5%	DB	40.1	40.1	43.1	57.1	67.6	73.8	74.6	74.4	66.0	56.2	49.0	43.6
		MCWB	38.7	38.3	39.9	47.2	57.9	63.6	66.1	64.3	59.4	53.2	46.8	41.8
	10%	DB	38.5	38.7	41.3	52.3	63.2	69.2	71.5	71.3	63.9	54.7	47.5	42.4
		MCWB	37.2	37.3	38.8	45.7	55.4	60.9	65.0	63.6	58.6	51.8	45.4	40.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.3	41.9	47.9	55.2	64.6	69.0	72.0	71.0	64.9	57.6	50.7	44.8
		MCDB	42.9	43.7	54.2	67.1	78.3	78.7	81.4	79.4	70.0	60.9	51.6	45.5
	2%	WB	40.6	40.1	42.6	51.4	61.1	66.7	69.7	67.7	62.3	55.3	48.6	43.3
		MCDB	41.3	41.5	45.6	59.8	69.3	75.1	76.2	73.4	65.7	57.7	50.1	44.3
	5%	WB	38.9	38.6	40.6	48.7	58.5	64.3	67.4	66.0	60.6	53.8	47.2	42.1
		MCDB	39.9	39.8	42.7	55.7	66.2	73.2	72.9	71.3	64.1	56.0	48.5	43.4
	10%	WB	37.4	37.5	39.0	46.3	55.9	62.0	65.5	64.6	59.2	52.3	45.8	40.9
		MCDB	38.6	38.7	41.0	52.0	62.9	68.4	70.8	69.9	63.5	54.5	47.2	42.4
Mean Daily Temperature Range	5% DB	MDBR	7.4	8.1	9.4	13.5	14.9	13.9	12.8	14.3	11.6	9.6	6.2	6.0
		MCDBR	5.7	7.1	11.6	21.8	21.6	22.3	19.1	21.0	16.1	11.4	6.3	5.5
		MCWBR	5.9	5.9	7.9	12.3	11.4	10.6	9.4	10.4	9.8	8.4	5.8	5.6
	5% WB	MCDBR	5.8	6.4	10.7	19.2	19.5	18.6	16.1	16.3	12.5	10.0	5.9	5.3
		MCWBR	5.9	5.8	7.9	12.0	11.0	9.8	8.9	9.9	8.8	8.0	5.8	5.6
Clear-Sky Solar Irradiance	taub		0.302	0.328	0.350	0.384	0.378	0.373	0.404	0.398	0.366	0.349	0.335	0.301
	taud		2.229	2.273	2.308	2.294	2.375	2.429	2.362	2.376	2.440	2.399	2.267	2.195
	Ebn at Noon		180	227	254	263	273	276	263	256	248	218	164	144
	Edh at Noon		17	24	30	36	35	34	35	33	27	22	16	13
All-Sky Solar Radiation	RadAvg		115	314	764	1350	1812	1924	1763	1410	944	442	146	77
	RadStd		20	46	87	151	146	91	151	126	104	58	25	10

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (26 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page