

LIEPAJA, Latvia

WMO: 264060

Lat: 56.4755N

Lon: 21.0206E

Elev: 16

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.4	9.8	-0.8	5.3	5.4	4.5	6.9	11.7	31.5	41.4	27.5	40.2	4.5	70	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	80.8	67.5	77.3	65.6	74.2	64.2	69.7	77.1	67.6	74.5	65.7	72.1	8.1	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.1	99.8	73.6	64.8	92.0	70.8	63.0	86.2	69.1	33.7	77.3	32.0	74.7	30.6	72.4	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.9	20.4	17.7	DB	-3.0	86.1	8.0	3.2	-8.8	88.5	-13.5	90.4	-18.0	92.2	-23.9	94.5	(4)
(5)			WB	-3.6	73.0	7.9	3.6	-9.2	75.6	-13.8	77.7	-18.2	79.7	-23.9	82.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.8	29.1	29.2	33.8	43.4	51.8	58.1	63.7	63.3	56.0	47.0	39.4	33.6		
	DBStd	14.14	9.47	9.06	6.57	7.13	7.22	5.61	5.09	4.83	5.20	6.35	6.88	8.59		
	HDD50	2996	648	584	502	226	59	3	0	0	12	133	320	509		
	HDD65	7119	1113	1004	967	649	415	221	87	91	271	558	769	974		
	CDD50	1456	0	0	0	27	115	245	425	412	193	39	0	0		
	CDD65	105	0	0	0	0	6	13	47	37	2	0	0	0		
	CDH74	749	0	0	0	5	67	109	339	219	10	0	0	0		
	CDH80	129	0	0	0	0	6	18	69	35	1	0	0	0		
(14) Wind	WSAvg	7.9	9.1	8.5	8.2	7.5	7.1	7.2	6.7	6.9	7.4	8.4	8.6	9.3		
(15) Precipitation	PrecAvg	26.5	1.7	1.1	1.3	1.3	1.5	1.8	2.9	3.2	2.9	2.8	3.3	2.5		
	PrecMax	39.2	3.9	3.1	2.9	3.5	3.8	3.2	5.9	11.2	6.9	7.9	8.3	4.8		
	PrecMin	17.4	0.3	0.2	0.1	0.0	0.3	0.3	0.8	0.6	0.8	0.6	1.5	0.2		
	PrecStd	5.1	0.9	0.6	0.6	0.8	0.9	0.8	1.4	2.1	1.5	1.7	1.4	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.0	44.4	57.1	73.0	80.4	82.5	85.9	84.2	75.1	64.1	52.3	48.3		
		MCWB	43.8	41.2	47.5	57.3	65.0	67.2	69.6	69.3	64.8	57.4	49.9	46.5		
	2%	DB	43.0	41.6	48.5	66.4	75.1	77.1	81.9	79.1	69.8	59.5	51.0	46.6		
		MCWB	41.6	40.0	42.9	53.5	61.6	65.4	68.6	66.5	61.8	55.8	48.9	45.1		
	5%	DB	41.2	40.5	43.7	61.0	70.0	72.8	77.7	75.7	66.9	57.5	49.9	45.0		
		MCWB	39.7	39.1	40.5	50.5	58.7	62.2	66.9	65.0	60.3	54.5	48.0	43.6		
	10%	DB	39.5	39.1	41.2	55.7	64.8	68.4	73.8	73.0	64.5	55.7	48.3	43.4		
		MCWB	38.3	38.0	39.0	47.6	56.0	60.4	65.3	64.2	59.3	53.0	46.6	42.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.9	42.1	47.9	59.2	67.0	70.2	73.1	72.1	65.6	58.8	50.9	47.1		
		MCDB	44.3	43.2	54.4	70.2	76.6	78.4	80.8	79.8	71.8	62.0	51.7	47.6		
	2%	WB	41.7	40.2	43.3	54.8	63.5	66.7	70.3	69.0	63.2	56.7	49.5	45.3		
		MCDB	42.5	41.0	47.1	63.8	72.5	74.7	77.7	76.0	67.6	59.2	50.5	46.1		
	5%	WB	39.9	39.1	40.9	51.6	60.0	63.9	68.5	67.0	61.5	55.1	48.1	43.8		
		MCDB	40.8	39.9	43.0	59.4	67.9	70.1	75.4	73.3	65.4	57.5	49.2	44.8		
	10%	WB	38.3	38.0	39.3	48.6	57.0	61.5	66.4	65.3	60.0	53.7	46.6	42.1		
		MCDB	39.2	38.8	40.7	54.9	64.6	67.2	72.6	71.0	63.8	55.9	48.0	43.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	8.8	10.9	15.3	16.3	14.6	14.3	14.8	13.5	10.5	7.4	7.3		
		MCDBR	5.8	6.9	14.7	24.2	23.8	23.1	21.4	20.5	18.1	12.1	7.6	5.6		
	5% WB	MCWBR	6.0	6.0	10.4	13.6	13.1	12.4	10.9	10.4	11.7	9.3	7.1	5.8		
		MCWBR	5.8	6.4	12.7	22.1	21.7	19.2	18.3	17.3	15.0	11.1	7.0	5.4		
(40) Clear-Sky Solar Irradiance	taub		0.304	0.330	0.353	0.388	0.381	0.376	0.407	0.402	0.369	0.351	0.337	0.304		
	taud		2.233	2.269	2.298	2.278	2.365	2.418	2.351	2.364	2.430	2.397	2.274	2.206		
	Ebn at Noon		183	228	254	262	272	275	262	256	248	219	167	148		
	Edh at Noon		17	25	31	36	35	34	36	33	27	22	17	14		
(44) All-Sky Solar Radiation	RadAvg		125	328	767	1347	1791	1893	1718	1384	945	450	154	82		
	RadStd		21	49	85	150	145	90	146	134	101	61	25	10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page