

SALDUS, Latvia

WMO: 264160

Lat: 56.6753N

Lon: 22.5036E

Elev: 372

StdP: 14.50

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.1	6.2	-5.0	4.3	0.9	0.7	5.8	7.6	23.3	32.0	20.6	32.7	3.5	120	0.574

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	80.8	66.5	77.9	65.0	75.0	63.4	68.8	77.2	66.7	74.9	65.0	72.6	7.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.7	96.2	73.2	63.6	89.3	70.6	61.8	83.7	68.6	33.1	77.1	31.5	75.2	30.1	72.7	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.6	16.1	14.2	DB	-6.8	85.3	9.2	3.2	-13.4	87.6	-18.8	89.5	-24.0	91.3	-30.7	93.7	
			WB	-7.2	72.1	8.9	2.5	-13.6	73.9	-18.8	75.3	-23.7	76.7	-30.2	78.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.4	25.9	26.8	32.7	43.1	52.5	58.9	63.9	62.2	54.4	44.0	36.6	30.1	(6)
	DBStd	15.21	10.31	9.30	8.10	7.03	7.46	5.72	5.26	5.01	5.57	6.49	7.04	8.80	(7)
	HDD50	3467	748	650	537	226	55	3	0	0	23	205	402	618	(8)
	HDD65	7641	1213	1070	1002	656	392	200	87	116	319	651	852	1083	(9)
	CDD50	1405	0	0	0	19	134	269	430	379	155	19	0	0	(10)
	CDD65	104	0	0	0	0	6	16	52	29	1	0	0	0	(11)
	CDH74	816	0	0	0	2	48	139	405	216	6	0	0	0	(12)
	CDH80	113	0	0	0	0	1	18	67	27	0	0	0	0	(13)
(14) Wind	WSAvg	6.9	7.9	7.5	7.5	7.2	6.6	6.4	6.0	5.9	6.2	6.7	7.3	7.4	(14)
(15) Precipitation	PrecAvg	26.3	2.0	1.6	1.4	1.4	1.9	2.6	2.9	3.0	2.4	2.8	2.2	2.1	(15)
	PrecMax	33.7	4.3	2.8	2.5	2.7	4.5	4.4	6.0	6.1	4.0	5.4	3.6	4.8	(16)
	PrecMin	20.2	0.7	0.2	0.3	0.2	0.5	0.8	0.1	0.1	1.0	0.2	0.5	1.3	(17)
	PrecStd	3.2	0.9	0.6	0.7	0.7	1.0	1.0	1.5	1.5	0.9	1.2	0.9	0.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.1	44.5	57.3	69.8	79.2	82.5	85.5	83.5	74.0	61.9	51.6	47.7	(19)
		MCWB	43.8	41.6	46.4	52.4	64.1	67.5	68.2	70.0	61.7	55.3	49.2	46.4	(20)
	2%	DB	41.6	41.7	51.4	64.7	74.6	78.1	81.7	79.0	70.1	58.0	48.9	44.9	(21)
		MCWB	40.2	39.2	43.4	51.3	61.0	64.4	67.3	65.4	60.3	54.0	46.9	43.1	(22)
	5%	DB	39.3	39.2	46.5	60.2	71.2	74.4	78.7	76.2	66.8	55.5	47.1	42.3	(23)
		MCWB	38.0	37.6	41.2	48.7	58.5	62.4	66.0	64.3	58.7	52.7	45.4	40.9	(24)
	10%	DB	37.2	37.4	42.6	56.0	67.1	70.8	75.3	73.0	63.8	53.3	45.6	40.4	(25)
		MCWB	36.2	36.0	39.0	46.6	56.4	60.0	64.5	62.5	57.6	50.9	44.3	39.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.9	42.0	47.7	55.5	66.3	70.2	71.8	71.3	64.2	56.7	49.8	46.8	(27)
		MCDB	44.9	43.7	55.1	64.4	75.2	79.4	80.3	79.9	71.2	59.5	50.7	47.5	(28)
	2%	WB	40.4	39.5	44.3	52.2	63.1	66.3	69.3	68.0	61.8	54.8	47.3	43.3	(29)
		MCDB	41.4	41.1	50.5	62.5	72.5	75.4	77.7	76.1	67.5	57.2	48.6	44.4	(30)
	5%	WB	38.1	37.8	41.6	49.6	60.3	63.6	67.3	65.7	60.0	53.1	45.8	41.1	(31)
		MCDB	39.0	39.1	45.6	58.4	68.4	71.5	75.8	73.0	64.6	55.4	46.9	42.1	(32)
	10%	WB	36.2	36.2	39.3	47.4	57.3	61.4	65.6	63.9	58.4	51.2	44.4	39.2	(33)
		MCDB	37.1	37.3	42.3	54.9	65.6	69.1	73.6	70.8	62.8	53.2	45.5	40.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	8.3	11.9	16.9	18.4	16.9	16.4	15.9	13.8	10.0	6.2	6.2	(35)
		MCDBR	6.7	8.1	17.5	24.2	23.3	22.7	21.6	21.8	19.2	12.6	7.2	6.1	(36)
	5% WB	MCWBR	6.6	6.3	10.9	12.9	12.1	11.0	9.4	9.8	10.7	8.8	6.4	6.1	(37)
		MCWBR	6.8	6.9	15.9	21.1	20.4	19.7	18.8	18.4	15.5	11.1	6.8	6.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.288	0.317	0.346	0.382	0.374	0.370	0.401	0.395	0.363	0.342	0.326	0.288	(40)
		taud	2.197	2.211	2.259	2.274	2.346	2.386	2.323	2.342	2.414	2.407	2.273	2.186	(41)
	Ebn at Noon		186	230	255	264	274	276	264	257	250	222	170	152	(42)
		Edh at Noon	17	26	32	36	36	35	37	34	27	21	16	14	(43)
(44) All-Sky Solar Radiation	RadAvg		144	362	789	1268	1713	1782	1680	1348	912	445	152	92	(44)
	RadStd		32	72	118	165	151	122	140	134	103	67	23	11	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (25 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page