

DOBELE, Latvia

WMO: 264240

Lat: 56.6200N

Lon: 23.3197E

Elev: 142

StdP: 14.62

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.8	4.8	-5.4	4.1	0.0	-0.3	5.4	5.4	23.1	29.2	20.7	30.9	3.6	30	0.580

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	82.4	67.6	79.2	66.0	76.3	64.3	69.6	77.9	67.5	76.0	65.7	73.9	8.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.7	98.8	73.7	64.5	91.2	71.3	62.6	85.4	69.4	33.7	77.9	32.0	75.8	30.6	74.0	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.0	16.8	15.2	DB	-5.1	89.2	6.7	2.8	-9.9	91.2	-13.8	92.9	-17.6	94.4	-22.4	96.5	(4)
(5)			WB	-6.2	73.2	6.5	2.0	-10.8	74.7	-14.6	75.8	-18.3	76.9	-22.9	78.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.0	24.9	27.0	34.1	44.5	53.7	60.5	64.8	63.2	55.1	44.2	36.9	30.2
	DBStd	15.69	10.34	10.40	7.50	7.12	7.43	6.04	5.42	5.22	5.43	6.53	7.89	9.19
	HDD50	3380	777	643	494	192	46	2	0	0	19	201	393	613
	HDD65	7431	1242	1063	959	614	355	162	72	99	299	646	842	1078
	CDD50	1564	0	0	0	28	161	316	459	409	171	20	0	0
	CDD65	142	0	0	0	0	6	26	66	43	1	0	0	0
	CDH74	1158	0	0	0	2	66	224	470	387	9	0	0	0
	CDH80	222	0	0	0	0	3	33	96	90	0	0	0	0
Wind	WSAvg	7.6	8.4	8.0	8.6	8.1	7.3	7.0	6.6	6.4	7.0	7.7	7.9	8.5
Precipitation	PrecAvg	25.4	1.8	1.4	1.3	1.3	1.9	2.8	3.3	2.9	2.3	2.7	2.0	1.8
	PrecMax	34.5	3.3	2.7	2.5	2.9	3.5	4.6	7.2	5.0	5.2	5.6	3.5	3.5
	PrecMin	20.5	0.7	0.4	0.3	0.2	0.6	0.9	0.2	0.0	0.8	0.2	0.4	1.0
	PrecStd	3.3	0.7	0.5	0.6	0.7	0.8	0.9	1.8	1.4	1.0	1.2	0.8	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.1	44.8	56.8	71.2	79.4	83.9	86.2	88.0	75.4	61.8	53.2	49.0
		MCWB	42.3	40.9	47.6	54.2	65.0	68.5	69.0	68.6	63.0	56.3	49.7	46.7
	2%	DB	40.9	41.8	51.2	66.5	75.5	79.8	82.8	81.8	71.0	58.2	50.0	45.9
		MCWB	38.9	38.8	43.8	52.6	62.1	66.4	68.2	66.3	59.9	54.6	47.6	43.7
	5%	DB	38.6	39.5	47.1	61.8	71.7	76.2	79.2	78.2	67.4	55.8	48.0	42.9
		MCWB	37.0	37.6	41.5	50.8	59.6	64.5	67.2	64.7	58.4	52.6	46.0	41.2
	10%	DB	36.8	37.8	43.8	56.8	67.6	72.5	75.9	74.8	64.5	53.6	46.3	40.7
		MCWB	35.6	36.2	39.8	47.7	57.6	62.2	65.4	62.7	57.9	50.6	44.6	39.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	41.6	48.7	56.7	67.0	70.9	73.0	71.6	64.5	57.5	50.4	47.1
		MCDB	44.2	43.9	55.5	67.0	76.9	79.2	82.2	81.6	71.8	60.3	52.2	48.4
	2%	WB	39.6	39.3	44.6	53.7	64.0	67.7	70.5	68.2	61.8	55.3	47.7	43.7
		MCDB	40.8	40.9	49.9	64.4	73.1	76.8	78.7	77.2	67.2	57.8	49.5	45.3
	5%	WB	37.3	37.9	42.1	51.3	61.1	65.5	68.4	65.9	60.0	53.2	46.3	41.4
		MCDB	38.3	39.4	46.1	60.7	69.1	74.2	76.3	75.5	65.3	55.4	47.9	42.9
	10%	WB	35.6	36.2	40.0	48.7	58.3	63.4	66.5	64.3	58.3	51.2	44.7	39.2
		MCDB	36.7	37.7	43.5	56.0	65.7	70.5	74.0	72.6	63.5	53.2	46.2	40.6
Mean Daily Temperature Range	5% DB	MDBR	7.9	7.9	10.9	16.9	18.3	17.1	16.4	17.6	14.2	10.1	6.3	6.2
		MCDBR	6.4	8.1	16.0	25.1	23.7	22.3	21.5	23.6	19.6	11.7	7.5	7.6
		MCWBR	6.1	6.5	10.5	13.2	12.4	10.9	9.2	9.9	10.3	8.7	6.7	7.2
	5% WB	MCDBR	6.5	8.0	14.4	22.6	20.6	20.6	18.8	20.7	15.9	10.8	7.1	7.2
		MCWBR	6.3	6.8	10.3	13.0	11.9	11.2	9.6	9.6	9.5	9.0	6.6	6.9
Clear-Sky Solar Irradiance	taub	0.290	0.320	0.351	0.389	0.380	0.375	0.408	0.402	0.368	0.346	0.330	0.290	
	taud	2.189	2.186	2.230	2.252	2.334	2.375	2.309	2.327	2.401	2.404	2.268	2.187	
	Ebn at Noon	185	228	253	261	272	275	262	255	247	221	169	152	
	Edh at Noon	17	26	33	37	36	36	37	34	28	22	16	14	
All-Sky Solar Radiation	RadAvg	146	365	789	1266	1709	1777	1675	1346	913	447	153	93	
	RadStd	32	73	119	166	150	123	140	135	103	68	24	11	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (30 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page