

DOBELE, Latvia

WMO: 264240

Lat: 56.6200N

Lon: 23.3197E

Elev: 43

StdP: 100.81

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.2	-15.1	-20.8	0.6	-17.8	-17.9	0.8	-14.8	10.3	-1.5	9.2	-0.6	1.6	30	0.580

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	28.0	19.8	26.2	18.9	24.6	17.9	20.9	25.5	19.7	24.4	18.7	23.3	3.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	14.1	23.2	18.0	13.0	21.9	17.0	12.2	20.8	60.5	25.5	56.6	24.3	53.3	23.4	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.5	7.5	6.8	-20.6	31.8	3.7	1.5	-23.3	32.9	-25.5	33.8	-27.5	34.7	-30.2	35.8
			-21.2	22.9	3.6	1.1	-23.8	23.7	-25.9	24.3	-27.9	25.0	-30.5	25.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-3.9	-2.8	1.2	7.0	12.1	15.8	18.2	17.3	12.8	6.8	2.7	-1.0
	DBStd	8.71	5.75	5.78	4.17	3.96	4.13	3.36	3.01	2.90	3.02	3.63	4.38	5.11
	HDD10.0	1878	432	357	274	107	26	1	0	0	11	112	218	341
	HDD18.3	4128	690	591	533	341	197	90	40	55	166	359	468	599
	CDD10.0	869	0	0	0	16	89	176	255	227	95	11	0	0
	CDD18.3	79	0	0	0	0	3	14	37	24	1	0	0	0
	CDH23.3	643	0	0	0	1	37	124	261	215	5	0	0	0
	CDH26.7	123	0	0	0	0	2	18	53	50	0	0	0	0
Wind	WSAvg	3.4	3.7	3.6	3.9	3.6	3.3	3.1	2.9	2.9	3.1	3.4	3.5	3.8
Precipitation	PrecAvg	645	45	35	33	34	49	70	84	73	58	68	52	45
	PrecMax	876	83	68	64	73	89	116	183	128	132	143	90	88
	PrecMin	520	17	9	7	4	16	24	6	1	20	6	11	25
	PrecStd	84	18	13	15	18	20	24	45	35	26	31	21	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.7	7.1	13.8	21.8	26.3	28.8	30.1	31.1	24.1	16.5	11.8	9.4
		MCWB	5.7	5.0	8.7	12.3	18.3	20.3	20.6	20.4	17.2	13.5	9.8	8.2
	2%	DB	4.9	5.5	10.6	19.1	24.2	26.6	28.2	27.7	21.7	14.6	10.0	7.7
		MCWB	3.8	3.8	6.6	11.5	16.7	19.1	20.1	19.1	15.5	12.5	8.7	6.5
	5%	DB	3.7	4.2	8.4	16.5	22.1	24.5	26.2	25.7	19.7	13.2	8.9	6.1
		MCWB	2.8	3.1	5.3	10.4	15.4	18.0	19.6	18.2	14.7	11.5	7.8	5.1
	10%	DB	2.7	3.2	6.6	13.8	19.8	22.5	24.4	23.8	18.1	12.0	7.9	4.8
		MCWB	2.0	2.3	4.3	8.7	14.2	16.8	18.5	17.1	14.4	10.3	7.0	4.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	5.3	9.3	13.7	19.5	21.6	22.8	22.0	18.0	14.1	10.2	8.4
		MCDB	6.8	6.6	13.1	19.5	24.9	26.2	27.9	27.5	22.1	15.7	11.2	9.1
	2%	WB	4.2	4.1	7.0	12.1	17.8	19.8	21.4	20.1	16.5	12.9	8.7	6.5
		MCDB	4.9	4.9	9.9	18.0	22.8	24.9	25.9	25.1	19.6	14.3	9.7	7.4
	5%	WB	2.9	3.3	5.6	10.7	16.2	18.6	20.2	18.9	15.6	11.8	7.9	5.2
		MCDB	3.5	4.1	7.8	15.9	20.6	23.5	24.6	24.2	18.5	13.0	8.8	6.1
	10%	WB	2.0	2.4	4.4	9.3	14.6	17.4	19.2	17.9	14.6	10.6	7.1	4.0
		MCDB	2.6	3.2	6.4	13.3	18.7	21.4	23.3	22.6	17.5	11.8	7.9	4.8
Mean Daily Temperature Range	5% DB	MDBR	4.4	4.4	6.1	9.4	10.2	9.5	9.1	9.8	7.9	5.6	3.5	3.5
		MCDBR	3.5	4.5	8.9	13.9	13.2	12.4	11.9	13.1	10.9	6.5	4.1	4.2
		MCWBR	3.4	3.6	5.8	7.3	6.9	6.1	5.1	5.5	5.7	4.8	3.7	4.0
	5% WB	MCDBR	3.6	4.4	8.0	12.5	11.4	11.4	10.5	11.5	8.9	6.0	4.0	4.0
		MCWBR	3.5	3.8	5.7	7.2	6.6	6.2	5.3	5.3	5.3	5.0	3.7	3.8
Clear-Sky Solar Irradiance	taub	0.290	0.320	0.351	0.389	0.380	0.375	0.408	0.402	0.368	0.346	0.330	0.290	
	taud	2.189	2.186	2.230	2.252	2.334	2.375	2.309	2.327	2.401	2.404	2.268	2.187	
	Ebn at Noon	584	719	798	824	858	866	825	803	780	697	532	478	
	Edh at Noon	55	83	103	117	115	112	117	108	87	68	52	43	
All-Sky Solar Radiation	RadAvg	0.46	1.15	2.49	3.99	5.39	5.60	5.28	4.24	2.88	1.41	0.48	0.29	
	RadStd	0.10	0.23	0.37	0.52	0.47	0.39	0.44	0.42	0.32	0.21	0.07	0.04	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)		+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page