

JELGAVA, Latvia

WMO: 264250

Lat: 56.5569N

Lon: 23.9642E

Elev: 19

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.7	3.8	-8.0	3.6	-2.9	-1.6	5.1	5.3	19.9	33.9	18.4	30.2	2.0	20	0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.8	82.7	68.5	79.5	66.6	76.6	65.0	70.7	79.4	68.5	76.6	66.5	74.3	5.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.5	101.2	75.6	65.5	94.2	73.0	63.5	87.6	70.5	34.6	79.1	32.7	76.4	31.2	74.7	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	14.7	12.8	-10.4	87.7	8.1	3.7	-16.2	90.3	-20.9	92.5	-25.5	94.6	-31.3	97.3
			-9.9	74.0	8.5	2.5	-16.0	75.7	-20.9	77.2	-25.7	78.6	-31.8	80.4
				DB										
				WB										

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	24.3	27.1	33.3	43.9	53.5	60.2	64.2	62.1	54.1	43.8	37.7	29.6	
	DBStd	15.65	10.41	10.97	7.80	7.30	7.82	6.50	5.48	5.23	5.72	6.62	6.98	9.50	
	HDD50	3459	795	642	519	209	51	3	0	0	25	211	371	633	
	HDD65	7580	1260	1062	983	633	366	172	82	121	327	656	820	1098	
	CDD50	1481	0	0	1	25	159	310	441	375	149	20	1	0	
	CDD65	128	0	0	0	0	8	29	58	32	1	0	0	0	
	CDH74	1241	0	0	0	6	100	293	512	321	9	0	0	0	
	CDH80	223	0	0	0	0	8	51	106	58	0	0	0	0	
Wind	WSAvg	5.3	6.2	6.5	6.4	5.9	4.7	4.6	3.9	3.3	4.5	5.5	5.7	6.0	
Precipitation	PrecAvg	25.8	1.7	1.4	1.3	1.3	2.0	2.7	3.3	2.9	2.4	2.8	2.0	1.9	
	PrecMax	34.2	2.9	2.4	2.8	2.9	3.7	4.8	6.6	5.5	5.1	5.5	3.3	3.7	
	PrecMin	20.4	0.6	0.4	0.3	0.2	0.6	0.9	0.4	0.0	1.0	0.1	0.4	0.9	
	PrecStd	3.2	0.7	0.5	0.6	0.7	0.8	1.0	1.7	1.5	1.1	1.2	0.8	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.2	44.8	57.3	72.7	80.9	84.6	86.1	86.1	75.6	62.4	53.6	48.9	
		MCWB	42.8	40.5	47.5	54.3	65.3	70.2	71.3	71.6	63.4	56.8	49.7	46.8	
	2%	DB	40.2	42.2	50.7	67.2	76.8	80.8	83.0	80.7	70.9	59.0	50.2	45.5	
		MCWB	38.5	39.3	43.6	52.9	62.3	67.1	68.8	67.1	60.4	55.3	47.9	43.7	
	5%	DB	38.2	40.2	46.4	62.3	72.9	77.4	79.8	77.6	67.3	56.1	48.4	42.7	
		MCWB	36.7	38.0	41.5	50.8	60.3	65.4	68.2	65.4	58.9	52.8	46.2	41.3	
	10%	DB	36.5	38.5	43.2	57.5	68.7	73.7	76.1	74.6	64.4	53.7	46.7	40.4	
		MCWB	35.3	36.7	39.4	47.8	57.5	63.3	66.3	63.6	58.3	51.0	45.2	39.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.9	41.7	48.6	57.3	66.9	73.5	73.2	73.1	64.9	57.8	50.5	47.3
			MCDB	43.8	43.8	56.5	67.2	78.2	84.1	82.7	82.4	72.0	60.7	52.0	48.4
2%		WB	39.1	39.6	44.5	54.0	64.4	68.5	71.2	69.6	62.3	55.5	48.2	43.7	
		MCDB	39.9	41.3	49.3	64.4	74.0	77.6	79.5	78.6	67.6	58.3	49.8	45.0	
5%		WB	37.0	38.3	42.0	51.6	61.4	66.4	69.2	67.0	60.6	53.5	46.6	41.3	
		MCDB	37.9	39.9	45.6	60.9	70.0	74.9	77.0	74.3	65.4	55.8	48.0	42.6	
10%		WB	35.4	36.8	39.7	48.9	58.8	64.2	67.3	65.1	58.8	51.5	45.3	39.0	
		MCDB	36.3	38.4	42.8	56.2	66.2	72.5	74.8	72.8	63.6	53.2	46.7	40.3	
Mean Daily Temperature Range	5% DB	MDBR	9.2	9.5	12.8	19.2	21.4	19.8	18.8	20.4	16.7	11.9	7.2	6.7	
		MCDBR	6.3	8.7	17.0	27.5	26.5	24.4	23.6	25.6	22.3	14.0	8.9	7.7	
		MCWBR	5.9	6.9	11.2	14.6	13.5	12.3	11.1	12.7	13.2	10.0	7.7	6.7	
	5% WB	MCDBR	6.6	8.2	15.5	24.7	22.4	22.0	21.4	22.5	17.6	12.1	8.6	7.2	
		MCWBR	6.4	7.0	10.8	14.1	12.1	11.9	11.0	12.4	11.3	9.4	7.8	6.6	
Clear-Sky Solar Irradiance	taub	0.291	0.323	0.355	0.393	0.383	0.379	0.412	0.407	0.371	0.348	0.333	0.291		
	taud	2.177	2.169	2.209	2.241	2.327	2.369	2.300	2.314	2.393	2.398	2.260	2.182		
	Ebn at Noon	185	226	252	260	271	274	260	253	246	220	167	151		
	Edh at Noon	18	27	33	38	37	36	37	35	28	22	17	14		
All-Sky Solar Radiation	RadAvg	148	371	793	1256	1695	1762	1666	1342	901	438	148	92		
	RadStd	35	76	126	161	154	135	145	134	100	69	23	13		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (31 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page