

SKRIVERI, Latvia

WMO: 264350

Lat: 56.6425N

Lon: 25.1283E

Elev: 265

StdP: 14.56

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.3	2.1	-9.6	3.3	-2.9	-3.6	4.6	2.8	16.2	35.1	14.5	31.2	2.9	50	0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	82.7	67.7	79.6	65.7	76.6	64.3	69.8	78.6	67.6	75.8	65.9	74.1	5.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	98.8	74.6	64.5	91.9	71.4	62.8	86.2	69.7	33.9	78.8	32.2	75.7	30.8	74.2	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	12.2	11.0	DB	-9.7	87.3	8.2	2.5	-15.6	89.1	-20.4	90.6	-25.0	92.0	-30.9	93.8	(4)
(5)			WB	-10.1	72.7	8.1	2.0	-15.9	74.1	-20.7	75.3	-25.2	76.4	-31.1	77.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	44.0	22.8	25.5	32.7	43.7	53.8	60.8	64.6	62.8	53.8	42.7	35.7	28.4	(6)
(7)		DBStd	16.45	10.69	10.72	7.90	7.71	8.11	6.69	5.89	5.35	5.53	6.53	8.34	10.01	(7)
(8)		HDD50	3707	842	686	537	221	52	4	0	0	27	240	430	668	(8)
(9)		HDD65	7803	1307	1106	1002	640	356	162	81	109	337	691	879	1133	(9)
(10)		CDD50	1533	0	0	0	31	171	327	453	397	141	13	0	0	(10)
(11)		CDD65	155	0	0	0	0	10	35	69	40	1	0	0	0	(11)
(12)		CDH74	1256	0	0	0	1	94	313	503	336	9	0	0	0	(12)
(13)		CDH80	229	0	0	0	0	6	46	105	72	0	0	0	0	(13)
(14)	Wind	WSAvg	5.3	6.0	5.8	6.0	5.5	4.8	4.8	4.4	4.3	4.7	5.4	5.9	6.0	(14)
(15)	Precipitation	PrecAvg	29.3	2.2	1.7	1.6	1.6	2.4	3.1	3.2	3.3	2.4	3.0	2.5	2.2	(15)
(16)		PrecMax	36.7	5.0	2.9	3.3	3.5	4.9	5.9	7.0	6.9	4.2	6.2	4.5	3.3	(16)
(17)		PrecMin	21.1	0.8	0.6	0.4	0.4	0.4	0.9	0.2	0.4	0.4	0.4	0.1	1.4	(17)
(18)		PrecStd	4.2	0.9	0.6	0.7	0.8	1.2	1.3	1.7	1.9	1.0	1.2	1.0	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.9	42.9	56.0	71.2	80.6	84.1	86.4	86.8	74.8	61.0	52.0	47.5	(19)
(20)			MCWB	41.7	38.9	45.7	53.1	64.5	66.5	71.3	70.9	61.8	55.6	49.8	45.8	(20)
(21)		2%	DB	39.3	40.4	50.2	67.3	76.5	80.9	83.0	81.4	69.8	57.0	49.1	44.3	(21)
(22)			MCWB	38.1	37.9	42.5	51.3	62.1	65.8	68.5	67.3	59.5	53.9	47.2	42.7	(22)
(23)		5%	DB	36.8	38.3	45.9	62.7	72.5	77.8	79.7	77.4	66.4	54.6	47.0	41.6	(23)
(24)			MCWB	35.6	36.6	40.5	49.7	59.3	64.2	66.9	64.7	58.0	51.8	45.5	40.4	(24)
(25)		10%	DB	35.2	36.7	42.7	57.8	68.5	74.1	76.0	74.3	63.3	52.5	45.4	39.6	(25)
(26)			MCWB	34.3	35.4	38.7	47.2	57.0	62.4	65.5	63.5	57.2	50.3	44.1	38.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.9	39.8	47.3	55.3	66.1	69.6	72.9	73.6	63.7	57.1	50.6	46.4	(27)
(28)			MCDWB	42.8	41.4	54.9	65.5	76.8	78.1	83.3	82.3	69.7	60.0	51.8	47.6	(28)
(29)		2%	WB	38.4	38.1	43.5	52.7	63.6	67.5	70.4	69.1	61.2	54.3	47.6	42.8	(29)
(30)			MCDWB	39.1	39.4	47.7	63.8	73.5	76.9	79.6	78.1	66.0	56.2	48.7	43.9	(30)
(31)		5%	WB	35.9	36.9	41.1	50.6	61.0	65.6	68.3	66.5	59.6	52.4	45.9	40.5	(31)
(32)			MCDWB	36.6	38.0	45.1	60.1	69.2	74.5	76.3	74.7	64.1	54.1	46.9	41.6	(32)
(33)		10%	WB	34.4	35.5	39.0	48.3	58.7	63.7	66.5	64.6	57.9	50.6	44.2	38.3	(33)
(34)			MCDWB	35.1	36.6	42.4	57.6	67.1	71.8	74.2	72.5	62.0	52.1	45.3	39.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.0	8.8	11.9	17.2	19.1	17.8	16.6	17.7	14.2	10.2	6.1	6.2	(35)
(36)			MCDBR	6.1	7.6	15.7	24.4	23.8	22.7	21.4	23.0	20.0	12.1	7.6	6.4	(36)
(37)			MCWBR	5.9	6.2	9.9	12.2	11.2	10.0	8.9	10.3	11.2	8.8	6.8	6.2	(37)
(38)		5% WB	MCDBR	6.0	6.8	14.1	21.1	20.3	19.4	18.7	19.4	15.3	10.0	7.1	6.2	(38)
(39)			MCWBR	6.0	5.9	10.0	11.5	10.7	9.8	8.9	10.0	9.8	8.0	6.7	6.2	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.286	0.317	0.350	0.389	0.379	0.375	0.407	0.405	0.369	0.345	0.329	0.286	(40)
(41)		taud		2.164	2.156	2.197	2.257	2.351	2.388	2.318	2.323	2.401	2.407	2.257	2.176	(41)
(42)		Ebn at Noon		185	228	253	261	272	275	262	254	247	221	168	152	(42)
(43)		Edh at Noon		18	27	34	37	36	35	37	35	28	22	17	14	(43)
(44)	All-Sky Solar Radiation	RadAvg		146	373	797	1248	1687	1755	1666	1341	884	425	139	89	(44)
(45)		RadStd		37	77	131	153	160	147	150	131	97	69	22	14	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page