

ZILANI, Latvia

WMO: 264360

Lat: 56.5200N

Lon: 25.9183E

Elev: 108

StdP: 100.03

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.9	-17.4	-23.8	0.4	-20.6	-20.5	0.6	-16.8	8.7	0.7	7.6	0.5	1.3	80	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	28.0	19.9	26.3	18.7	24.6	17.9	21.1	26.3	19.9	24.4	18.9	23.1	2.1	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.1	24.1	18.1	13.2	22.2	17.2	12.4	21.2	61.4	26.4	57.3	24.5	53.9	23.0	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.2	5.4	DB	-24.3	30.6	4.0	1.5	-27.2	31.7	-29.5	32.5	-31.8	33.3	-34.7	34.4	(4)
(5)			WB	-24.5	22.7	4.0	1.1	-27.4	23.5	-29.7	24.1	-32.0	24.7	-34.9	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	-5.3	-4.2	0.1	6.6	12.2	16.1	18.2	16.7	11.9	6.1	2.4	-2.5	(6)
(7)		DBStd	9.24	6.06	6.27	4.45	4.23	4.42	3.62	3.27	3.00	3.24	3.70	3.96	5.44	(7)
(8)		HDD10.0	2094	476	399	308	119	28	2	0	0	18	131	228	387	(8)
(9)		HDD18.3	4372	734	632	567	352	194	86	44	68	193	380	478	645	(9)
(10)		CDD10.0	846	0	0	0	17	97	184	254	209	76	9	0	0	(10)
(11)		CDD18.3	82	0	0	0	0	5	19	39	18	1	0	0	0	(11)
(12)		CDH23.3	661	0	0	0	2	51	155	293	155	5	0	0	0	(12)
(13)		CDH26.7	124	0	0	0	0	3	23	67	31	0	0	0	0	(13)
(14)	Wind	WSAvg	2.4	2.7	2.5	2.8	2.6	2.2	2.2	2.0	2.0	2.3	2.6	2.6	2.7	(14)
(15)	Precipitation	PrecAvg	698	53	45	41	36	59	79	71	69	58	77	58	52	(15)
(16)		PrecMax	854	101	80	79	95	139	133	212	137	95	138	104	77	(16)
(17)		PrecMin	498	17	18	6	2	9	14	14	11	18	28	1	33	(17)
(18)		PrecStd	86	22	16	20	23	32	35	47	37	22	27	24	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.7	5.7	12.9	22.5	27.2	28.9	30.7	30.1	24.1	17.0	11.0	6.9	(19)
(20)			MCWB	5.0	4.2	6.9	12.6	17.8	19.2	21.8	22.5	16.7	12.9	9.7	5.8	(20)
(21)		2%	DB	3.9	4.4	9.9	19.4	24.7	27.0	28.5	26.7	21.1	14.4	9.3	5.5	(21)
(22)			MCWB	3.2	3.2	5.6	10.8	16.6	18.9	20.5	18.8	15.3	12.1	8.1	4.7	(22)
(23)		5%	DB	2.5	3.0	7.5	16.7	22.7	25.2	26.5	24.7	19.1	12.7	8.2	4.5	(23)
(24)			MCWB	1.8	2.1	4.5	10.1	15.1	18.1	19.6	18.0	14.3	11.0	7.2	3.8	(24)
(25)		10%	DB	1.5	2.1	5.7	14.2	20.4	23.2	24.6	23.1	17.4	11.4	7.3	3.4	(25)
(26)			MCWB	1.0	1.4	3.7	8.4	13.8	17.1	18.5	17.3	13.8	10.1	6.5	2.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	4.6	8.1	13.5	18.8	21.8	22.7	23.0	17.7	13.7	9.9	6.2	(27)
(28)			MCDWB	5.8	5.4	12.2	20.2	25.5	27.8	29.1	28.8	21.4	16.0	10.8	6.7	(28)
(29)		2%	WB	3.4	3.3	6.3	11.7	17.5	19.7	21.4	20.6	16.2	12.4	8.4	4.9	(29)
(30)			MCDWB	3.8	4.1	8.4	17.5	23.1	24.7	27.2	25.2	19.3	13.9	9.2	5.4	(30)
(31)		5%	WB	2.0	2.3	4.8	10.5	16.1	18.8	20.3	19.1	15.2	11.3	7.3	3.8	(31)
(32)			MCDWB	2.3	2.9	7.0	15.8	20.9	23.6	25.0	23.3	18.3	12.5	8.1	4.4	(32)
(33)		10%	WB	1.0	1.5	3.8	9.0	14.7	17.7	19.3	17.9	14.2	10.3	6.5	2.7	(33)
(34)			MCDWB	1.4	2.1	5.7	13.5	19.3	22.3	23.2	21.9	16.7	11.4	7.2	3.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	4.8	6.5	9.3	10.6	9.4	9.1	9.6	7.5	5.3	3.3	3.3	(35)
(36)			MCDBR	3.4	4.0	8.6	13.5	13.4	12.2	12.0	12.7	11.1	7.0	4.0	3.6	(36)
(37)			MCWBR	3.4	3.2	5.6	6.9	6.5	5.4	5.1	5.8	6.0	5.0	3.7	3.4	(37)
(38)		5% WB	MCDBR	3.4	3.8	7.6	11.9	11.5	10.4	10.4	10.8	8.9	6.3	4.0	3.6	(38)
(39)			MCWBR	3.4	3.3	5.4	6.6	6.1	5.4	5.0	5.6	5.3	4.9	3.8	3.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.286	0.318	0.351	0.390	0.381	0.375	0.407	0.405	0.369	0.345	0.328	0.285	(40)	
(41)		taud	2.173	2.160	2.199	2.246	2.341	2.384	2.313	2.314	2.391	2.399	2.256	2.183	(41)	
(42)		Ebn at Noon	590	720	797	822	858	867	827	800	779	698	535	487	(42)	
(43)		Edh at Noon	56	85	106	118	114	111	117	110	88	68	53	43	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.48	1.21	2.56	3.93	5.30	5.53	5.23	4.23	2.78	1.32	0.43	0.29	(44)	
(45)		RadStd	0.12	0.25	0.41	0.49	0.51	0.45	0.50	0.41	0.30	0.22	0.07	0.05	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page