

REZEKNE, Latvia

WMO: 264460

Lat: 56.5447N

Lon: 27.2806E

Elev: 158

StdP: 99.44

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.1	-18.1	-24.1	0.4	-20.7	-20.9	0.6	-17.5	8.7	0.6	8.0	-0.4	1.6	70	0.565

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	27.7	19.6	25.9	18.5	24.3	17.7	20.8	25.9	19.7	24.1	18.6	22.7	2.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	14.0	23.6	18.0	13.2	22.2	17.0	12.4	20.9	60.8	25.5	56.8	24.2	53.4	22.7	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.8	6.1	-25.3	30.1	3.8	1.6	-28.0	31.2	-30.2	32.1	-32.4	33.0	-35.1	34.1		
(5)			-25.5	22.4	3.8	1.7	-28.2	23.6	-30.4	24.6	-32.5	25.5	-35.3	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.0	-5.9	-5.0	-0.6	6.7	11.8	15.5	17.8	16.3	11.4	5.9	0.9	-3.0		
	DBStd	9.42	6.01	6.51	4.39	4.67	4.44	3.70	3.33	3.04	3.37	3.78	4.90	5.67		
	HDD10.0	2233	492	421	329	121	32	2	0	0	24	136	273	403		
	HDD18.3	4555	750	654	588	348	207	99	51	79	208	386	523	661		
	CDD10.0	791	0	0	0	23	88	168	242	196	66	8	0	0		
	CDD18.3	71	0	0	0	4	16	35	16	16	1	0	0	0		
	CDH23.3	569	0	0	0	2	38	117	270	137	6	0	0	0		
	CDH26.7	102	0	0	0	0	4	13	61	25	0	0	0	0		
(14) Wind	WSAvg	2.8	3.1	3.2	3.3	3.0	2.7	2.6	2.3	2.2	2.6	2.9	3.1	3.2		
(15) Precipitation	PrecAvg	658	47	38	34	34	66	81	69	72	56	64	53	45		
	PrecMax	820	94	62	86	77	136	185	178	131	105	119	114	84		
	PrecMin	503	14	13	15	1	20	22	16	9	14	13	1	26		
	PrecStd	84	17	13	15	20	30	41	37	36	25	29	23	13		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.3	5.8	12.4	23.1	27.1	28.2	30.5	29.5	24.0	17.2	10.4	7.9		
		MCWB	4.6	3.3	6.4	13.1	17.4	19.0	21.1	21.5	17.4	12.7	9.1	7.1		
	2%	DB	3.2	4.0	9.1	20.5	24.0	26.4	28.4	26.6	20.6	14.6	9.1	6.2		
		MCWB	2.6	2.7	4.7	11.6	16.5	18.4	20.4	18.9	15.6	11.6	8.0	5.3		
	5%	DB	1.9	3.0	6.7	17.6	21.8	24.6	26.3	24.6	18.7	12.6	7.8	4.7		
		MCWB	1.3	2.0	3.9	10.6	14.9	17.9	19.4	17.6	14.4	10.8	6.9	4.1		
	10%	DB	1.1	2.1	5.0	14.8	19.7	22.7	24.4	22.6	17.0	11.3	6.7	3.5		
		MCWB	0.6	1.3	2.9	9.2	13.7	17.0	18.3	16.7	13.7	9.8	6.1	2.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.7	4.1	7.5	14.1	18.7	20.9	22.5	22.2	18.2	13.6	9.6	7.4		
		MCDB	5.1	4.9	11.2	21.5	24.6	25.8	28.9	28.4	21.6	16.2	10.1	7.8		
	2%	WB	2.8	2.9	5.6	12.5	17.2	19.6	21.2	20.3	16.5	12.1	8.2	5.3		
		MCDB	3.2	3.6	7.6	18.4	22.6	24.3	26.7	25.0	19.3	13.8	8.9	5.9		
	5%	WB	1.5	2.1	4.2	11.2	15.9	18.6	20.2	18.7	15.2	11.1	7.0	4.2		
		MCDB	1.8	2.9	6.3	16.7	20.4	23.1	24.9	22.7	18.0	12.5	7.7	4.6		
	10%	WB	0.7	1.4	3.1	9.8	14.5	17.5	19.1	17.5	14.0	9.9	6.0	2.8		
		MCDB	1.0	2.0	4.8	14.3	18.6	21.8	22.9	21.4	16.5	11.2	6.7	3.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.3	5.2	6.4	8.9	10.2	9.2	9.3	9.6	7.8	5.8	3.8	3.6		
		MCDBR	3.2	3.8	8.4	12.9	12.7	11.7	12.1	12.4	10.5	7.7	4.6	3.6		
	5% WB	MCWBR	3.1	3.2	5.7	6.5	6.5	5.7	5.3	5.7	6.2	5.3	4.1	3.5		
		MCDWR	3.1	4.1	7.1	11.3	11.2	10.1	10.7	11.1	9.2	7.2	4.3	3.4		
(40) Clear-Sky Solar Irradiance	taub		0.281	0.314	0.344	0.385	0.377	0.370	0.401	0.401	0.365	0.341	0.321	0.279		
		taud	2.163	2.150	2.194	2.260	2.349	2.393	2.327	2.321	2.398	2.401	2.255	2.174		
	Ebn at Noon		595	724	804	828	861	871	832	805	784	703	543	493		
		Edh at Noon	56	85	106	116	113	110	115	109	87	68	53	43		
(44) All-Sky Solar Radiation	RadAvg		0.49	1.25	2.63	3.94	5.30	5.54	5.23	4.22	2.76	1.28	0.43	0.29		
	RadStd		0.12	0.24	0.38	0.50	0.51	0.43	0.53	0.39	0.29	0.22	0.07	0.06		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (20 neighbors)		+0.39	N/A	N/A	N/A	N/A	N/A	-136	N/A	N/A	N/A	

Nomenclature: See separate page